

ID	Name	Type	Constraint	Quality	Fallback	Access	Conformance
0	Pre-setHandle	octstr	max 16	X			M
1	PresetScenario	PresetScenarioEnum	all				M
2	Name	string	max 64	X	null		O
3	CoolingSetpoint	temperature	desc		26°C		COOL
4	HeatingSetpoint	temperature	desc		20°C		HEAT
5	BuiltIn	bool	all	X	false		M

4.3.8.24.1. PresetHandle Field

This field SHALL indicate a device generated identifier for this preset. It SHALL be unique on the device, and SHALL NOT be reused after the associated preset has been deleted.

This field SHALL only be null when the encompassing [PresetStruct](#) is appended to the [Presets](#) attribute for the purpose of creating a new Preset. Refer to [Presets](#) for the creation of Preset handles.

4.3.8.24.2. PresetScenario Field

This field SHALL indicate the associated [PresetScenarioEnum](#) value for this preset.

4.3.8.24.3. Name Field

This field SHALL indicate a name provided by a user. The null value SHALL indicate no name.

Within each subset of presets sharing the same PresetScenario field value, there SHALL NOT be any presets with the same value, including null as a value, in the Name field.

4.3.8.24.4. CoolingSetpoint Field

This field SHALL indicate the cooling setpoint for the preset. Refer to [Setpoint Limits](#) for value constraints.

4.3.8.24.5. HeatingSetpoint Field

This field SHALL indicate the heating setpoint for the preset. Refer to [Setpoint Limits](#) for value constraints.

4.3.8.24.6. BuiltIn Field

This field SHALL indicate whether the preset is marked as "built-in", meaning that it can be modi-