

4.3.8.29. ScheduleTypeStruct Type

ID	Name	Type	Constraint	Quality	Fallback	Access	Conformance
0	System-Mode	System-ModeEnum	desc				M
1	NumberOfSchedules	uint8	max NumberOfSchedules		0		M
2	Schedule-TypeFeatures	Schedule-TypeFeatures-Bitmap	desc		0		M

4.3.8.29.1. SystemMode Field

This field SHALL specify a [SystemModeEnum](#) supported by this thermostat for Schedules. The only valid values for this field SHALL be Auto, Heat, and Cool.

4.3.8.29.2. NumberOfSchedules Field

This field SHALL specify a limit for the number of Schedules for this SystemMode.

4.3.8.29.3. ScheduleTypeFeatures Field

This field SHALL specify a bitmap of features for this schedule entry. At least one of SupportsPresets and SupportsSetpoints SHALL be set.

4.3.8.30. TemperatureDifference Type

This data type is derived from int16 and represents a temperature difference with a resolution of 0.01°C.

- $value = (temperature\ in\ ^\circ C) \times 100$

- $-4^\circ C \Rightarrow -400$
- $123.45^\circ C \Rightarrow 12345$

The full (non-null) range of $-327.67^\circ C$ to $327.67^\circ C$ may be used.

4.3.8.31. SignedTemperature Type

This data type is derived from int8 and represents a temperature from $-12.7^\circ C$ to $12.7^\circ C$ with a resolution of 0.1°C.

- $value = (temperature\ in\ ^\circ C) \times 10$