

ID	Name	Type	Constraint	Quality	Fallback	Access	Conformance
0x0018	Max-CoolSet-pointLimit	tempera- ture	desc	N	AbsMax-CoolSet-pointLimit	RW VM	[COOL]
0x0019	MinSet-point-DeadBand	SignedTemperature	0 to 12.7°C	N	2°C	R[W] VM	AUTO
0x001A	Remote-Sensing	Remote-Sensing-Bitmap	all	N	0	RW VM	O
0x001B	ControlSequenceOf-Operation	ControlSequenceOf-OperationEnum	desc	N		RW VM	M
0x001C	System-Mode	System-ModeEnum	desc	N		RW VM	M
0x001E	Thermosta-tRunning-Mode	ThermostatRunning-ModeEnum	desc		0	R V	[AUTO]
0x0020	StartOfWeek	StartOfWeekEnum	desc	F		R V	SCH
0x0021	Num-berOfWeeklyTransi-tions	uint8	all	F		R V	SCH
0x0022	Num-berOfDailyTransi-tions	uint8	all	F		R V	SCH
0x0023	Tempera-tureSet-pointHold	TemperatureSet-pointHold-Enum	desc	N	0	RW VM	O
0x0024	Tempera-tureSet-pointHold-Duration	uint16	max 1440	N X	null	RW VM	O