

ID	Name	Type	Constraint	Quality	Fallback	Access	Conformance
0x0025	Thermostat-ProgrammingOperationMode	ProgrammingOperationModeBitmap	desc	P	0	RW VM	O
0x0029	ThermostatRunningState	RelayStateBitmap	desc		-	R V	O
0x0030	SetpointChangeSource	SetpointChangeSourceEnum	desc		0	R V	O
0x0031	SetpointChangeAmount	TemperatureDifference	all	X	null	R V	O
0x0032	SetpointChangeSource-Timestamp	epoch-s	all		MS	R V	O
0x0034	Occupied-Setback	UnsignedTemperature	Occupied-Setback-Min to Occupied-Setback-Max	N X		RW VM	SB
0x0035	Occupied-Setback-Min	UnsignedTemperature	max OccupiedSetbackMax	F X		R V	SB
0x0036	Occupied-Setback-Max	UnsignedTemperature	Occupied-Setback-Min to 25.4°C	F X		R V	SB
0x0037	UnoccupiedSetback	UnsignedTemperature	UnoccupiedSetbackMin to UnoccupiedSetbackMax	N X		RW VM	SB & OCC