

ID	Name	Type	Constraint	Quality	Fallback	Access	Conformance
0x0038	UnoccupiedSet-backMin	UnsignedTemperature	max UnoccupiedSet-backMax	F X		R V	SB & OCC
0x0039	UnoccupiedSet-backMax	UnsignedTemperature	UnoccupiedSet-backMin to 25.4°C	F X		R V	SB & OCC
0x003A	EmergencyHeat-Delta	UnsignedTemperature	all	N	25.5°C	RW VM	O
0x0040	ACType	ACTypeEnum	desc	N	0	RW VM	O
0x0041	ACCapacity	uint16	all	N	0	RW VM	O
0x0042	ACRefrigerantType	ACRefrigerantTypeEnum	desc	N	0	RW VM	O
0x0043	ACCompressorType	ACCompressorTypeEnum	desc	N	0	RW VM	O
0x0044	ACError-Code	ACError-CodeBitmap	all		0	RW VM	O
0x0045	ACLouver-Position	ACLouver-PositionEnum	desc	N	0	RW VM	O
0x0046	ACCoil-Temperature	temperature	all	X	null	R V	O
0x0047	ACCapacityFormat	ACCapacityFormatEnum	desc	N	0	RW VM	O
0x0048	Preset-Types	list[Preset-Type-Struct]	1 to 7	F		R V	PRES
0x0049	Schedule-Types	list[ScheduleType-Struct]	1 to 3	F		R V	MSCH