

the **BuiltIn** field on the pending **ScheduleStruct** SHALL be set to the value of the **BuiltIn** on the matching **ScheduleStruct**.

- ii. Otherwise, the **BuiltIn** field on the pending **ScheduleStruct** SHALL be set to false.

On an attempt to commit, the status of this attribute SHALL be determined as follows:

1. For all existing **schedules**:
 - a. If, after applying all pending changes, the updated value of the **Schedules** attribute would not contain a **ScheduleStruct** with a matching **ScheduleHandle** field, indicating the removal of the **ScheduleStruct**, the server SHALL check for invalid removal of the **ScheduleStruct**:
 - i. If the **BuiltIn** field is true on the removed **ScheduleStruct**, the attribute status SHALL be **CONSTRAINT_ERROR**.
 - ii. If the removed **ScheduleHandle** is equal to the value of the **ActiveScheduleHandle** attribute, the attribute status SHALL be **INVALID_IN_STATE**.
2. Otherwise, the attribute status SHALL be **SUCCESS**.

4.3.9.61. SetpointHoldExpiryTimestamp Attribute

If there is a known time when the **TemperatureSetpointHold** SHALL be cleared, this attribute SHALL contain the timestamp in UTC indicating when that will happen. If there is no such known time, this attribute SHALL be null.

If the **TemperatureSetpointHold** is set to **SetpointHoldOn** and the **TemperatureSetpointHoldDuration** is set to null, this attribute SHALL be set to null indicating there is a hold on the Thermostat without a duration.

If the **TemperatureSetpointHold** is set to **SetpointHoldOff**, this attribute SHALL be set to null indicating there is no hold on the Thermostat.

4.3.10. Commands

ID	Name	Direction	Response	Access	Conformance
0x00	Set-pointRaiseLower	client ⇒ server	Y	O	M
0x01	SetWeeklySchedule	client ⇒ server	Y	M	SCH
0x02	GetWeeklySchedule	client ⇒ server	GetWeeklyScheduleResponse	O	SCH
0x00	GetWeeklyScheduleResponse	client ⇐ server	N		SCH
0x03	Clear-WeeklySchedule	client ⇒ server	Y	M	SCH