

9.2.7.6. AdjustmentCauseEnum Type

This data type is derived from enum8.

Value	Name	Summary	Conformance
0	LocalOptimization	The adjustment is to optimize the local energy usage	M
1	GridOptimization	The adjustment is to optimize the grid energy usage	M

9.2.7.7. ForecastUpdateReasonEnum Type

This data type is derived from enum8.

Value	Name	Summary	Conformance
0	InternalOptimization	The update was due to internal ESA device optimization	M
1	LocalOptimization	The update was due to local EMS optimization	M
2	GridOptimization	The update was due to grid optimization	M

9.2.7.8. PowerAdjustReasonEnum Type

This data type is derived from enum8.

Value	Name	Summary	Conformance
0	NoAdjustment	There is no Power Adjustment active	M
1	LocalOptimizationAdjustment	There is PowerAdjustment active due to local EMS optimization	M
2	GridOptimizationAdjustment	There is PowerAdjustment active due to grid optimization	M

9.2.7.9. CostStruct Type

This indicates a generic mechanism for expressing cost to run an appliance, in terms of financial, GHG emissions, comfort value etc.