

9.5.6. Data Types

9.5.6.1. WaterHeaterHeatSourceBitmap Type

This data type is derived from map8.

Bit	Name	Summary	Conformance
0	ImmersionElement1	Immersion Heating Element 1	M
1	ImmersionElement2	Immersion Heating Element 2	M
2	HeatPump	Heat pump Heating	M
3	Boiler	Boiler Heating (e.g. Gas or Oil)	M
4	Other	Other Heating	M

9.5.6.2. BoostStateEnum Type

This data type is derived from enum8.

Value	Name	Summary	Conformance
0	Inactive	Boost is not currently active	M
1	Active	Boost is currently active	M

9.5.6.3. WaterHeaterBoostInfoStruct Type

ID	Name	Type	Constraint	Quality	Fallback	Access	Conformance
0	Duration	elapsed-s	min 1				M
1	OneShot	bool	all		False		[!TP], [TP].a-
2	EmergencyBoost	bool	all		False		O
3	TemporarySet-point	temperature	desc				O
4	TargetPercentage	percent	all				TargetRe-heat, [TP]
5	TargetRe-heat	percent	max TargetPercentage				[TP].a-