

9.5.7. Attributes

ID	Name	Type	Constraint	Quality	Fallback	Access	Conformance
0x0000	Heater-Types	Water-Heater-Heat-SourceBit map	all	F		R V	M
0x0001	HeatDemand	Water-Heater-Heat-SourceBit map	all			R V	M
0x0002	TankVolume	uint16	all			R V	EM
0x0003	EstimatedHeatRequired	energy-mWh	min 0			R V	EM
0x0004	TankPercentage	percent	all			R V	TP
0x0005	BoostState	BoostStateEnum	all			R V	M

9.5.7.1. HeaterTypes Attribute

This attribute SHALL indicate the heat sources that the water heater can call on for heating. If a bit is set then the water heater supports the corresponding heat source.

9.5.7.2. HeatDemand Attribute

This attribute SHALL indicate if the water heater is heating water. If a bit is set then the corresponding heat source is active.

9.5.7.3. TankVolume Attribute

This attribute SHALL indicate the volume of water that the hot water tank can hold (in units of Litres). This allows an energy management system to estimate the required heating energy needed to reach the target temperature.

9.5.7.4. EstimatedHeatRequired Attribute

This attribute SHALL indicate the estimated heat energy needed to raise the water temperature to the target setpoint. This can be computed by taking the specific heat capacity of water (4182 J/kg °C) and by knowing the current temperature of the water, the tank volume and target temperature.