

9.13.5.2.4. GridCarbonLevel Field

This field SHALL indicate the relative level of carbon intensity of the grid. This is not impacted by any local generation.

It is up to the cluster server to determine the thresholds of High, Medium or Low based upon typical grid carbon levels for this region or market, since this can vary significantly between countries across the world.

9.13.5.2.5. LocalCarbonIntensity Field

This field SHALL indicate the estimated carbon intensity in grams of CO₂ equivalent per kWh of the premises mains supply. This value SHALL take into account the impact of any local generation.

For example, if an EMS can forecast that excess generation will occur in a period or the premises are currently generating excess power to the grid, then this could assume a value of 0 grams CO₂ equivalent per kWh for this period.

When solar PV is not being exported to the grid then this value is typically the same as the GridCarbonIntensity.

Clients are expected to use this value when computing or displaying the local premises carbon intensity to users.

If there is no local generation, this value SHALL be the same as the GridCarbonIntensity at all times.

9.13.5.2.6. LocalCarbonLevel Field

This field SHALL indicate the relative level of carbon intensity of the premises mains supply. This level SHALL take into account impact of any local generation.

It is up to the cluster server to determine the thresholds of High, Medium or Low based upon typical grid carbon levels for this region or market, since this can vary significantly between countries across the world.

When local power generation (for example from solar PV) is not being exported to the grid then this level is the same as the GridCarbonLevel.

Clients are expected to use this value when displaying the local premises carbon intensity to users.

If there is no local generation, this value SHALL be the same as the GridCarbonLevel at all times.

9.13.6. Attributes

ID	Name	Type	Constraint	Quality	Fallback	Access	Conformance
0x0000	LocalGenerationAvailable	bool	all	X		RW VO	M