

4.3.4. Cluster Requirements

Each endpoint supporting this device type SHALL include these clusters based on the conformance defined below.

Table 2. Color Temperature Light Cluster Requirements

Cluster ID	Cluster Name	Client/Server	Quality	Conformance
0x0003	Identify	Server		M
0x0004	Groups	Server		M
0x0006	On/Off	Server		M
0x0008	Level Control	Server		M
0x0062	Scenes Management	Server		M
0x0300	Color Control	Server		M
0x0406	Occupancy Sensing	Client		O

4.3.5. Element Requirements

The table below lists qualities and conformance that override the cluster specification requirements. A blank table cell means there is no change to that item and the value from the cluster specification applies.

Cluster ID	Cluster Name	Element	Name	Constraint	Access	Conformance
0x0003	Identify	Command	TriggerEffect			M
0x0006	On/Off	Feature	Lighting			M
0x0008	Level Control	Feature	OnOff			M
0x0008	Level Control	Feature	Lighting			M
0x0008	Level Control	Attribute	CurrentLevel	1 to 254		
0x0008	Level Control	Attribute	MinLevel	1		
0x0008	Level Control	Attribute	MaxLevel	254		
0x0062	Scenes Management	Command	CopyScene			M
0x0300	Color Control	Feature	ColorTemperature			M