

Cluster ID	Cluster Name	Client/Server	Quality	Conformance
0x0004	Groups	Client		M
0x0006	On/Off	Client		M
0x0008	Level Control	Client		M
0x0062	Scenes Management	Client		M
0x0300	Color Control	Client		M
0x0400	Illuminance Measurement	Client		O
0x0406	Occupancy Sensing	Client		O

6.5. Pump Controller Device Type

A Pump Controller device is capable of configuring and controlling a Pump device.

6.5.1. Revision History

Revision	Description
1	Initial Zigbee 3.0 revision
2	New data model format and notation
3	Updated the Scenes cluster to Scenes Management with Cluster ID: 0x0062
4	Remove Binding client as a result of review of CCB4058

6.5.2. Classification

Device Type ID	Device Type Name	Superset Of	Class	Scope
0x0304	Pump Controller		Simple	Endpoint

6.5.3. Conditions

See the Base Device Type definition for conformance tags.

6.5.4. Cluster Requirements

Each endpoint supporting this device type SHALL include these clusters based on the conformance defined below.