

Chapter 7. Sensor Device Types

7.1. Contact Sensor Device Type

This defines conformance to the Contact Sensor device type.

7.1.1. Revision History

Revision	Description
1	Initial revision
2	Add Boolean State Configuration as optional cluster

7.1.2. Classification

Device Type ID	Device Type Name	Superset Of	Class	Scope
0x0015	Contact Sensor		Simple	Endpoint

7.1.3. Conditions

See the Base Device Type definition for conformance tags.

7.1.4. Cluster Requirements

Each endpoint supporting this device type SHALL include these clusters based on the conformance defined below.

Cluster ID	Cluster Name	Client/Server	Quality	Conformance
0x0003	Identify	Server		M
0x0045	Boolean State	Server		M
0x0080	Boolean State Configuration	Server		O

7.1.4.1. Identify Cluster

This is used to identify the endpoint.

7.1.4.2. Boolean State Cluster

This is used to indicate the state of the sensor/detector.

The state of the Boolean State cluster SHALL reflect the sensor detection using this scheme: