

### 7.3.4.3. Occupancy Sensing Cluster

This is used to indicate occupancy as well as the type of occupancy sensor used for detection and configuring the delays related to the occupied and unoccupied transitions.

### 7.3.5. Multi-modality sensors

The Occupancy Sensing cluster defines multiple modalities that can be employed to sense occupancy. A device implementing multiple such modalities (exposed in the feature flags) can be implemented in two ways:

- A single endpoint with an Occupancy Sensing cluster which has two or more of these feature bits set to 1.
  - This requires reporting the combination the sensing results as a single bit in the Occupancy attribute (and the OccupancyChanged event, when supported), with a single set of timing parameters applied.
  - Sensitivity setting (via a Boolean State Configuration cluster on the same endpoint) applies to all the sensing modalities together via a manufacturer-specific mapping.
- Multiple endpoints each hosting an Occupancy Sensing cluster (each with one feature bit set):
  - The sensing result of each modality is reported separately in the Occupancy attribute (and the OccupancyChanged event, when supported) of each endpoint, governed by the set of timing parameters provided in the cluster on that endpoint.
    - This implies some of these attributes can have a different values than their counterparts on other endpoints and that a client MAY have to combine these values if it wants to derive a single value.
  - Each modality can be provided with an independent sensitivity setting via a Boolean State Configuration cluster located on one or more of the endpoints.

## 7.4. Temperature Sensor Device Type

A Temperature Sensor device reports measurements of temperature.

### 7.4.1. Revision History

| Revision | Description                                           |
|----------|-------------------------------------------------------|
| 1        | Initial Zigbee 3.0 revision                           |
| 2        | New data model format and notation                    |
| 3        | Added Thermostat User Interface Configuration cluster |

### 7.4.2. Classification