

Device Type ID	Device Type Name	Superset Of	Class	Scope
0x0302	Temperature Sensor		Simple	Endpoint

7.4.3. Conditions

See the Base Device Type definition for conformance tags.

7.4.4. Cluster Requirements

Each endpoint supporting this device type SHALL include these clusters based on the conformance defined below.

Cluster ID	Cluster Name	Client/Server	Quality	Conformance
0x0402	Temperature Measurement	Server		M
0x0003	Identify	Server		M
0x0204	Thermostat User Interface Configuration	Server		O

7.4.4.1. Thermostat User Interface Configuration Cluster

This cluster provides an interface to allow configuration of the user interface for a temperature sensor that supports keypad or screen.

7.4.5. Element Requirements

The table below lists qualities and conformance that override the cluster specification requirements. A blank table cell means there is no change to that item and the value from the cluster specification applies.

Cluster ID	Cluster Name	Element	Name	Constraint	Access	Conformance
0x0204	Thermostat User Interface Configuration	Attribute	KeypadLock-out			O

7.5. Pressure Sensor Device Type

A Pressure Sensor device measures and reports the pressure of a fluid.