

8.6. Closure Panel Device Type

A Closure Panel SHALL ONLY exist as a part (child) of a [Closure](#) device type. It represents a single panel aspect (e.g. position of a blind, tilt of slats, etc) within that Closure.

This panel can be used to express the following:

- Translation : panel translates along one axis
- Rotation : panel rotates around an axis of rotation
- Modulation : panel modifies its aspect to modulate a flow

A Closure Panel SHALL use exactly one semantic tag from the ClosurePanel namespace (0x45) in the TagList attribute of the Descriptor cluster to describe the spatial aspect of the dimension, e.g., "Lift", "Tilt", etc.

8.6.1. Revision History

Revision	Description
1	Initial revision

8.6.2. Classification

Device Type ID	Device Type Name	Superset Of	Class	Scope
0x0231	Closure Panel		Simple	Endpoint

8.6.3. Cluster Requirements

Each endpoint supporting this device type SHALL include these clusters based on the conformance defined below.

Cluster ID	Cluster Name	Client/Server	Quality	Conformance
0x0102	Window Covering	Server		X
0x0104	Closure Control	Server		X
0x0105	Closure Dimension	Server		M

In revision 1 of this device type, the Window Covering cluster SHALL NOT appear on the same endpoint. This restriction prevents conflicts between potential future standardized use of the Window Covering cluster and any existing non-standard implementations, until appropriate data dependency language is defined.

8.6.4. Element Requirements

The table below lists qualities and conformance that override the cluster specification requirements. A blank table cell means there is no change to that item and the value from the cluster speci-