

Chapter 9. HVAC Device Types

9.1. Thermostat Device Type

A Thermostat device is capable of having either built-in or separate sensors for temperature, humidity or occupancy. It allows the desired temperature to be set either remotely or locally. The thermostat is capable of sending heating and/or cooling requirement notifications to a heating/cooling unit (for example, an indoor air handler) or is capable of including a mechanism to control a heating or cooling unit directly.

9.1.1. Revision History

Revision	Description
1	Initial Zigbee 3.0 revision
2	New data model format and notation, added Clusters required for Matter support, restricted legacy elements to Zigbee only
3	Addition of Energy Preference cluster and updated the Scenes cluster to Scenes Management with Cluster ID: 0x0062
4	Remove Time Synchronization cluster, Scenes Management and Zigbee only clusters, remove provisional marking from Energy Preference cluster

9.1.2. Classification

Device Type ID	Device Type Name	Superset Of	Class	Scope
0x0301	Thermostat		Simple	Endpoint

9.1.3. Conditions

See the Base Device Type definition for conformance tags.

9.1.4. Cluster Requirements

Each endpoint supporting this device type SHALL include these clusters based on the conformance defined below.

Cluster ID	Cluster Name	Client/Server	Quality	Conformance
0x0003	Identify	Server		M
0x0004	Groups	Server		Active