

- This Electrical Energy Measurement cluster SHOULD support the CumulativeEnergy feature.

14.3.6.4. Semantic Tag Requirements on Component Device Types

The Descriptor cluster for the endpoint including the Power Source device SHALL include the Grid tag if it is connected to the premises wiring.

If a Solar Power device supports two or three phase power output then it MAY include two or three additional endpoints, each including an Electrical Sensor Device Type as child elements. For each such child endpoint it SHALL include a semantic tag from the Electrical Measurement Namespace in the TagList attribute of the Descriptor cluster to describe the endpoint for the relevant Electrical Power Measurement and Electrical Energy Measurement clusters indicating the relevant AC phase that is being measured.

If a Solar Power device supports measurement of the output of individual solar panels or strings of solar panels then it MAY include additional endpoints for each such measurement, including an Electrical Sensor Device Type as child elements. For each such child endpoint:

- It SHALL include a semantic tag from a Common Namespace, or a Manufacturer defined Tag and Label, in the TagList attribute of the Descriptor cluster to describe the endpoint for the relevant Electrical Power Measurement and Electrical Energy Measurement clusters, indicating the relevant device port, panel, or string of panels that is being measured.

Any Temperature Sensors included SHALL include Tag(s), and for non-standard Namespaces, Label(s) in the Descriptor clusters of their endpoints to identify the temperature being measured.

14.4. Battery Storage Device Type

A Battery Storage device is a device that allows a DC battery, which can optionally be comprised of a set parallel strings of battery packs and associated controller, and an AC inverter, to be monitored and controlled by an Energy Management System in order to manage the peaks and troughs of supply and demand, and/or to optimize cost of the energy consumed in premises. It is not intended to be used for a UPS directly supplying a set of appliances, nor for portable battery storage devices.

14.4.1. Battery Storage Architecture

A Battery Storage device is always defined via endpoint composition. See [Section 14.4.6, “Device Type Requirements”](#) for more details.

An example of a Battery Storage device with single phase AC output is illustrated below.