

14.4.3. Classification

Device Type ID	Device Type Name	Superset Of	Class	Scope
0x0018	Battery Storage		Simple	Endpoint

14.4.4. Conditions

See the Base Device Type definition for conformance tags.

14.4.5. Cluster Requirements

Each endpoint supporting this device type SHALL include these clusters based on the conformance defined below.

Cluster ID	Cluster Name	Client/Server	Conformance
0x0003	Identify	Server	O

14.4.6. Device Type Requirements

A Battery Storage device SHALL be composed of at least two endpoints with device types as defined by the conformance below. There MAY be more endpoints with additional instances of these device types or additional device types existing in the Battery Storage device.

Device Type ID	Device Type Name	Constraint	Conformance
0x0011	Power Source	min 2	M
0x0017	Solar Power		O
0x0302	Temperature Sensor		O
0x050D	Device Energy Management		M
0x0510	Electrical Sensor	min 2	M

The Solar Power devices, if included, SHALL have separate endpoints, and include their own Power Source, Electrical Sensor, and Device Energy Management devices, as defined by the [Solar Power](#) device.

14.4.6.1. Cluster Requirements on Component Device Types

The table below lists qualities and conformance that override the cluster requirements for the component device types.

Device Type ID	Device Type Name	Cluster ID	Cluster Name	Client/Server	Conformance
Electrical Sensor (1st)					