

Device Type ID	Device Name	Cluster ID	Cluster Name	Element	Name	Con-straint	Access	Confor-mance
0x0510	Electrical Sensor	0x0090	Electrical Power Measurement	Feature	Alternat-ingCur-rent			M
0x0510	Electrical Sensor	0x0090	Electrical Power Measurement	Attribute	Voltage			M
0x0510	Electrical Sensor	0x0090	Electrical Power Measurement	Attribute	Active-Current			M

If a Heat Pump device supports two or three phase power input then it MAY include two or three additional endpoints, each including an Electrical Sensor Device Type as child elements. For each such child endpoint it SHALL include a semantic tag from the Electrical Measurement Namespace in the TagList attribute of the Descriptor cluster to describe the endpoint for the relevant Electrical Power Measurement and Electrical Energy Measurement clusters indicating the relevant AC phase that is being measured.

The Electrical Energy Measurement and Electrical Power Measurement clusters of the mandatory Electrical Sensor device SHALL measure the energy and power of the Heat Pump device at the AC grid connection point.

The Electrical Power Measurement clusters of the mandatory Electrical Sensor device SHALL support the PolyPhasePower feature if the Heat Pump device is connected via polyphase wiring.

The Electrical Energy Measurement cluster of the mandatory Electrical Sensor device SHOULD support the ImportedEnergy and CumulativeEnergy features.

Any Temperature Sensors using non-standard Namespaces for their Tags SHALL include Label(s) in the Descriptor clusters of their endpoints to identify the temperature being measured.

Any Thermostat SHALL include a semantic tag from a Common Namespace, or a Manufacturer defined Tag and Label, in the TagList attribute of the Descriptor cluster to describe the endpoint for the relevant Thermostat clusters, indicating the relevant device (or its connected port) that is being measured. It SHALL also include a User Label cluster to allow an installer to add identifying information for the rooms or spaces where the Thermostat measurement point is located.

14.5.6.3. Semantic Tag Requirements on Component Device Types

The table below lists conformance requirements for semantic tags associated with the device types listed in the table when used in a composition.