# Work Completion Report (Form-4)

**(To be submitted by the applicant)**

**To,**
The Circle solar executive/SDO/Executive Engineer (Ele),
CED Jajpur, Subdivision/Division/Circle, TPNODL

**Sub:** Submission of work completion report for System documentation requirements.

**Ref:** Your PMSGY REG. N0.- NP-ODTN026-10625985/05-03-2026

**Sir,**

With reference to the above, I would like to submit the following basic information of my Solar Rooftop PV System (SRTPV System) for your kind perusal and request for arranging to Inspect and Commission at the earliest:

| | | |
|---|---|---|
| **A. Details of the Application:** | | |
| | | |
| 1<br>2 | Application FG No/Date<br>Application fees in Rs. | 31312092606481/12-09-2026 |
| **B. Details of the Solar PV Module:** | | |
| 1 | Model No. | BIFICIAL |
| 2 | Total Capacity in kWp | 3.32 KWP |
| 3 | Make | LUMINOUS |
| 4 | Sl. NO | **16QGUBR1244719**<br>**16QGUBR1244927**<br>**86QJVCR1175725**<br>**86QJVCR1175737**<br>**86QJVCR1175768**<br>**86QJVCR1175814** |
| 5 | Total No. of PV Modules | 6 Nos |
| 6 | Capacity of each Module in kWp | 555Kwp-4PIC,550Kwp-2PIC |
| 7 | Date of Installation | 12 SEP 2026 |
| 8 | Date of Commission | 12 SEP 2026 |
| **C. Details of the Inverter:** | | |
| **1** | Total No of Inverter | 1 Nos |
| 2 | Name of the inverter (Type) | Grid-Tied Inverter |
| 3 | Make | LUMINOUS |
| 4 | Model No. | NXIT130 3KW/1P-230V,50Hz |
| 5 | Capacity | 3 KW |
| 6 | Serial No. | G7QGZDB1001678 |

| | | |
|---|---|---|
| 7 | Input Voltage | 300V DC |
| 8 | Output Voltage | 220-240V AC |
| 9 | Date of Installation | 12 SEP 2026 |
| 10 | Date of Commission | 12 SEP 2026 |
| **D. Details of Cables: DC** | | |
| 1 | Make | KEI |
| 2 | Size & Type | 4 SQ MM |
| **E. Details of AC Wiring:** | | |
| 1 | Make | KEI |
| 2 | Size & Type | 4 SQ MM |
| **F. Details of the DC distribution box:** | | |
| 1 | Make | HAVELLS |
| 2 | Sl. No. | |
| 3 | DC Surge Protection Device rating | |
| 4 | MCB / Isolator quantity & capacity | 32 AMP |
| **G. Details of AC distribution box:** | | |
| 1 | Make | HAVELLS |
| 2 | Sl. No. | |
| 3 | AC Surge Protection Device rating | |
| 4 | MCB / MCCB quantity & capacity | 32 AMP |
| **H. Details of Earthing:** | | |
| 1 | Earth resistance (in ohms) | 3 OHM |
| 2 | Size of the Earth wire / flat*(Copper/Al) | 16SQ MM Aluminum |
| 3 | Two separate earthing points | YES |
| 4 | Lightening Arrester | YES |
| 5 | LA Size & Type | Copper Bonded |
| **Note:*** Earthing shall be done in accordance IS 3043-1986 | | |
| **I. Details of the NET and Solar meters details (please enclose the test report of the bidirectional meter tested at MRT division, TPNODL)** | | |
| 1 | No of Net Meter | |
| 2 | Make | |
| 3 | Serial No. | |
| 4 | Capacity | |
| 5 | Type/Model | |
| 6 | Single ph./Three ph. | |
| 7 | Line CT/ PT Ratio | |
| 8 | Date of Test by MRT, TPNODL | |

| | | |
|---|---|---|
| 1 | No. of Solar Meters | |
| 2 | Make | |
| 3 | Serial No. | |
| 4 | Capacity | |
| 5 | Type/Model | |
| 6 | Single ph./Three ph. | |
| 7 | Line CT/ PT Ratio | |
| 8 | Date of Test by MRT, TPNODL | |
| **J. Details of the Caution signs** | | |
| (Size of the caution label: 105 mm width X 20 mm height, with white letters on a red background) | | |
| | | |
| 1 | Panels | |
| 2 | Inverters | |
| 3 | DC/ AC distribution box | |
| **K. Provision of manual and automatic switches: Yes / No** | | |
| **L. Whether Operation and Maintenance information:** | | |
| **Such as Do's and Don'ts are provided by the System Installer: Yes*/ No*.** | | |

Certified that the above said SPV system was installed by me and the equipment used, comply with the Technical and Safety standards as specified by CEA/MNRE/IEGC/OGC/OERC and TPNODL's requirement.

**Signature of the Applicant**
**Name:- SAROJ KUMAR MAHAPATRA**
**Address**:- AT-MANGALPUR,JAJPUR TOWN-II
**Dist-**JAJPUR, PIN-755011
**Date:**

**Name and Signature of the System Installer with Seal**
**Name of the firm:** Shri Trutiyadev Solar Enterprises
**Address:** AT-Talamundali,PO- Kankadajodi, PS-Maniabandha, Dist-Cuttack PIN-754035
**Date:**

**Certified by**
**Circle solar executive/SDO/Executive Engineer, TPNODL**
**Date:**

**Enclosures:**

1. Test report of bi-directional meter tested at MMG/MRT division, TPNODL.
2. Copy of the IEC/IS Test reports/ certificate of PV modules, Inverter, Cable etc.
3. Data sheets/Drawing for the array mounting System.
4. Actual Single line wiring diagram of the SPV System.
5. Copy of Maintenance & Operation information provided by the System Installer.