



Photo:3	Date:06/16/2022	Location:WL: 3, FL: 2
Condition Description: DETERIORATED BRICK MASONRY	Recommendation: REPLACE DETERIORATED BRICKS	
Causes: AGE & WEATHERING OR MOISTURE INFILTRATION	Quantity: 8	