

**Photo:1****Date:06/16/2022****Location:WL: 1, FL: 2**

Condition Description: DETERIORATED BRICK
MASONRY

Recommendation: REPLACE DETERIORATED
BRICKS

Causes: AGE & WEATHERING OR MOISTURE
INFILTRATION

Quantity: 2