

City of Fixture Ordinance 2025-7

Local amendments to Title 99 (synthetic; not real law).
Adopted March 1, 2025.

Contents

AM-1 AM-1 Guardrail systems (local amendment to § 2.8)

AM-2 AM-2 Training frequency and exit access width (local amendments to § 1.4(b) and § 2.10(b))

AM-1 Guardrail systems (local amendment to § 2.8)

Within the City of Fixture, § 2.8 of Title 99 is replaced by the following:

(a) Top rail height. The top edge height of a top rail, or equivalent guardrail system member, shall be 48 inches (122 cm), plus or minus 2 inches (5 cm), above the walking-working surface.

(b) Midrails. Two midrails shall be installed, at one-third and two-thirds of the top rail height, wherever there is no wall or parapet at least 24 inches (61 cm) high. Intermediate vertical members, where used instead of midrails, shall be no more than 12 inches (30 cm) apart.

(c) Strength. A guardrail system shall be capable of withstanding, without failure, a force of at least 300 pounds (1,335 N) applied in a downward or outward direction at any point along the top rail. Midrails and intermediate members shall be capable of withstanding a force of at least 200 pounds (890 N).

(d) Toeboards. A toeboard at least 4 inches (10 cm) high shall be installed wherever a guardrail system is required, whether or not objects could fall to a lower level.

(e) Other criteria. Paragraphs (e) and (f) of § 2.8 of Title 99 (construction, and openings around holes) apply within the city unchanged.

(f) Applicability. This amendment applies to a guardrail system installed or substantially altered on or after March 1, 2025. A guardrail system that complied with § 2.8 of Title 99 before that date may remain in service until it is replaced.

Reserved

AM-2 Training frequency and exit access width (local amendments to § 1.4(b) and § 2.10(b))

(a) Training frequency. Within the City of Fixture, the periodic training required by § 1.4(b) of Title 99 shall be provided at least once every 12 months, and the phrase "periodically thereafter" in that paragraph is read as "at least annually thereafter". The remainder of § 1.4 applies unchanged.

(b) Exit access width. Within the City of Fixture, the minimum width of an exit access under § 2.10(b) of Title 99 is 36 inches (91 cm) rather than 28 inches (71 cm). The ceiling height requirement and the remainder of § 2.10 apply unchanged.

(c) Applicability. Paragraph (b) of this amendment applies to exit routes in a building constructed, or substantially altered, on or after March 1, 2025. Paragraph (a) applies to every employer in the city from that date.