




CURRENT TECHNOLOGY PART NUMBER	1 CRIMP CONNECTOR RoHS COMPLIANT		3 WIRE TYPE #8 AWG – UL STYLE 1028, CSA TEW STRANDED, TINNED COPPER, RoHS COMPLIANT INSULATION, PVC, 600 V, 105C° INSULATION COLOR, GREEN / YELLOW				2 CRIMP CONNECTOR RoHS COMPLIANT	
	MFG. – P/N	CURRENT TECH. P/N	MANUFACTURER	MANUFACTURER P/N	CURRENT TECH. P/N	WIRE LENGTH	MFG. – P/N	CURRENT TECH. P/N
500–0144–001	T&B – RD367	212–0020–001	ALLIED WIRE & CABLE	1028–8–133T–5/4	224–0017–004	8 INCHES	T&B – RD367	212–0020–001
500–0144–002	T&B – RD367	212–0020–001	ALLIED WIRE & CABLE	1028–8–133T–5/4	224–0017–004	14 INCHES	T&B – RD367	212–0020–001
500–0144–003	T&B – RD367	212–0020–001	ALLIED WIRE & CABLE	1028–8–133T–5/4	224–0017–004	14 INCHES	T&B – RD717	212–0021–001

COO	Fix Tolerance Values	RJD	MAG	08/26/14
BOO	REVISION UPDATED FOR ECN-2310	MAG	MWG	08/01/13
AO2	ADDED 500–0144–003	MAG	MWG	06/01/12
A	INITIAL RELEASE	MAG	MWG	08/30/10
ISSUE	DESCRIPTION	BY	APPVD	DATE

Thomas&Betts
Power Solutions

5900 EASTPORT BLVD - RICHMOND, VA 23231-4453

THIS DOCUMENT IS THE PROPERTY OF T&B POWER SOLUTIONS. UNDER COPYRIGHT LAW, NO PART OF THIS DOCUMENT, REPRODUCTIONS OF IT, OR INFORMATION DERIVED FROM IT IS TO BE GIVEN TO OTHERS WITHOUT WRITTEN AUTHORIZATION FROM T&BPS

STATUS	SCALE	DRWN: MAG	CHKD: MWG
ORDER	N/A	APPVD:	DATE: 08/30/10

TITLE 8 AWG, 600 V CABINET DOOR GROUND STRAP	DWG, SIZE, NUMBER 500–0144–000	COO
	SHEET 1 OF 1	

–	–	–	–	–	–	–
HOLE	QTY	SIZE	DESCRIPTION	MFG	MFG P/N	T&B P/N
MATERIAL: –			FINISH: –			
UNLESS OTHERWISE SPECIFIED: ALL DIMENSIONS IN INCHES INSIDE BEND RADIUS .030 MAX REMOVE ALL BURRS AND SHARP EDGES			TOLERANCE:		HOLE ϕ = $\pm$.005 ANGLE = $\pm$ 1/2°	
			x = $\pm$ 0.25 x.x = $\pm$ 0.10 x.xx = $\pm$ 0.025			