

## SCHEMATIC NOTES:

- 1. ALL DEVICES SHALL BE PLUG-IN/ WITHDRAWABLE TYPE.
- 2. SWITCHPANEL ENCLOSURES SHALL BE MARKED WITH COLOURED BANDS, INDICATING SCHEMATICALLY ALL DEVICE AND BUSBAR INTERCONNECTIONS AND SYSTEM LAYOUT. DEDICATED GENERATOR CIRCUITS SHALL BE RED, ALL
- OTHER SHALL BE BLACK. 3. INCOMING CABLES SHALL BE CU SINGLE CORE ALU WIRED ARMOURED. GLAND PLATES SHALL BE ALU.
- 4. ALL EXTENSIONS REQUIRED FOR CABLE CONNECTION AND METER HOUSINGS SHALL BE INCLUDED.
- 5. LABELS FOR EVERY DEVICE ON THE SWITCH PANEL SHALL INDICATE DUTY, RATING, VOLTAGE, PHASE, SIZE OF CONDUCTOR, IMPEDANCE, FAULT LEVEL AND EQUIPMENT IT FEEDS. ALL LABELS SHALL BE SUBMITTED FOR APPROVAL PRIOR TO MANUFACTURE.

## <u>LEGEND</u>

SINGLE-PHASE & NEUTRAL DISTRIBUTION BOARD

MCCB PANEL BOARD

THREE-PHASE & NEUTRAL DISTRIBUTION BOARD THREE PHASE & NEUTRAL DISTRIBUTION BOARD FED VIA COMMON 400A ISOLATOR

M → DIGITAL MULTIMETER

CIRCUIT BREAKER, NOTATION: xxxATFRAME RATING TPN X TRIP SETTING MCCB No. OF POLES BREAKER TYPE

3-PHASE ISOLATOR

SURGE SUPRESSION DEVICE

POWER FACTOR CORRECTION UNIT

KEY-SWITCH ISOLATOR

GENERATOR CONTROL PANEL

AFC 108/12/16 COMMENTS INCORPORATED
AFC 10/10/16 ISSUED FOR CONSTRUCTION
Rev Date Description

I & H BROWN

WARRINGTON BRIDGE STREET QUARTER MULTI-STOREY CAR PARK WARRINGTON

ELECTRICAL SERVICES MAIN ELECTRICAL SCHEMATIC DIAGRAM

Originating Office



VAUGHAN ENGINEERING LTD THE BREEZE CLAREMONT HOUSE 2 KELVIN CLOSE, WARRINGTON CHESHIRE, WA3 7PB Tel. 0844 963 2172 Email. vnw@vaughan-group.co.uk Website. www.vaughan-group.co.uk

N.T.S

Head Office 174 Dunkeld Road Perth P1 3AA Tel. 01738 637 171 Fax. 01738 637 175 Email. enquiries@ihbrown.com www.ihbrown.com

Job Manager QA System - Checks Date PAS DS 10 Oct 2016 Drawn By: M CLEMENTSON

Checked: Authorised: M CLEMENTSON Project No. Drawing Status

Scale (at A1) C60298 Drawing Number

VEL(60)E001 AFC1