


Woodmere Middle School



Woodmere Middle School



WOODMERE MIDDLE SCHOOL

BCS item #	Description	Cost
38	Space Adequacy – Recommend additional storage room off the stage	\$356,832.00
42	Site Fuel Oil – Recommend replacement of existing underground FOT	\$522,032.00
55	Pavement – Recommend complete replacement of main parking lot, roadway and bus loop at south end of lot	\$1,544,576.40
56	Sidewalks – Partial Sidewalk and curbing replacement. Install concrete pads below fresh air intakes at 10 locations	\$323,792.00
58	Athletic Fields -Track and synthetic field replacement scheduled for Summer 2024, Funding for project part of 2023-2024 budget. Handball court pavement needs to be replaced. Repaint handball walls. Tennis courts beginning to show cracks at net line. Control joints were not installed as part of original construction. Crack fill and seal courts. Install bottom rail at 4'-0" high CLF. Crack fill and seal basketball courts.	\$907,936.00
66	Exterior Walls/Columns - Scrape and paint lintels at music room	\$9,912.00
69	Exterior Doors - Replace doors and frames off exterior mechanical and locker rooms. Harden visions on all exterior doors as well as window walls at link corridor from 2 story wing to single story wing.	\$185,076.86
72	Windows – Re-caulk at top of all first-floor window heads and second floor louvers. Building is experiencing water infiltration during wind driven rain.	\$52,864.00
77	Resilient Tiles or Sheet Flooring - Replace remaining VAT flooring, storage room off library and office/ storage rooms of kitchen.	\$13,216.00
82	Interior Doors -Recommend replacement of original doors to match style of recently replaced doors. Reuse locking hardware. Harden glazing at all doors as well as at main security check in.	\$376,656.00
88	Ventilation Systems - Improve mechanical ventilation in 3 spaces	\$191,632.00
97	Plumbing Fixtures - Recommend replacement of remaining 1961 bathrooms, kitchen and two adult bathrooms adjacent to auditorium.	\$290,752.00
102	Lighting Fixtures - Upgrade East and West side parking lots with new LED lighting.	\$237,888.00
116	Interior Accessible Spaces - Install ADA sink in tech room.	\$6,608.00
Building Total		\$5,019,773.26



Woodmere Middle School



Woodmere Middle School



Woodmere Middle School




Woodmere Middle School



Woodmere Middle School



Woodmere Middle School



Woodmere Middle School



Woodmere Middle School



Woodmere Middle School

