

SAFETY & COMPLIANCE

Authorization required before any welding, cutting, grinding, or open-flame work

This permit must be completed and authorized BEFORE initiating any hot work operations including welding, cutting, grinding, brazing, soldering, open-flame heating, or any activity that produces sparks or heat. Hot work in areas containing flammable or combustible materials requires additional fire watch and atmospheric testing.

Item	Requirement	Verified By
Work area	Combustibles removed or protected within 35 ft	_____
Fire watch	Assigned and briefed on duties and extinguisher location	_____
Atmospheric test	LEL <10% confirmed by CGI within 30 minutes of work	_____
Hot work equipment	Hoses, regulators, and fittings inspected, no leaks	_____
Fire extinguisher	20-lb dry chemical within 10 ft of work	_____
Affected areas	Adjacent areas and floors below notified	_____
Post-work watch	Fire watch maintained 30 min after work completion	_____

WORK DESCRIPTION

LOCATION / UNIT

AUTHORIZED DATES/TIMES

FOREMAN SIGNATURE

SAFETY OFFICER SIGNATURE

CLIENT REPRESENTATIVE (IF REQUIRED)