ALIRAN UTILITIES SDN BHD (Co No: 271143-T)
LEVEL 1, TOWER BLOCK SYED KECHIK FOUNDATION BUILDING,
JALAN KAPAS, BANGSAR,
59100 KUALA LUMPUR
Tel : 03-2280 0493 Fax : 03-2280 0494
Website : www.airb.com.my

Project Name	**7,920m3/day F3WT Phase 2 Water Recycling Treatment Plant**				
Client	**Top Quality Glove Sdn Bhd**				
Project No.	**TG-F3WT-PH2**				
Document Title	**IO List**				
Document No.	**TG-F3WT-PH2-IO-E02RA-20210415**			No. of Pages (incl. cover)	**26**
Rev	**Date**	**Description**	**Prepared by**	**Reviewed by**	**Approved by**
A	15/4/2021	Issued for Construction	CC	IH	ST

Date Received	
Review Grade	**Next Submittal Status**
☐ Proceed to next submission & Status ☐ Proceed with exceptions as noted to next submission & Status ☐ Do not proceed, revise as noted & resubmit	☐ Internal review ☐ Certified Final ☐ Final ☐ As-Built **Next Submittal Date**
☐ No further submission required - Complete	☐
☐ No further submission required - Cancelled	☐
☐ No further submission required - Superseded	☐

ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	P001A	Phase 2 Intake Pump A	_REMOTE	P001A_REMOTE	S/S	DI	DRY CONTACT	1				SIEMENS	2	1	a.0
A	PLC	TG-F3WT-PH2	P001A	Phase 2 Intake Pump A	_RUN	P001A_RUN	S/S	DI	DRY CONTACT	1				SIEMENS	2	1	a.1
A	PLC	TG-F3WT-PH2	P001A	Phase 2 Intake Pump A	_TRIP	P001A_TRIP	S/S	DI	DRY CONTACT	1				SIEMENS	2	1	a.2
A	PLC	TG-F3WT-PH2	P001A	Phase 2 Intake Pump A	_ISOLATOR_ON	P001A_ISOLATOR_ON	S/S	DI	DRY CONTACT	1				SIEMENS	2	1	a.3
A	PLC	TG-F3WT-PH2	P001B	Phase 2 Intake Pump B	_REMOTE	P001B_REMOTE	S/S	DI	DRY CONTACT	1				SIEMENS	2	1	a.4
A	PLC	TG-F3WT-PH2	P001B	Phase 2 Intake Pump B	_RUN	P001B_RUN	S/S	DI	DRY CONTACT	1				SIEMENS	2	1	a.5
A	PLC	TG-F3WT-PH2	P001B	Phase 2 Intake Pump B	_TRIP	P001B_TRIP	S/S	DI	DRY CONTACT	1				SIEMENS	2	1	a.6
A	PLC	TG-F3WT-PH2	P001B	Phase 2 Intake Pump B	_ISOLATOR_ON	P001B_ISOLATOR_ON	S/S	DI	DRY CONTACT	1				SIEMENS	2	1	a.7
A	PLC	TG-F3WT-PH2	P001C	Phase 2 Intake Pump C	_REMOTE	P001C_REMOTE	S/S	DI	DRY CONTACT	1				SIEMENS	2	1	b.0
A	PLC	TG-F3WT-PH2	P001C	Phase 2 Intake Pump C	_RUN	P001C_RUN	S/S	DI	DRY CONTACT	1				SIEMENS	2	1	b.1
A	PLC	TG-F3WT-PH2	P001C	Phase 2 Intake Pump C	_TRIP	P001C_TRIP	S/S	DI	DRY CONTACT	1				SIEMENS	2	1	b.2
A	PLC	TG-F3WT-PH2	P001C	Phase 2 Intake Pump C	_ISOLATOR_ON	P001C_ISOLATOR_ON	S/S	DI	DRY CONTACT	1				SIEMENS	2	1	b.3
A	PLC	TG-F3WT-PH2	P003A	WWRP Phase 2 Feed Pump A	_REMOTE	P003A_REMOTE	S/S	DI	DRY CONTACT	1				SIEMENS	2	1	b.4
A	PLC	TG-F3WT-PH2	P003A	WWRP Phase 2 Feed Pump A	_RUN	P003A_RUN	S/S	DI	DRY CONTACT	1				SIEMENS	2	1	b.5
A	PLC	TG-F3WT-PH2	P003A	WWRP Phase 2 Feed Pump A	_TRIP	P003A_TRIP	S/S	DI	DRY CONTACT	1				SIEMENS	2	1	b.6
A	PLC	TG-F3WT-PH2	P003A	WWRP Phase 2 Feed Pump A	_ISOLATOR_ON	P003A_ISOLATOR_ON	S/S	DI	DRY CONTACT	1				SIEMENS	2	1	b.7
A	PLC	TG-F3WT-PH2	P003B	WWRP Phase 2 Feed Pump B	_REMOTE	P003B_REMOTE	S/S	DI	DRY CONTACT	1				SIEMENS	2	2	a.0
A	PLC	TG-F3WT-PH2	P003B	WWRP Phase 2 Feed Pump B	_RUN	P003B_RUN	S/S	DI	DRY CONTACT	1				SIEMENS	2	2	a.1
A	PLC	TG-F3WT-PH2	P003B	WWRP Phase 2 Feed Pump B	_TRIP	P003B_TRIP	S/S	DI	DRY CONTACT	1				SIEMENS	2	2	a.2
A	PLC	TG-F3WT-PH2	P003B	WWRP Phase 2 Feed Pump B	_ISOLATOR_ON	P003B_ISOLATOR_ON	S/S	DI	DRY CONTACT	1				SIEMENS	2	2	a.3
A	PLC	TG-F3WT-PH2	P003C	WWRP Phase 2 Feed Pump C	_REMOTE	P003C_REMOTE	S/S	DI	DRY CONTACT	1				SIEMENS	2	2	a.4
A	PLC	TG-F3WT-PH2	P003C	WWRP Phase 2 Feed Pump C	_RUN	P003C_RUN	S/S	DI	DRY CONTACT	1				SIEMENS	2	2	a.5
A	PLC	TG-F3WT-PH2	P003C	WWRP Phase 2 Feed Pump C	_TRIP	P003C_TRIP	S/S	DI	DRY CONTACT	1				SIEMENS	2	2	a.6
A	PLC	TG-F3WT-PH2	P003C	WWRP Phase 2 Feed Pump C	_ISOLATOR_ON	P003C_ISOLATOR_ON	S/S	DI	DRY CONTACT	1				SIEMENS	2	2	a.7
A	PLC	TG-F3WT-PH2	P003D	WWRP Phase 2 Feed Pump D	_REMOTE	P003D_REMOTE	S/S	DI	DRY CONTACT	1				SIEMENS	2	2	b.0
A	PLC	TG-F3WT-PH2	P003D	WWRP Phase 2 Feed Pump D	_RUN	P003D_RUN	S/S	DI	DRY CONTACT	1				SIEMENS	2	2	b.1
A	PLC	TG-F3WT-PH2	P003D	WWRP Phase 2 Feed Pump D	_TRIP	P003D_TRIP	S/S	DI	DRY CONTACT	1				SIEMENS	2	2	b.2
A	PLC	TG-F3WT-PH2	P003D	WWRP Phase 2 Feed Pump D	_ISOLATOR_ON	P003D_ISOLATOR_ON	S/S	DI	DRY CONTACT	1				SIEMENS	2	2	b.3
A	PLC	TG-F3WT-PH2	P004A	MBR Permeate Pump A	_REMOTE	P004A_REMOTE	VFD	DI	DRY CONTACT	1				SIEMENS	2	2	b.4
A	PLC	TG-F3WT-PH2	P004A	MBR Permeate Pump A	_RUN	P004A_RUN	VFD	DI	DRY CONTACT	1				SIEMENS	2	2	b.5
A	PLC	TG-F3WT-PH2	P004A	MBR Permeate Pump A	_TRIP	P004A_TRIP	VFD	DI	DRY CONTACT	1				SIEMENS	2	2	b.6
A	PLC	TG-F3WT-PH2	P004A	MBR Permeate Pump A	_ISOLATOR_ON	P004A_ISOLATOR_ON	VFD	DI	DRY CONTACT	1				SIEMENS	2	2	b.7
A	PLC	TG-F3WT-PH2	P004B	MBR Permeate Pump B	_REMOTE	P004B_REMOTE	VFD	DI	DRY CONTACT	1				SIEMENS	2	3	a.0
A	PLC	TG-F3WT-PH2	P004B	MBR Permeate Pump B	_RUN	P004B_RUN	VFD	DI	DRY CONTACT	1				SIEMENS	2	3	a.1

ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	P004B	MBR Permeate Pump B	_TRIP	P004B_TRIP	VFD	DI	DRY CONTACT	1				SIEMENS	2	3	a.2
A	PLC	TG-F3WT-PH2	P004B	MBR Permeate Pump B	_ISOLATOR_ON	P004B_ISOLATOR_ON	VFD	DI	DRY CONTACT	1				SIEMENS	2	3	a.3
A	PLC	TG-F3WT-PH2	P004C	MBR Permeate Pump C	_REMOTE	P004C_REMOTE	VFD	DI	DRY CONTACT	1				SIEMENS	2	3	a.4
A	PLC	TG-F3WT-PH2	P004C	MBR Permeate Pump C	_RUN	P004C_RUN	VFD	DI	DRY CONTACT	1				SIEMENS	2	3	a.5
A	PLC	TG-F3WT-PH2	P004C	MBR Permeate Pump C	_TRIP	P004C_TRIP	VFD	DI	DRY CONTACT	1				SIEMENS	2	3	a.6
A	PLC	TG-F3WT-PH2	P004C	MBR Permeate Pump C	_ISOLATOR_ON	P004C_ISOLATOR_ON	VFD	DI	DRY CONTACT	1				SIEMENS	2	3	a.7
A	PLC	TG-F3WT-PH2	P004D	MBR Permeate Pump D	_REMOTE	P004D_REMOTE	VFD	DI	DRY CONTACT	1				SIEMENS	2	3	b.0
A	PLC	TG-F3WT-PH2	P004D	MBR Permeate Pump D	_RUN	P004D_RUN	VFD	DI	DRY CONTACT	1				SIEMENS	2	3	b.1
A	PLC	TG-F3WT-PH2	P004D	MBR Permeate Pump D	_TRIP	P004D_TRIP	VFD	DI	DRY CONTACT	1				SIEMENS	2	3	b.2
A	PLC	TG-F3WT-PH2	P004D	MBR Permeate Pump D	_ISOLATOR_ON	P004D_ISOLATOR_ON	VFD	DI	DRY CONTACT	1				SIEMENS	2	3	b.3
A	PLC	TG-F3WT-PH2	P005A	MBR RAS Pump A	_REMOTE	P005A_REMOTE	S/S	DI	DRY CONTACT	1				SIEMENS	2	3	b.4
A	PLC	TG-F3WT-PH2	P005A	MBR RAS Pump A	_RUN	P005A_RUN	S/S	DI	DRY CONTACT	1				SIEMENS	2	3	b.5
A	PLC	TG-F3WT-PH2	P005A	MBR RAS Pump A	_TRIP	P005A_TRIP	S/S	DI	DRY CONTACT	1				SIEMENS	2	3	b.6
A	PLC	TG-F3WT-PH2	P005A	MBR RAS Pump A	_ISOLATOR_ON	P005A_ISOLATOR_ON	S/S	DI	DRY CONTACT	1				SIEMENS	2	3	b.7
A	PLC	TG-F3WT-PH2	P005B	MBR RAS Pump B	_REMOTE	P005B_REMOTE	S/S	DI	DRY CONTACT	1				SIEMENS	2	4	a.0
A	PLC	TG-F3WT-PH2	P005B	MBR RAS Pump B	_RUN	P005B_RUN	S/S	DI	DRY CONTACT	1				SIEMENS	2	4	a.1
A	PLC	TG-F3WT-PH2	P005B	MBR RAS Pump B	_TRIP	P005B_TRIP	S/S	DI	DRY CONTACT	1				SIEMENS	2	4	a.2
A	PLC	TG-F3WT-PH2	P005B	MBR RAS Pump B	_ISOLATOR_ON	P005B_ISOLATOR_ON	S/S	DI	DRY CONTACT	1				SIEMENS	2	4	a.3
A	PLC	TG-F3WT-PH2	P005C	MBR RAS Pump C	_REMOTE	P005C_REMOTE	S/S	DI	DRY CONTACT	1				SIEMENS	2	4	a.4
A	PLC	TG-F3WT-PH2	P005C	MBR RAS Pump C	_RUN	P005C_RUN	S/S	DI	DRY CONTACT	1				SIEMENS	2	4	a.5
A	PLC	TG-F3WT-PH2	P005C	MBR RAS Pump C	_TRIP	P005C_TRIP	S/S	DI	DRY CONTACT	1				SIEMENS	2	4	a.6
A	PLC	TG-F3WT-PH2	P005C	MBR RAS Pump C	_ISOLATOR_ON	P005C_ISOLATOR_ON	S/S	DI	DRY CONTACT	1				SIEMENS	2	4	a.7
A	PLC	TG-F3WT-PH2	P005D	MBR RAS Pump D	_REMOTE	P005D_REMOTE	S/S	DI	DRY CONTACT	1				SIEMENS	2	4	b.0
A	PLC	TG-F3WT-PH2	P005D	MBR RAS Pump D	_RUN	P005D_RUN	S/S	DI	DRY CONTACT	1				SIEMENS	2	4	b.1
A	PLC	TG-F3WT-PH2	P005D	MBR RAS Pump D	_TRIP	P005D_TRIP	S/S	DI	DRY CONTACT	1				SIEMENS	2	4	b.2
A	PLC	TG-F3WT-PH2	P005D	MBR RAS Pump D	_ISOLATOR_ON	P005D_ISOLATOR_ON	S/S	DI	DRY CONTACT	1				SIEMENS	2	4	b.3
A	PLC	TG-F3WT-PH2	P006A	MBR MC Pump A	_REMOTE	P006A_REMOTE	VFD	DI	DRY CONTACT	1				SIEMENS	2	4	b.4
A	PLC	TG-F3WT-PH2	P006A	MBR MC Pump A	_RUN	P006A_RUN	VFD	DI	DRY CONTACT	1				SIEMENS	2	4	b.5
A	PLC	TG-F3WT-PH2	P006A	MBR MC Pump A	_TRIP	P006A_TRIP	VFD	DI	DRY CONTACT	1				SIEMENS	2	4	b.6
A	PLC	TG-F3WT-PH2	P006A	MBR MC Pump A	_ISOLATOR_ON	P006A_ISOLATOR_ON	VFD	DI	DRY CONTACT	1				SIEMENS	2	4	b.7
A	PLC	TG-F3WT-PH2	P006B	MBR MC Pump B	_REMOTE	P006B_REMOTE	VFD	DI	DRY CONTACT	1				SIEMENS	2	5	a.0
A	PLC	TG-F3WT-PH2	P006B	MBR MC Pump B	_RUN	P006B_RUN	VFD	DI	DRY CONTACT	1				SIEMENS	2	5	a.1
A	PLC	TG-F3WT-PH2	P006B	MBR MC Pump B	_TRIP	P006B_TRIP	VFD	DI	DRY CONTACT	1				SIEMENS	2	5	a.2
A	PLC	TG-F3WT-PH2	P006B	MBR MC Pump B	_ISOLATOR_ON	P006B_ISOLATOR_ON	VFD	DI	DRY CONTACT	1				SIEMENS	2	5	a.3

ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	P007A	RO Feed Pump A	_REMOTE	P007A_REMOTE	VFD	DI	DRY CONTACT	1				SIEMENS	2	5	a.4
A	PLC	TG-F3WT-PH2	P007A	RO Feed Pump A	_RUN	P007A_RUN	VFD	DI	DRY CONTACT	1				SIEMENS	2	5	a.5
A	PLC	TG-F3WT-PH2	P007A	RO Feed Pump A	_TRIP	P007A_TRIP	VFD	DI	DRY CONTACT	1				SIEMENS	2	5	a.6
A	PLC	TG-F3WT-PH2	P007A	RO Feed Pump A	_ISOLATOR_ON	P007A_ISOLATOR_ON	VFD	DI	DRY CONTACT	1				SIEMENS	2	5	a.7
A	PLC	TG-F3WT-PH2	P007B	RO Feed Pump B	_REMOTE	P007B_REMOTE	VFD	DI	DRY CONTACT	1				SIEMENS	2	5	b.0
A	PLC	TG-F3WT-PH2	P007B	RO Feed Pump B	_RUN	P007B_RUN	VFD	DI	DRY CONTACT	1				SIEMENS	2	5	b.1
A	PLC	TG-F3WT-PH2	P007B	RO Feed Pump B	_TRIP	P007B_TRIP	VFD	DI	DRY CONTACT	1				SIEMENS	2	5	b.2
A	PLC	TG-F3WT-PH2	P007B	RO Feed Pump B	_ISOLATOR_ON	P007B_ISOLATOR_ON	VFD	DI	DRY CONTACT	1				SIEMENS	2	5	b.3
A	PLC	TG-F3WT-PH2	P007C	RO Feed Pump C	_REMOTE	P007C_REMOTE	VFD	DI	DRY CONTACT	1				SIEMENS	2	5	b.4
A	PLC	TG-F3WT-PH2	P007C	RO Feed Pump C	_RUN	P007C_RUN	VFD	DI	DRY CONTACT	1				SIEMENS	2	5	b.5
A	PLC	TG-F3WT-PH2	P007C	RO Feed Pump C	_TRIP	P007C_TRIP	VFD	DI	DRY CONTACT	1				SIEMENS	2	5	b.6
A	PLC	TG-F3WT-PH2	P007C	RO Feed Pump C	_ISOLATOR_ON	P007C_ISOLATOR_ON	VFD	DI	DRY CONTACT	1				SIEMENS	2	5	b.7
A	PLC	TG-F3WT-PH2	P007D	RO Feed Pump D	_REMOTE	P007D_REMOTE	VFD	DI	DRY CONTACT	1				SIEMENS	2	6	a.0
A	PLC	TG-F3WT-PH2	P007D	RO Feed Pump D	_RUN	P007D_RUN	VFD	DI	DRY CONTACT	1				SIEMENS	2	6	a.1
A	PLC	TG-F3WT-PH2	P007D	RO Feed Pump D	_TRIP	P007D_TRIP	VFD	DI	DRY CONTACT	1				SIEMENS	2	6	a.2
A	PLC	TG-F3WT-PH2	P007D	RO Feed Pump D	_ISOLATOR_ON	P007D_ISOLATOR_ON	VFD	DI	DRY CONTACT	1				SIEMENS	2	6	a.3
A	PLC	TG-F3WT-PH2	P008A	RO High Pressure Pump A	_REMOTE	P008A_REMOTE	VFD	DI	DRY CONTACT	1				SIEMENS	2	6	a.4
A	PLC	TG-F3WT-PH2	P008A	RO High Pressure Pump A	_RUN	P008A_RUN	VFD	DI	DRY CONTACT	1				SIEMENS	2	6	a.5
A	PLC	TG-F3WT-PH2	P008A	RO High Pressure Pump A	_TRIP	P008A_TRIP	VFD	DI	DRY CONTACT	1				SIEMENS	2	6	a.6
A	PLC	TG-F3WT-PH2	P008A	RO High Pressure Pump A	_ISOLATOR_ON	P008A_ISOLATOR_ON	VFD	DI	DRY CONTACT	1				SIEMENS	2	6	a.7
A	PLC	TG-F3WT-PH2	P008B	RO High Pressure Pump B	_REMOTE	P008B_REMOTE	VFD	DI	DRY CONTACT	1				SIEMENS	2	6	b.0
A	PLC	TG-F3WT-PH2	P008B	RO High Pressure Pump B	_RUN	P008B_RUN	VFD	DI	DRY CONTACT	1				SIEMENS	2	6	b.1
A	PLC	TG-F3WT-PH2	P008B	RO High Pressure Pump B	_TRIP	P008B_TRIP	VFD	DI	DRY CONTACT	1				SIEMENS	2	6	b.2
A	PLC	TG-F3WT-PH2	P008B	RO High Pressure Pump B	_ISOLATOR_ON	P008B_ISOLATOR_ON	VFD	DI	DRY CONTACT	1				SIEMENS	2	6	b.3
A	PLC	TG-F3WT-PH2	P009A	RO Recirculation Pump A	_REMOTE	P009A_REMOTE	VFD	DI	DRY CONTACT	1				SIEMENS	2	6	b.4
A	PLC	TG-F3WT-PH2	P009A	RO Recirculation Pump A	_RUN	P009A_RUN	VFD	DI	DRY CONTACT	1				SIEMENS	2	6	b.5
A	PLC	TG-F3WT-PH2	P009A	RO Recirculation Pump A	_TRIP	P009A_TRIP	VFD	DI	DRY CONTACT	1				SIEMENS	2	6	b.6
A	PLC	TG-F3WT-PH2	P009A	RO Recirculation Pump A	_ISOLATOR_ON	P009A_ISOLATOR_ON	VFD	DI	DRY CONTACT	1				SIEMENS	2	6	b.7
A	PLC	TG-F3WT-PH2	P009B	RO Recirculation Pump B	_REMOTE	P009B_REMOTE	VFD	DI	DRY CONTACT	1				SIEMENS	2	7	a.0
A	PLC	TG-F3WT-PH2	P009B	RO Recirculation Pump B	_RUN	P009B_RUN	VFD	DI	DRY CONTACT	1				SIEMENS	2	7	a.1
A	PLC	TG-F3WT-PH2	P009B	RO Recirculation Pump B	_TRIP	P009B_TRIP	VFD	DI	DRY CONTACT	1				SIEMENS	2	7	a.2
A	PLC	TG-F3WT-PH2	P009B	RO Recirculation Pump B	_ISOLATOR_ON	P009B_ISOLATOR_ON	VFD	DI	DRY CONTACT	1				SIEMENS	2	7	a.3
A	PLC	TG-F3WT-PH2	P009C	RO Recirculation Pump C	_REMOTE	P009C_REMOTE	VFD	DI	DRY CONTACT	1				SIEMENS	2	7	a.4
A	PLC	TG-F3WT-PH2	P009C	RO Recirculation Pump C	_RUN	P009C_RUN	VFD	DI	DRY CONTACT	1				SIEMENS	2	7	a.5

ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	P009C	RO Recirculation Pump C	_TRIP	P009C_TRIP	VFD	DI	DRY CONTACT	1				SIEMENS	2	7	a.6
A	PLC	TG-F3WT-PH2	P009C	RO Recirculation Pump C	_ISOLATOR_ON	P009C_ISOLATOR_ON	VFD	DI	DRY CONTACT	1				SIEMENS	2	7	a.7
A	PLC	TG-F3WT-PH2	P009D	RO Recirculation Pump D	_REMOTE	P009D_REMOTE	VFD	DI	DRY CONTACT	1				SIEMENS	2	7	b.0
A	PLC	TG-F3WT-PH2	P009D	RO Recirculation Pump D	_RUN	P009D_RUN	VFD	DI	DRY CONTACT	1				SIEMENS	2	7	b.1
A	PLC	TG-F3WT-PH2	P009D	RO Recirculation Pump D	_TRIP	P009D_TRIP	VFD	DI	DRY CONTACT	1				SIEMENS	2	7	b.2
A	PLC	TG-F3WT-PH2	P009D	RO Recirculation Pump D	_ISOLATOR_ON	P009D_ISOLATOR_ON	VFD	DI	DRY CONTACT	1				SIEMENS	2	7	b.3
A	PLC	TG-F3WT-PH2	P010	RO CIP Pump	_REMOTE	P010_REMOTE	S/S	DI	DRY CONTACT	1				SIEMENS	2	7	b.4
A	PLC	TG-F3WT-PH2	P010	RO CIP Pump	_RUN	P010_RUN	S/S	DI	DRY CONTACT	1				SIEMENS	2	7	b.5
A	PLC	TG-F3WT-PH2	P010	RO CIP Pump	_TRIP	P010_TRIP	S/S	DI	DRY CONTACT	1				SIEMENS	2	7	b.6
A	PLC	TG-F3WT-PH2	P010	RO CIP Pump	_ISOLATOR_ON	P010_ISOLATOR_ON	S/S	DI	DRY CONTACT	1				SIEMENS	2	7	b.7
A	PLC	TG-F3WT-PH2	P011A	Waste Transfer Pump A	_REMOTE	P011A_REMOTE	S/S	DI	DRY CONTACT	1				SIEMENS	2	8	a.0
A	PLC	TG-F3WT-PH2	P011A	Waste Transfer Pump A	_RUN	P011A_RUN	S/S	DI	DRY CONTACT	1				SIEMENS	2	8	a.1
A	PLC	TG-F3WT-PH2	P011A	Waste Transfer Pump A	_TRIP	P011A_TRIP	S/S	DI	DRY CONTACT	1				SIEMENS	2	8	a.2
A	PLC	TG-F3WT-PH2	P011A	Waste Transfer Pump A	_ISOLATOR_ON	P011A_ISOLATOR_ON	S/S	DI	DRY CONTACT	1				SIEMENS	2	8	a.3
A	PLC	TG-F3WT-PH2	P011B	Waste Transfer Pump B	_REMOTE	P011B_REMOTE	S/S	DI	DRY CONTACT	1				SIEMENS	2	8	a.4
A	PLC	TG-F3WT-PH2	P011B	Waste Transfer Pump B	_RUN	P011B_RUN	S/S	DI	DRY CONTACT	1				SIEMENS	2	8	a.5
A	PLC	TG-F3WT-PH2	P011B	Waste Transfer Pump B	_TRIP	P011B_TRIP	S/S	DI	DRY CONTACT	1				SIEMENS	2	8	a.6
A	PLC	TG-F3WT-PH2	P011B	Waste Transfer Pump B	_ISOLATOR_ON	P011B_ISOLATOR_ON	S/S	DI	DRY CONTACT	1				SIEMENS	2	8	a.7
A	PLC	TG-F3WT-PH2	P012	RO Permeate Transfer Pump	_REMOTE	P012_REMOTE	DOL	DI	DRY CONTACT	1				SIEMENS	2	8	b.0
A	PLC	TG-F3WT-PH2	P012	RO Permeate Transfer Pump	_RUN	P012_RUN	DOL	DI	DRY CONTACT	1				SIEMENS	2	8	b.1
A	PLC	TG-F3WT-PH2	P012	RO Permeate Transfer Pump	_TRIP	P012_TRIP	DOL	DI	DRY CONTACT	1				SIEMENS	2	8	b.2
A	PLC	TG-F3WT-PH2	P012	RO Permeate Transfer Pump	_ISOLATOR_ON	P012_ISOLATOR_ON	DOL	DI	DRY CONTACT	1				SIEMENS	2	8	b.3
A	PLC	TG-F3WT-PH2	DP001A	MBR NaOCl MC Dosing Pump	_REMOTE	DP001A_REMOTE	DOL	DI	DRY CONTACT	1				SIEMENS	2	8	b.4
A	PLC	TG-F3WT-PH2	DP001A	MBR NaOCl MC Dosing Pump	_RUN	DP001A_RUN	DOL	DI	DRY CONTACT	1				SIEMENS	2	8	b.5
A	PLC	TG-F3WT-PH2	DP001A	MBR NaOCl MC Dosing Pump	_TRIP	DP001A_TRIP	DOL	DI	DRY CONTACT	1				SIEMENS	2	8	b.6
A	PLC	TG-F3WT-PH2	DP001A	MBR NaOCl MC Dosing Pump	_ISOLATOR_ON	DP001A_ISOLATOR_ON	DOL	DI	DRY CONTACT	1				SIEMENS	2	8	b.7
A	PLC	TG-F3WT-PH2	DP003A	RO SMBS Dosing Pump A	_REMOTE	DP003A_REMOTE	DOL	DI	DRY CONTACT	1				SIEMENS	2	9	a.0
A	PLC	TG-F3WT-PH2	DP003A	RO SMBS Dosing Pump A	_RUN	DP003A_RUN	DOL	DI	DRY CONTACT	1				SIEMENS	2	9	a.1
A	PLC	TG-F3WT-PH2	DP003A	RO SMBS Dosing Pump A	_TRIP	DP003A_TRIP	DOL	DI	DRY CONTACT	1				SIEMENS	2	9	a.2
A	PLC	TG-F3WT-PH2	DP003A	RO SMBS Dosing Pump A	_ISOLATOR_ON	DP003A_ISOLATOR_ON	DOL	DI	DRY CONTACT	1				SIEMENS	2	9	a.3
A	PLC	TG-F3WT-PH2	DP003B	RO SMBS Dosing Pump B	_REMOTE	DP003B_REMOTE	DOL	DI	DRY CONTACT	1				SIEMENS	2	9	a.4
A	PLC	TG-F3WT-PH2	DP003B	RO SMBS Dosing Pump B	_RUN	DP003B_RUN	DOL	DI	DRY CONTACT	1				SIEMENS	2	9	a.5
A	PLC	TG-F3WT-PH2	DP003B	RO SMBS Dosing Pump B	_TRIP	DP003B_TRIP	DOL	DI	DRY CONTACT	1				SIEMENS	2	9	a.6
A	PLC	TG-F3WT-PH2	DP003B	RO SMBS Dosing Pump B	_ISOLATOR_ON	DP003B_ISOLATOR_ON	DOL	DI	DRY CONTACT	1				SIEMENS	2	9	a.7

ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	DP005A	RO Antiscalant Dosing Pump A	_REMOTE	DP005A_REMOTE	DOL	DI	DRY CONTACT	1				SIEMENS	2	9	b.0
A	PLC	TG-F3WT-PH2	DP005A	RO Antiscalant Dosing Pump A	_RUN	DP005A_RUN	DOL	DI	DRY CONTACT	1				SIEMENS	2	9	b.1
A	PLC	TG-F3WT-PH2	DP005A	RO Antiscalant Dosing Pump A	_TRIP	DP005A_TRIP	DOL	DI	DRY CONTACT	1				SIEMENS	2	9	b.2
A	PLC	TG-F3WT-PH2	DP005A	RO Antiscalant Dosing Pump A	_ISOLATOR_ON	DP005A_ISOLATOR_ON	DOL	DI	DRY CONTACT	1				SIEMENS	2	9	b.3
A	PLC	TG-F3WT-PH2	DP005B	RO Antiscalant Dosing Pump B	_REMOTE	DP005B_REMOTE	DOL	DI	DRY CONTACT	1				SIEMENS	2	9	b.4
A	PLC	TG-F3WT-PH2	DP005B	RO Antiscalant Dosing Pump B	_RUN	DP005B_RUN	DOL	DI	DRY CONTACT	1				SIEMENS	2	9	b.5
A	PLC	TG-F3WT-PH2	DP005B	RO Antiscalant Dosing Pump B	_TRIP	DP005B_TRIP	DOL	DI	DRY CONTACT	1				SIEMENS	2	9	b.6
A	PLC	TG-F3WT-PH2	DP005B	RO Antiscalant Dosing Pump B	_ISOLATOR_ON	DP005B_ISOLATOR_ON	DOL	DI	DRY CONTACT	1				SIEMENS	2	9	b.7
A	PLC	TG-F3WT-PH2	DP008	Coagulant Dosing Pump	_REMOTE	DP008_REMOTE	DOL	DI	DRY CONTACT	1				SIEMENS	2	10	a.0
A	PLC	TG-F3WT-PH2	DP008	Coagulant Dosing Pump	_RUN	DP008_RUN	DOL	DI	DRY CONTACT	1				SIEMENS	2	10	a.1
A	PLC	TG-F3WT-PH2	DP008	Coagulant Dosing Pump	_TRIP	DP008_TRIP	DOL	DI	DRY CONTACT	1				SIEMENS	2	10	a.2
A	PLC	TG-F3WT-PH2	DP008	Coagulant Dosing Pump	_ISOLATOR_ON	DP008_ISOLATOR_ON	DOL	DI	DRY CONTACT	1				SIEMENS	2	10	a.3
A	PLC	TG-F3WT-PH2	MX001A	Anoxic Submersible Mixer A	_REMOTE	MX001A_REMOTE	DOL	DI	DRY CONTACT	1				SIEMENS	2	10	a.4
A	PLC	TG-F3WT-PH2	MX001A	Anoxic Submersible Mixer A	_RUN	MX001A_RUN	DOL	DI	DRY CONTACT	1				SIEMENS	2	10	a.5
A	PLC	TG-F3WT-PH2	MX001A	Anoxic Submersible Mixer A	_TRIP	MX001A_TRIP	DOL	DI	DRY CONTACT	1				SIEMENS	2	10	a.6
A	PLC	TG-F3WT-PH2	MX001A	Anoxic Submersible Mixer A	_ISOLATOR_ON	MX001A_ISOLATOR_ON	DOL	DI	DRY CONTACT	1				SIEMENS	2	10	a.7
A	PLC	TG-F3WT-PH2	MX001B	Anoxic Submersible Mixer B	_REMOTE	MX001B_REMOTE	DOL	DI	DRY CONTACT	1				SIEMENS	2	10	b.0
A	PLC	TG-F3WT-PH2	MX001B	Anoxic Submersible Mixer B	_RUN	MX001B_RUN	DOL	DI	DRY CONTACT	1				SIEMENS	2	10	b.1
A	PLC	TG-F3WT-PH2	MX001B	Anoxic Submersible Mixer B	_TRIP	MX001B_TRIP	DOL	DI	DRY CONTACT	1				SIEMENS	2	10	b.2
A	PLC	TG-F3WT-PH2	MX001B	Anoxic Submersible Mixer B	_ISOLATOR_ON	MX001B_ISOLATOR_ON	DOL	DI	DRY CONTACT	1				SIEMENS	2	10	b.3
A	PLC	TG-F3WT-PH2	BL001A	Areation Air Blower A	_REMOTE	BL001A_REMOTE	VFD	DI	DRY CONTACT	1				SIEMENS	2	10	b.4
A	PLC	TG-F3WT-PH2	BL001A	Areation Air Blower A	_RUN	BL001A_RUN	VFD	DI	DRY CONTACT	1				SIEMENS	2	10	b.5
A	PLC	TG-F3WT-PH2	BL001A	Areation Air Blower A	_TRIP	BL001A_TRIP	VFD	DI	DRY CONTACT	1				SIEMENS	2	10	b.6
A	PLC	TG-F3WT-PH2	BL001A	Areation Air Blower A	_ISOLATOR_ON	BL001A_ISOLATOR_ON	VFD	DI	DRY CONTACT	1				SIEMENS	2	10	b.7
A	PLC	TG-F3WT-PH2	BL001B	Areation Air Blower B	_REMOTE	BL001B_REMOTE	VFD	DI	DRY CONTACT	1				SIEMENS	2	11	a.0
A	PLC	TG-F3WT-PH2	BL001B	Areation Air Blower B	_RUN	BL001B_RUN	VFD	DI	DRY CONTACT	1				SIEMENS	2	11	a.1
A	PLC	TG-F3WT-PH2	BL001B	Areation Air Blower B	_TRIP	BL001B_TRIP	VFD	DI	DRY CONTACT	1				SIEMENS	2	11	a.2
A	PLC	TG-F3WT-PH2	BL001B	Areation Air Blower B	_ISOLATOR_ON	BL001B_ISOLATOR_ON	VFD	DI	DRY CONTACT	1				SIEMENS	2	11	a.3
A	PLC	TG-F3WT-PH2	BL001C	Areation Air Blower C	_REMOTE	BL001C_REMOTE	VFD	DI	DRY CONTACT	1				SIEMENS	2	11	a.4
A	PLC	TG-F3WT-PH2	BL001C	Areation Air Blower C	_RUN	BL001C_RUN	VFD	DI	DRY CONTACT	1				SIEMENS	2	11	a.5
A	PLC	TG-F3WT-PH2	BL001C	Areation Air Blower C	_TRIP	BL001C_TRIP	VFD	DI	DRY CONTACT	1				SIEMENS	2	11	a.6
A	PLC	TG-F3WT-PH2	BL001C	Areation Air Blower C	_ISOLATOR_ON	BL001C_ISOLATOR_ON	VFD	DI	DRY CONTACT	1				SIEMENS	2	11	a.7
A	PLC	TG-F3WT-PH2	BL002A	MBR Scouring Blower A	_REMOTE	BL002A_REMOTE	VFD	DI	DRY CONTACT	1				SIEMENS	2	11	b.0
A	PLC	TG-F3WT-PH2	BL002A	MBR Scouring Blower A	_RUN	BL002A_RUN	VFD	DI	DRY CONTACT	1				SIEMENS	2	11	b.1

ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	BL002A	MBR Scouring Blower A	_TRIP	BL002A_TRIP	VFD	DI	DRY CONTACT	1				SIEMENS	2	11	b.2
A	PLC	TG-F3WT-PH2	BL002A	MBR Scouring Blower A	_ISOLATOR_ON	BL002A_ISOLATOR_ON	VFD	DI	DRY CONTACT	1				SIEMENS	2	11	b.3
A	PLC	TG-F3WT-PH2	BL002B	MBR Scouring Blower B	_REMOTE	BL002B_REMOTE	VFD	DI	DRY CONTACT	1				SIEMENS	2	11	b.4
A	PLC	TG-F3WT-PH2	BL002B	MBR Scouring Blower B	_RUN	BL002B_RUN	VFD	DI	DRY CONTACT	1				SIEMENS	2	11	b.5
A	PLC	TG-F3WT-PH2	BL002B	MBR Scouring Blower B	_TRIP	BL002B_TRIP	VFD	DI	DRY CONTACT	1				SIEMENS	2	11	b.6
A	PLC	TG-F3WT-PH2	BL002B	MBR Scouring Blower B	_ISOLATOR_ON	BL002B_ISOLATOR_ON	VFD	DI	DRY CONTACT	1				SIEMENS	2	11	b.7
A	PLC	TG-F3WT-PH2	BL002C	MBR Scouring Blower C	_REMOTE	BL002C_REMOTE	VFD	DI	DRY CONTACT	1				SIEMENS	2	12	a.0
A	PLC	TG-F3WT-PH2	BL002C	MBR Scouring Blower C	_RUN	BL002C_RUN	VFD	DI	DRY CONTACT	1				SIEMENS	2	12	a.1
A	PLC	TG-F3WT-PH2	BL002C	MBR Scouring Blower C	_TRIP	BL002C_TRIP	VFD	DI	DRY CONTACT	1				SIEMENS	2	12	a.2
A	PLC	TG-F3WT-PH2	BL002C	MBR Scouring Blower C	_ISOLATOR_ON	BL002C_ISOLATOR_ON	VFD	DI	DRY CONTACT	1				SIEMENS	2	12	a.3
A	PLC	TG-F3WT-PH2	BL002D	MBR Scouring Blower D	_REMOTE	BL002D_REMOTE	VFD	DI	DRY CONTACT	1				SIEMENS	2	12	a.4
A	PLC	TG-F3WT-PH2	BL002D	MBR Scouring Blower D	_RUN	BL002D_RUN	VFD	DI	DRY CONTACT	1				SIEMENS	2	12	a.5
A	PLC	TG-F3WT-PH2	BL002D	MBR Scouring Blower D	_TRIP	BL002D_TRIP	VFD	DI	DRY CONTACT	1				SIEMENS	2	12	a.6
A	PLC	TG-F3WT-PH2	BL002D	MBR Scouring Blower D	_ISOLATOR_ON	BL002D_ISOLATOR_ON	VFD	DI	DRY CONTACT	1				SIEMENS	2	12	a.7
A	PLC	TG-F3WT-PH2	C001	Air Compressor	_REMOTE	C001_REMOTE	DOL	DI	DRY CONTACT	1				SIEMENS	2	12	b.0
A	PLC	TG-F3WT-PH2	C001	Air Compressor	_RUN	C001_RUN	DOL	DI	DRY CONTACT	1				SIEMENS	2	12	b.1
A	PLC	TG-F3WT-PH2	C001	Air Compressor	_TRIP	C001_TRIP	DOL	DI	DRY CONTACT	1				SIEMENS	2	12	b.2
A	PLC	TG-F3WT-PH2	C001	Air Compressor	_ISOLATOR_ON	C001_ISOLATOR_ON	DOL	DI	DRY CONTACT	1				SIEMENS	2	12	b.3
A	PLC	TG-F3WT-PH2	D001	Air Dryer	_REMOTE	D001_REMOTE	DOL	DI	DRY CONTACT	1				SIEMENS	2	12	b.4
A	PLC	TG-F3WT-PH2	D001	Air Dryer	_RUN	D001_RUN	DOL	DI	DRY CONTACT	1				SIEMENS	2	12	b.5
A	PLC	TG-F3WT-PH2	D001	Air Dryer	_TRIP	D001_TRIP	DOL	DI	DRY CONTACT	1				SIEMENS	2	12	b.6
A	PLC	TG-F3WT-PH2	D001	Air Dryer	_ISOLATOR_ON	D001_ISOLATOR_ON	DOL	DI	DRY CONTACT	1				SIEMENS	2	12	b.7
A	PLC	TG-F3WT-PH2	F001	Rotary Screen	_REMOTE	F001_REMOTE	DOL	DI	DRY CONTACT	1				SIEMENS	2	13	a.0
A	PLC	TG-F3WT-PH2	F001	Rotary Screen	_RUN	F001_RUN	DOL	DI	DRY CONTACT	1				SIEMENS	2	13	a.1
A	PLC	TG-F3WT-PH2	F001	Rotary Screen	_TRIP	F001_TRIP	DOL	DI	DRY CONTACT	1				SIEMENS	2	13	a.2
A	PLC	TG-F3WT-PH2	F001	Rotary Screen	_ISOLATOR_ON	F001_ISOLATOR_ON	DOL	DI	DRY CONTACT	1				SIEMENS	2	13	a.3
A	PLC	TG-F3WT-PH2	FIT-001	Intake Pump Flow	_PULSE	FIT-001_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	13	a.4
A	PLC	TG-F3WT-PH2	FIT-002	WWRP Phase 1 Inlet Flow	_PULSE	FIT-002_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	13	a.5
A	PLC	TG-F3WT-PH2	FIT-003	WWRP Phase 2 Inlet Flow	_PULSE	FIT-003_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	13	a.6
A	PLC	TG-F3WT-PH2	FIT-004	MOS Tank A Inlet Flow	_PULSE	FIT-004_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	13	a.7
A	PLC	TG-F3WT-PH2	FIT-005	MOS Tank A Scouring Air Flow	_PULSE	FIT-005_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	13	b.0
A	PLC	TG-F3WT-PH2	FIT-006	MOS Tank A Permeate Flow	_PULSE	FIT-006_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	13	b.1
A	PLC	TG-F3WT-PH2	FIT-007	MOS Tank A RAS Flow	_PULSE	FIT-007_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	13	b.2
A	PLC	TG-F3WT-PH2	FIT-008	MOS Tank B Inlet Flow	_PULSE	FIT-008_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	13	b.3

ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	FIT-009	MOS Tank B Scouring Air Flow	_PULSE	FIT-009_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	13	b.4
A	PLC	TG-F3WT-PH2	FIT-010	MOS Tank B Permeate Flow	_PULSE	FIT-010_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	13	b.5
A	PLC	TG-F3WT-PH2	FIT-011	MOS Tank B RAS Flow	_PULSE	FIT-011_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	13	b.6
A	PLC	TG-F3WT-PH2	FIT-012	MOS Tank C Inlet Flow	_PULSE	FIT-012_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	13	b.7
A	PLC	TG-F3WT-PH2	FIT-013	MOS Tank C Scouring Air Flow	_PULSE	FIT-013_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	14	a.0
A	PLC	TG-F3WT-PH2	FIT-014	MOS Tank C Permeate Flow	_PULSE	FIT-014_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	14	a.1
A	PLC	TG-F3WT-PH2	FIT-015	MOS Tank C RAS Flow	_PULSE	FIT-015_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	14	a.2
A	PLC	TG-F3WT-PH2	FIT-016	MOS Tank D Inlet Flow	_PULSE	FIT-016_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	14	a.3
A	PLC	TG-F3WT-PH2	FIT-017	MOS Tank D Scouring Air Flow	_PULSE	FIT-017_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	14	a.4
A	PLC	TG-F3WT-PH2	FIT-018	MOS Tank D Permeate Flow	_PULSE	FIT-018_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	14	a.5
A	PLC	TG-F3WT-PH2	FIT-019	MOS Tank D RAS Flow	_PULSE	FIT-019_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	14	a.6
A	PLC	TG-F3WT-PH2	FIT-020	MBR MC Flow	_PULSE	FIT-020_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	14	a.7
A	PLC	TG-F3WT-PH2	FIT-021	RO A Feed Flow	_PULSE	FIT-021_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	14	b.0
A	PLC	TG-F3WT-PH2	FIT-022	RO A Recirculation Flow	_PULSE	FIT-022_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	14	b.1
A	PLC	TG-F3WT-PH2	FIT-023	RO B Feed Flow	_PULSE	FIT-023_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	14	b.2
A	PLC	TG-F3WT-PH2	FIT-024	RO B Recirculation Flow	_PULSE	FIT-024_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	14	b.3
A	PLC	TG-F3WT-PH2	FIT-025	CIP Flow	_PULSE	FIT-025_PULSE	FLOW TRANSMITTER	DI	DRY CONTACT	1				SIEMENS	2	14	b.4
A	PLC	TG-F3WT-PH2	LS-001	Intake Pump Sump Level - L	_LSL	LS-001_LSL	LEVEL SWITCH	DI	DRY CONTACT	1				SIEMENS	2	14	b.5
A	PLC	TG-F3WT-PH2	LS-001	Intake Pump Sump Level - H	_LSH	LS-001_LSH	LEVEL SWITCH	DI	DRY CONTACT	1				SIEMENS	2	14	b.6
A	PLC	TG-F3WT-PH2	LS-001	Intake Pump Sump Level - HH	_LSHH	LS-001_LSHH	LEVEL SWITCH	DI	DRY CONTACT	1				SIEMENS	2	14	b.7
A	PLC	TG-F3WT-PH2	LS-002	Holding Pond 2 Level - L	_LSL	LS-002_LSL	LEVEL SWITCH	DI	DRY CONTACT	1				SIEMENS	2	15	a.0
A	PLC	TG-F3WT-PH2	LS-002	Holding Pond 2 Level - H	_LSH	LS-002_LSH	LEVEL SWITCH	DI	DRY CONTACT	1				SIEMENS	2	15	a.1
A	PLC	TG-F3WT-PH2	LS-002	Holding Pond 2 Level - HH	_LSHH	LS-002_LSHH	LEVEL SWITCH	DI	DRY CONTACT	1				SIEMENS	2	15	a.2
A	PLC	TG-F3WT-PH2	LS-003	MOS Tank A Permeate Level	_LS	LS-003_LS	LEVEL SWITCH	DI	DRY CONTACT	1				SIEMENS	2	15	a.3
A	PLC	TG-F3WT-PH2	LS-004	MOS Tank B Permeate Level	_LS	LS-004_LS	LEVEL SWITCH	DI	DRY CONTACT	1				SIEMENS	2	15	a.4
A	PLC	TG-F3WT-PH2	LS-005	MOS Tank C Permeate Level	_LS	LS-005_LS	LEVEL SWITCH	DI	DRY CONTACT	1				SIEMENS	2	15	a.5
A	PLC	TG-F3WT-PH2	LS-006	MOS Tank D Permeate Level	_LS	LS-006_LS	LEVEL SWITCH	DI	DRY CONTACT	1				SIEMENS	2	15	a.6
A	PLC	TG-F3WT-PH2	LS-007	NaOCl Dosing Tank	_LS	LS-007_LS	LEVEL SWITCH	DI	DRY CONTACT	1				SIEMENS	2	15	a.7
A	PLC	TG-F3WT-PH2	LS-008	Citric Acid Dosing Tank	_LS	LS-008_LS	LEVEL SWITCH	DI	DRY CONTACT	1				SIEMENS	2	15	b.0
A	PLC	TG-F3WT-PH2	LS-009	SMBS Dosing Tank	_LS	LS-009_LS	LEVEL SWITCH	DI	DRY CONTACT	1				SIEMENS	2	15	b.1
A	PLC	TG-F3WT-PH2	LS-010	Antiscalant Dosing Tank	_LS	LS-010_LS	LEVEL SWITCH	DI	DRY CONTACT	1				SIEMENS	2	15	b.2
A	PLC	TG-F3WT-PH2	LS-011	Caustic Dosing Tank	_LS	LS-011_LS	LEVEL SWITCH	DI	DRY CONTACT	1				SIEMENS	2	15	b.3
A	PLC	TG-F3WT-PH2	LS-012	H2SO4 Dosing Tank	_LS	LS-012_LS	LEVEL SWITCH	DI	DRY CONTACT	1				SIEMENS	2	15	b.4
A	PLC	TG-F3WT-PH2	LS-013	Coagulant Dosing Tank	_LS	LS-013_LS	LEVEL SWITCH	DI	DRY CONTACT	1				SIEMENS	2	15	b.5

ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	LS-014	Neutralisation Tank Level - L	_LSL	LS-014_LSL	LEVEL SWITCH	DI	DRY CONTACT	1				SIEMENS	2	15	b.6
A	PLC	TG-F3WT-PH2	LS-014	Neutralisation Tank Level - H	_LSH	LS-014_LSH	LEVEL SWITCH	DI	DRY CONTACT	1				SIEMENS	2	15	b.7
A	PLC	TG-F3WT-PH2	LS-014	Neutralisation Tank Level - HH	_LSHH	LS-014_LSHH	LEVEL SWITCH	DI	DRY CONTACT	1				SIEMENS	2	16	a.0
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	2	16	a.1
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	2	16	a.2
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	2	16	a.3
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	2	16	a.4
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	2	16	a.5
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	2	16	a.6
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	2	16	a.7
A	PLC	TG-F3WT-PH2	XV001	Static Screen Service Water Inlet	_OPEN	XV001_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	2	16	b.0
A	PLC	TG-F3WT-PH2	XV001	Static Screen Service Water Inlet	_CLOSE	XV001_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	2	16	b.1
A	PLC	TG-F3WT-PH2	XV003	MOS Tank A MC Tank Inlet	_OPEN	XV003_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	2	16	b.2
A	PLC	TG-F3WT-PH2	XV003	MOS Tank A MC Tank Inlet	_CLOSE	XV003_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	2	16	b.3
A	PLC	TG-F3WT-PH2	XV004	MOS Tank A Blower Air Inlet	_OPEN	XV004_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	2	16	b.4
A	PLC	TG-F3WT-PH2	XV004	MOS Tank A Blower Air Inlet	_CLOSE	XV004_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	2	16	b.5
A	PLC	TG-F3WT-PH2	XV005	MOS Tank A Priming	_OPEN	XV005_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	2	16	b.6
A	PLC	TG-F3WT-PH2	XV005	MOS Tank A Priming	_CLOSE	XV005_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	2	16	b.7
A	PLC	TG-F3WT-PH2	XV006	MOS Tank A Permeate	_OPEN	XV006_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	2	17	a.0
A	PLC	TG-F3WT-PH2	XV006	MOS Tank A Permeate	_CLOSE	XV006_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	2	17	a.1
A	PLC	TG-F3WT-PH2	XV007	MOS Tank A Permeate Outlet	_OPEN	XV007_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	2	17	a.2
A	PLC	TG-F3WT-PH2	XV007	MOS Tank A Permeate Outlet	_CLOSE	XV007_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	2	17	a.3
A	PLC	TG-F3WT-PH2	XV008	MOS Tank A Permeate Recycling	_OPEN	XV008_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	2	17	a.4
A	PLC	TG-F3WT-PH2	XV008	MOS Tank A Permeate Recycling	_CLOSE	XV008_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	2	17	a.5
A	PLC	TG-F3WT-PH2	XV009	MOS Tank A Test Air Inlet	_OPEN	XV009_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	2	17	a.6
A	PLC	TG-F3WT-PH2	XV009	MOS Tank A Test Air Inlet	_CLOSE	XV009_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	2	17	a.7
A	PLC	TG-F3WT-PH2	XV010	MOS Tank A MC Inlet	_OPEN	XV010_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	2	17	b.0
A	PLC	TG-F3WT-PH2	XV010	MOS Tank A MC Inlet	_CLOSE	XV010_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	2	17	b.1
A	PLC	TG-F3WT-PH2	XV011	MOS Tank A Compressed Air Inlet	_OPEN	XV011_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	2	17	b.2
A	PLC	TG-F3WT-PH2	XV011	MOS Tank A Compressed Air Inlet	_CLOSE	XV011_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	2	17	b.3
A	PLC	TG-F3WT-PH2	XV012	MOS Tank A RAS Return	_OPEN	XV012_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	2	17	b.4
A	PLC	TG-F3WT-PH2	XV012	MOS Tank A RAS Return	_CLOSE	XV012_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	2	17	b.5
A	PLC	TG-F3WT-PH2	XV013	MOS Tank A RAS Discharge	_OPEN	XV013_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	2	17	b.6
A	PLC	TG-F3WT-PH2	XV013	MOS Tank A RAS Discharge	_CLOSE	XV013_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	2	17	b.7

ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	XV014	MOS Tank B MC Tank Inlet	_OPEN	XV014_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	1	a.0
A	PLC	TG-F3WT-PH2	XV014	MOS Tank B MC Tank Inlet	_CLOSE	XV014_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	1	a.1
A	PLC	TG-F3WT-PH2	XV015	MOS Tank B Blower Air Inlet	_OPEN	XV015_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	1	a.2
A	PLC	TG-F3WT-PH2	XV015	MOS Tank B Blower Air Inlet	_CLOSE	XV015_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	1	a.3
A	PLC	TG-F3WT-PH2	XV016	MOS Tank B Compressed Air Inlet	_OPEN	XV016_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	1	a.4
A	PLC	TG-F3WT-PH2	XV016	MOS Tank B Compressed Air Inlet	_CLOSE	XV016_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	1	a.5
A	PLC	TG-F3WT-PH2	XV017	MOS Tank B Test Air Inlet	_OPEN	XV017_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	1	a.6
A	PLC	TG-F3WT-PH2	XV017	MOS Tank B Test Air Inlet	_CLOSE	XV017_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	1	a.7
A	PLC	TG-F3WT-PH2	XV018	MOS Tank B Priming	_OPEN	XV018_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	1	b.0
A	PLC	TG-F3WT-PH2	XV018	MOS Tank B Priming	_CLOSE	XV018_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	1	b.1
A	PLC	TG-F3WT-PH2	XV019	MOS Tank B MC Inlet	_OPEN	XV019_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	1	b.2
A	PLC	TG-F3WT-PH2	XV019	MOS Tank B MC Inlet	_CLOSE	XV019_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	1	b.3
A	PLC	TG-F3WT-PH2	XV020	MOS Tank B Permeate	_OPEN	XV020_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	1	b.4
A	PLC	TG-F3WT-PH2	XV020	MOS Tank B Permeate	_CLOSE	XV020_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	1	b.5
A	PLC	TG-F3WT-PH2	XV021	MOS Tank B Permeate Outlet	_OPEN	XV021_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	1	b.6
A	PLC	TG-F3WT-PH2	XV021	MOS Tank B Permeate Outlet	_CLOSE	XV021_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	1	b.7
A	PLC	TG-F3WT-PH2	XV022	MOS Tank B Permeate Recycling	_OPEN	XV022_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	2	a.0
A	PLC	TG-F3WT-PH2	XV022	MOS Tank B Permeate Recycling	_CLOSE	XV022_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	2	a.1
A	PLC	TG-F3WT-PH2	XV023	MOS Tank B RAS Return	_OPEN	XV023_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	2	a.2
A	PLC	TG-F3WT-PH2	XV023	MOS Tank B RAS Return	_CLOSE	XV023_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	2	a.3
A	PLC	TG-F3WT-PH2	XV024	MOS Tank B RAS Discharge	_OPEN	XV024_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	2	a.4
A	PLC	TG-F3WT-PH2	XV024	MOS Tank B RAS Discharge	_CLOSE	XV024_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	2	a.5
A	PLC	TG-F3WT-PH2	XV025	MOS Tank C Blower Air Inlet	_OPEN	XV025_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	2	a.6
A	PLC	TG-F3WT-PH2	XV025	MOS Tank C Blower Air Inlet	_CLOSE	XV025_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	2	a.7
A	PLC	TG-F3WT-PH2	XV026	MOS Tank C MC Tank Inlet	_OPEN	XV026_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	2	b.0
A	PLC	TG-F3WT-PH2	XV026	MOS Tank C MC Tank Inlet	_CLOSE	XV026_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	2	b.1
A	PLC	TG-F3WT-PH2	XV027	MOS Tank C Compressed Air Inlet	_OPEN	XV027_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	2	b.2
A	PLC	TG-F3WT-PH2	XV027	MOS Tank C Compressed Air Inlet	_CLOSE	XV027_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	2	b.3
A	PLC	TG-F3WT-PH2	XV028	MOS Tank C Test Air Inlet	_OPEN	XV028_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	2	b.4
A	PLC	TG-F3WT-PH2	XV028	MOS Tank C Test Air Inlet	_CLOSE	XV028_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	2	b.5
A	PLC	TG-F3WT-PH2	XV029	MOS Tank C Priming	_OPEN	XV029_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	2	b.6
A	PLC	TG-F3WT-PH2	XV029	MOS Tank C Priming	_CLOSE	XV029_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	2	b.7
A	PLC	TG-F3WT-PH2	XV030	MOS Tank C MC Inlet	_OPEN	XV030_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	3	a.0
A	PLC	TG-F3WT-PH2	XV030	MOS Tank C MC Inlet	_CLOSE	XV030_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	3	a.1

ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	XV031	MOS Tank C Permeate	_OPEN	XV031_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	3	a.2
A	PLC	TG-F3WT-PH2	XV031	MOS Tank C Permeate	_CLOSE	XV031_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	3	a.3
A	PLC	TG-F3WT-PH2	XV032	MOS Tank C Permeate Outlet	_OPEN	XV032_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	3	a.4
A	PLC	TG-F3WT-PH2	XV032	MOS Tank C Permeate Outlet	_CLOSE	XV032_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	3	a.5
A	PLC	TG-F3WT-PH2	XV033	MOS Tank C Permeate Recycling	_OPEN	XV033_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	3	a.6
A	PLC	TG-F3WT-PH2	XV033	MOS Tank C Permeate Recycling	_CLOSE	XV033_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	3	a.7
A	PLC	TG-F3WT-PH2	XV034	MOS Tank C RAS Return	_OPEN	XV034_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	3	b.0
A	PLC	TG-F3WT-PH2	XV034	MOS Tank C RAS Return	_CLOSE	XV034_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	3	b.1
A	PLC	TG-F3WT-PH2	XV035	MOS Tank C RAS Discharge	_OPEN	XV035_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	3	b.2
A	PLC	TG-F3WT-PH2	XV035	MOS Tank C RAS Discharge	_CLOSE	XV035_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	3	b.3
A	PLC	TG-F3WT-PH2	XV036	MOS Tank D Test Air Inlet	_OPEN	XV036_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	3	b.4
A	PLC	TG-F3WT-PH2	XV036	MOS Tank D Test Air Inlet	_CLOSE	XV036_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	3	b.5
A	PLC	TG-F3WT-PH2	XV037	MOS Tank D Compressed Air Inlet	_OPEN	XV037_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	3	b.6
A	PLC	TG-F3WT-PH2	XV037	MOS Tank D Compressed Air Inlet	_CLOSE	XV037_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	3	b.7
A	PLC	TG-F3WT-PH2	XV038	MOS Tank D Blower Air Inlet	_OPEN	XV038_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	4	a.0
A	PLC	TG-F3WT-PH2	XV038	MOS Tank D Blower Air Inlet	_CLOSE	XV038_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	4	a.1
A	PLC	TG-F3WT-PH2	XV039	MOS Tank D MC Tank Inlet	_OPEN	XV039_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	4	a.2
A	PLC	TG-F3WT-PH2	XV039	MOS Tank D MC Tank Inlet	_CLOSE	XV039_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	4	a.3
A	PLC	TG-F3WT-PH2	XV040	MOS Tank D Priming	_OPEN	XV040_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	4	a.4
A	PLC	TG-F3WT-PH2	XV040	MOS Tank D Priming	_CLOSE	XV040_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	4	a.5
A	PLC	TG-F3WT-PH2	XV041	MOS Tank D MC Inlet	_OPEN	XV041_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	4	a.6
A	PLC	TG-F3WT-PH2	XV041	MOS Tank D MC Inlet	_CLOSE	XV041_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	4	a.7
A	PLC	TG-F3WT-PH2	XV042	MOS Tank D Permeate	_OPEN	XV042_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	4	b.0
A	PLC	TG-F3WT-PH2	XV042	MOS Tank D Permeate	_CLOSE	XV042_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	4	b.1
A	PLC	TG-F3WT-PH2	XV043	MOS Tank D Permeate Outlet	_OPEN	XV043_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	4	b.2
A	PLC	TG-F3WT-PH2	XV043	MOS Tank D Permeate Outlet	_CLOSE	XV043_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	4	b.3
A	PLC	TG-F3WT-PH2	XV044	MOS Tank D Permeate Recycling	_OPEN	XV044_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	4	b.4
A	PLC	TG-F3WT-PH2	XV044	MOS Tank D Permeate Recycling	_CLOSE	XV044_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	4	b.5
A	PLC	TG-F3WT-PH2	XV045	MOS Tank D RAS Return	_OPEN	XV045_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	4	b.6
A	PLC	TG-F3WT-PH2	XV045	MOS Tank D RAS Return	_CLOSE	XV045_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	4	b.7
A	PLC	TG-F3WT-PH2	XV046	MOS Tank D RAS Discharge	_OPEN	XV046_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	5	a.0
A	PLC	TG-F3WT-PH2	XV046	MOS Tank D RAS Discharge	_CLOSE	XV046_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	5	a.1
A	PLC	TG-F3WT-PH2	XV047	RO A CIP Inlet	_OPEN	XV047_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	5	a.2
A	PLC	TG-F3WT-PH2	XV047	RO A CIP Inlet	_CLOSE	XV047_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	5	a.3

ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	XV048	RO A CIP Fill	_OPEN	XV048_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	5	a.4
A	PLC	TG-F3WT-PH2	XV048	RO A CIP Fill	_CLOSE	XV048_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	5	a.5
A	PLC	TG-F3WT-PH2	XV049	RO A Vent	_OPEN	XV049_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	5	a.6
A	PLC	TG-F3WT-PH2	XV049	RO A Vent	_CLOSE	XV049_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	5	a.7
A	PLC	TG-F3WT-PH2	XV050	RO A CIP Outlet	_OPEN	XV050_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	5	b.0
A	PLC	TG-F3WT-PH2	XV050	RO A CIP Outlet	_CLOSE	XV050_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	5	b.1
A	PLC	TG-F3WT-PH2	XV051	RO A Drain	_OPEN	XV051_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	5	b.2
A	PLC	TG-F3WT-PH2	XV051	RO A Drain	_CLOSE	XV051_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	5	b.3
A	PLC	TG-F3WT-PH2	XV052	RO B CIP Inlet	_OPEN	XV052_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	5	b.4
A	PLC	TG-F3WT-PH2	XV052	RO B CIP Inlet	_CLOSE	XV052_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	5	b.5
A	PLC	TG-F3WT-PH2	XV053	RO B CIP Outlet	_OPEN	XV053_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	5	b.6
A	PLC	TG-F3WT-PH2	XV053	RO B CIP Outlet	_CLOSE	XV053_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	5	b.7
A	PLC	TG-F3WT-PH2	XV054	RO B Drain	_OPEN	XV054_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	6	a.0
A	PLC	TG-F3WT-PH2	XV054	RO B Drain	_CLOSE	XV054_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	6	a.1
A	PLC	TG-F3WT-PH2	XV055	RO B Vent	_OPEN	XV055_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	6	a.2
A	PLC	TG-F3WT-PH2	XV055	RO B Vent	_CLOSE	XV055_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	6	a.3
A	PLC	TG-F3WT-PH2	XV056	RO B CIP Fill	_OPEN	XV056_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	6	a.4
A	PLC	TG-F3WT-PH2	XV056	RO B CIP Fill	_CLOSE	XV056_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	6	a.5
A	PLC	TG-F3WT-PH2	XV057	Waste Recycling	_OPEN	XV057_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	6	a.6
A	PLC	TG-F3WT-PH2	XV057	Waste Recycling	_CLOSE	XV057_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	6	a.7
A	PLC	TG-F3WT-PH2	XV058	Waste Discharge	_OPEN	XV058_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	6	b.0
A	PLC	TG-F3WT-PH2	XV058	Waste Discharge	_CLOSE	XV058_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	6	b.1
A	PLC	TG-F3WT-PH2	XV059	MOS CIP NaOCl dosing pump control valve	_OPEN	XV059_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	6	b.2
A	PLC	TG-F3WT-PH2	XV059	MOS CIP NaOCl dosing pump control valve	_CLOSE	XV059_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	6	b.3
A	PLC	TG-F3WT-PH2	XV060	MOS MC Citric acid dosing pump control valve	_OPEN	XV060_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	6	b.4
A	PLC	TG-F3WT-PH2	XV060	MOS MC Citric acid dosing pump control valve	_CLOSE	XV060_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	6	b.5
A	PLC	TG-F3WT-PH2	XV061	MOS CIP Citric acid dosing pump control valve	_OPEN	XV061_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	6	b.6
A	PLC	TG-F3WT-PH2	XV061	MOS CIP Citric acid dosing pump control valve	_CLOSE	XV061_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	6	b.7
A	PLC	TG-F3WT-PH2	XV062	Neutralization SMBS dosing pump control valve	_OPEN	XV062_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	7	a.0
A	PLC	TG-F3WT-PH2	XV062	Neutralization SMBS dosing pump control valve	_CLOSE	XV062_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	7	a.1
A	PLC	TG-F3WT-PH2	XV063	Neutralization caustic dosing pump control valve	_OPEN	XV063_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	7	a.2
A	PLC	TG-F3WT-PH2	XV063	Neutralization caustic dosing pump control valve	_CLOSE	XV063_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	7	a.3
A	PLC	TG-F3WT-PH2	XV064	Neutralization H2SO4 dosing pump control valve	_OPEN	XV064_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	7	a.4
A	PLC	TG-F3WT-PH2	XV064	Neutralization H2SO4 dosing pump control valve	_CLOSE	XV064_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	7	a.5

ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	XV065	NaOCl MC Inlet	_OPEN	XV065_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	7	a.6
A	PLC	TG-F3WT-PH2	XV065	NaOCl MC Inlet	_CLOSE	XV065_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	7	a.7
A	PLC	TG-F3WT-PH2	XV066	Citric Acid MC Inlet	_OPEN	XV066_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	7	b.0
A	PLC	TG-F3WT-PH2	XV066	Citric Acid MC Inlet	_CLOSE	XV066_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	7	b.1
A	PLC	TG-F3WT-PH2	XV067	RO 1 Feed Suction Valve	_OPEN	XV067_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	7	b.2
A	PLC	TG-F3WT-PH2	XV067	RO 1 Feed Suction Valve	_CLOSE	XV067_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	7	b.3
A	PLC	TG-F3WT-PH2	XV068	RO 2 Feed Suction Valve	_OPEN	XV068_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	7	b.4
A	PLC	TG-F3WT-PH2	XV068	RO 2 Feed Suction Valve	_CLOSE	XV068_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	7	b.5
A	PLC	TG-F3WT-PH2	XV069	SMBS RO1 Inlet	_OPEN	XV069_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	7	b.6
A	PLC	TG-F3WT-PH2	XV069	SMBS RO1 Inlet	_CLOSE	XV069_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	7	b.7
A	PLC	TG-F3WT-PH2	XV070	Antiscalant RO1 Inlet	_OPEN	XV070_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	8	a.0
A	PLC	TG-F3WT-PH2	XV070	Antiscalant RO1 Inlet	_CLOSE	XV070_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	8	a.1
A	PLC	TG-F3WT-PH2	XV071	SMBS RO2 Inlet	_OPEN	XV071_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	8	a.2
A	PLC	TG-F3WT-PH2	XV071	SMBS RO2 Inlet	_CLOSE	XV071_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	8	a.3
A	PLC	TG-F3WT-PH2	XV072	Antiscalant RO2 Inlet	_OPEN	XV072_OPEN	VALVE	DI	DRY CONTACT	1				SIEMENS	3	8	a.4
A	PLC	TG-F3WT-PH2	XV072	Antiscalant RO2 Inlet	_CLOSE	XV072_CLOSE	VALVE	DI	DRY CONTACT	1				SIEMENS	3	8	a.5
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	8	a.6
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	8	a.7
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	8	b.0
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	8	b.1
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	8	b.2
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	8	b.3
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	8	b.4
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	8	b.5
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	8	b.6
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	8	b.7
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	9	a.0
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	9	a.1
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	9	a.2
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	9	a.3
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	9	a.4
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	9	a.5
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	9	a.6
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	9	a.7

ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	9	b.0
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	9	b.1
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	9	b.2
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	9	b.3
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	9	b.4
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	9	b.5
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	9	b.6
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	9	b.7
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	10	a.0
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	10	a.1
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	10	a.2
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	10	a.3
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	10	a.4
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	10	a.5
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	10	a.6
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	10	a.7
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	10	b.0
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	10	b.1
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	10	b.2
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	10	b.3
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	10	b.4
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	10	b.5
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	10	b.6
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	10	b.7
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	11	a.0
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	11	a.1
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	11	a.2
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	11	a.3
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	11	a.4
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	11	a.5
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	11	a.6
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	11	a.7
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	11	b.0
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	11	b.1

ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	11	b.2
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	11	b.3
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	11	b.4
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	11	b.5
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	11	b.6
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	11	b.7
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	12	a.0
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	12	a.1
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	12	a.2
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	12	a.3
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	12	a.4
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	12	a.5
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	12	a.6
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	12	a.7
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	12	b.0
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	12	b.1
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	12	b.2
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	12	b.3
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	12	b.4
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	12	b.5
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	12	b.6
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	12	b.7
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	13	a.0
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	13	a.1
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	13	a.2
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	13	a.3
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	13	a.4
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	13	a.5
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	13	a.6
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	13	a.7
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	13	b.0
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	13	b.1
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	13	b.2
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	13	b.3

ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	13	b.4
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	13	b.5
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	13	b.6
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	13	b.7
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	14	a.0
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	14	a.1
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	14	a.2
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	14	a.3
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	14	a.4
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	14	a.5
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	14	a.6
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	14	a.7
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	14	b.0
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	14	b.1
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	14	b.2
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	14	b.3
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	14	b.4
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	14	b.5
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	14	b.6
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	14	b.7
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	15	a.0
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	15	a.1
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	15	a.2
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	15	a.3
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	15	a.4
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	15	a.5
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	15	a.6
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	15	a.7
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	15	b.0
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	15	b.1
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	15	b.2
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	15	b.3
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	15	b.4
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	15	b.5

ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	15	b.6
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	15	b.7
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	16	a.0
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	16	a.1
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	16	a.2
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	16	a.3
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	16	a.4
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	16	a.5
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	16	a.6
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	16	a.7
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	16	b.0
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	16	b.1
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	16	b.2
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	16	b.3
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	16	b.4
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	16	b.5
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	16	b.6
A	PLC	TG-F3WT-PH2	DI		_Spare	DI_Spare		DI	DRY CONTACT	1				SIEMENS	3	16	b.7
A	PLC	TG-F3WT-PH2	P001A	Phase 2 Intake Pump A Start Command	_Cmd	P001A_Cmd	S/S	DO	RELAY,WET		1			SIEMENS	4	1	a.0
A	PLC	TG-F3WT-PH2	P001B	Phase 2 Intake Pump B Start Command	_Cmd	P001B_Cmd	S/S	DO	RELAY,WET		1			SIEMENS	4	1	a.1
A	PLC	TG-F3WT-PH2	P001C	Phase 2 Intake Pump c Start Command	_Cmd	_P001C_Cmd	S/S	DO	RELAY,WET		1			SIEMENS	4	1	a.2
A	PLC	TG-F3WT-PH2	P003A	WWRP Phase 2 Feed Pump A Start Command	_Cmd	P003A_Cmd	S/S	DO	RELAY,WET		1			SIEMENS	4	1	a.3
A	PLC	TG-F3WT-PH2	P003B	WWRP Phase 2 Feed Pump B Start Command	_Cmd	P003B_Cmd	S/S	DO	RELAY,WET		1			SIEMENS	4	1	a.4
A	PLC	TG-F3WT-PH2	P003C	WWRP Phase 2 Feed Pump C Start Command	_Cmd	P003C_Cmd	S/S	DO	RELAY,WET		1			SIEMENS	4	1	a.5
A	PLC	TG-F3WT-PH2	P003D	WWRP Phase 2 Feed Pump D Start Command	_Cmd	P003D_Cmd	S/S	DO	RELAY,WET		1			SIEMENS	4	1	a.6
A	PLC	TG-F3WT-PH2	P004A	MBR Permeate Pump A Start Command	_Cmd	P004A_Cmd	VFD	DO	RELAY,WET		1			SIEMENS	4	1	a.7
A	PLC	TG-F3WT-PH2	P004B	MBR Permeate Pump B Start Command	_Cmd	P004B_Cmd	VFD	DO	RELAY,WET		1			SIEMENS	4	1	b.0
A	PLC	TG-F3WT-PH2	P004C	MBR Permeate Pump C Start Command	_Cmd	P004C_Cmd	VFD	DO	RELAY,WET		1			SIEMENS	4	1	b.1
A	PLC	TG-F3WT-PH2	P004D	MBR Permeate Pump D Start Command	_Cmd	P004D_Cmd	VFD	DO	RELAY,WET		1			SIEMENS	4	1	b.2
A	PLC	TG-F3WT-PH2	P005A	MBR RAS Pump A Start Command	_Cmd	P005A_Cmd	S/S	DO	RELAY,WET		1			SIEMENS	4	1	b.3
A	PLC	TG-F3WT-PH2	P005B	MBR RAS Pump B Start Command	_Cmd	P005B_Cmd	S/S	DO	RELAY,WET		1			SIEMENS	4	1	b.4
A	PLC	TG-F3WT-PH2	P005C	MBR RAS Pump C Start Command	_Cmd	P005C_Cmd	S/S	DO	RELAY,WET		1			SIEMENS	4	1	b.5
A	PLC	TG-F3WT-PH2	P005D	MBR RAS Pump D Start Command	_Cmd	P005D_Cmd	VFD	DO	RELAY,WET		1			SIEMENS	4	1	b.6
A	PLC	TG-F3WT-PH2	P006A	MBR MC Pump A Start Command	_Cmd	P006A_Cmd	VFD	DO	RELAY,WET		1			SIEMENS	4	1	b.7

ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	P006B	MBR MC Pump B Start Command	_Cmd	P006B_Cmd	VFD	DO	RELAY,WET		1			SIEMENS	4	2	a.0
A	PLC	TG-F3WT-PH2	P007A	RO Feed Pump A Start Command	_Cmd	P007A_Cmd	VFD	DO	RELAY,WET		1			SIEMENS	4	2	a.1
A	PLC	TG-F3WT-PH2	P007B	RO Feed Pump B Start Command	_Cmd	P007B_Cmd	VFD	DO	RELAY,WET		1			SIEMENS	4	2	a.2
A	PLC	TG-F3WT-PH2	P007C	RO Feed Pump C Start Command	_Cmd	P007C_Cmd	VFD	DO	RELAY,WET		1			SIEMENS	4	2	a.3
A	PLC	TG-F3WT-PH2	P007D	RO Feed Pump D Start Command	_Cmd	P007D_Cmd	VFD	DO	RELAY,WET		1			SIEMENS	4	2	a.4
A	PLC	TG-F3WT-PH2	P008A	RO High Pressure Pump A Start Command	_Cmd	P008A_Cmd	VFD	DO	RELAY,WET		1			SIEMENS	4	2	a.5
A	PLC	TG-F3WT-PH2	P008B	RO High Pressure Pump B Start Command	_Cmd	P008B_Cmd	VFD	DO	RELAY,WET		1			SIEMENS	4	2	a.6
A	PLC	TG-F3WT-PH2	P009A	RO Recirculation Pump A Start Command	_Cmd	P009A_Cmd	VFD	DO	RELAY,WET		1			SIEMENS	4	2	a.7
A	PLC	TG-F3WT-PH2	P009B	RO Recirculation Pump B Start Command	_Cmd	P009B_Cmd	VFD	DO	RELAY,WET		1			SIEMENS	4	2	b.0
A	PLC	TG-F3WT-PH2	P009C	RO Recirculation Pump C Start Command	_Cmd	P009C_Cmd	VFD	DO	RELAY,WET		1			SIEMENS	4	2	b.1
A	PLC	TG-F3WT-PH2	P009D	RO Recirculation Pump D Start Command	_Cmd	P009D_Cmd	VFD	DO	RELAY,WET		1			SIEMENS	4	2	b.2
A	PLC	TG-F3WT-PH2	P010	RO CIP Pump	_Cmd	P010_Cmd	S/S	DO	RELAY,WET		1			SIEMENS	4	2	b.3
A	PLC	TG-F3WT-PH2	P011A	Waste Transfer Pump A Start Command	_Cmd	P011A_Cmd	S/S	DO	RELAY,WET		1			SIEMENS	4	2	b.4
A	PLC	TG-F3WT-PH2	P011B	Waste Transfer Pump B Start Command	_Cmd	P011B_Cmd	S/S	DO	RELAY,WET		1			SIEMENS	4	2	b.5
A	PLC	TG-F3WT-PH2	P012	RO Permeate Transfer Pump	_Cmd	P012_Cmd	DOL	DO	RELAY,WET		1			SIEMENS	4	2	b.6
A	PLC	TG-F3WT-PH2	DP001A	MBR NaOCl MC Dosing Pump A Start Command	_Cmd	DP001A_Cmd	DOL	DO	RELAY,WET		1			SIEMENS	4	2	b.7
A	PLC	TG-F3WT-PH2	DP003A	RO SMBS Dosing Pump A Start Command	_Cmd	DP003A_Cmd	DOL	DO	RELAY,WET		1			SIEMENS	4	3	a.0
A	PLC	TG-F3WT-PH2	DP003B	RO SMBS Dosing Pump B Start Command	_Cmd	DP003B_Cmd	DOL	DO	RELAY,WET		1			SIEMENS	4	3	a.1
A	PLC	TG-F3WT-PH2	DP005A	RO Antiscalant Dosing Pump A Start Command	_Cmd	DP005A_Cmd	DOL	DO	RELAY,WET		1			SIEMENS	4	3	a.2
A	PLC	TG-F3WT-PH2	DP005B	RO Antiscalant Dosing Pump B Start Command	_Cmd	DP005B_Cmd	DOL	DO	RELAY,WET		1			SIEMENS	4	3	a.3
A	PLC	TG-F3WT-PH2	DP008	Coagulant Dosing Pump	_Cmd	DP008_Cmd	DOL	DO	RELAY,WET		1			SIEMENS	4	3	a.4
A	PLC	TG-F3WT-PH2	MX001A	Anoxic Submersible Mixer A Start Command	_Cmd	MX001A_Cmd	DOL	DO	RELAY,WET		1			SIEMENS	4	3	a.5
A	PLC	TG-F3WT-PH2	MX001B	Anoxic Submersible Mixer B Start Command	_Cmd	MX001B_Cmd	DOL	DO	RELAY,WET		1			SIEMENS	4	3	a.6
A	PLC	TG-F3WT-PH2	BL001A	Areation Air Blower A Start Command	_Cmd	BL001A_Cmd	VFD	DO	RELAY,WET		1			SIEMENS	4	3	a.7
A	PLC	TG-F3WT-PH2	BL001B	Areation Air Blower B Start Command	_Cmd	BL001B_Cmd	VFD	DO	RELAY,WET		1			SIEMENS	4	3	b.0
A	PLC	TG-F3WT-PH2	BL001C	Areation Air Blower C Start Command	_Cmd	BL001C_Cmd	VFD	DO	RELAY,WET		1			SIEMENS	4	3	b.1
A	PLC	TG-F3WT-PH2	BL002A	MBR Scouring Blower A Start Command	_Cmd	BL002A_Cmd	VFD	DO	RELAY,WET		1			SIEMENS	4	3	b.2
A	PLC	TG-F3WT-PH2	BL002B	MBR Scouring Blower B Start Command	_Cmd	BL002B_Cmd	VFD	DO	RELAY,WET		1			SIEMENS	4	3	b.3
A	PLC	TG-F3WT-PH2	BL002C	MBR Scouring Blower C Start Command	_Cmd	BL002C_Cmd	VFD	DO	RELAY,WET		1			SIEMENS	4	3	b.4
A	PLC	TG-F3WT-PH2	BL002D	MBR Scouring Blower D Start Command	_Cmd	BL002D_Cmd	VFD	DO	RELAY,WET		1			SIEMENS	4	3	b.5
A	PLC	TG-F3WT-PH2	F001	Rotary Screen	_Cmd	F001_Cmd	DOL	DO	RELAY,WET		1			SIEMENS	4	3	b.6
A	PLC	TG-F3WT-PH2	XV-001	Static Screen Service Water Inlet	_Cmd	XV-001_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	3	b.7
A	PLC	TG-F3WT-PH2	XV-003	MOS Tank A MC Tank Inlet	_Cmd	XV-003_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	4	a.0
A	PLC	TG-F3WT-PH2	XV-004	MOS Tank A Blower Air Inlet	_Cmd	XV-004_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	4	a.1

ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	XV-005	MOS Tank A Priming	_Cmd	XV-005_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	4	a.2
A	PLC	TG-F3WT-PH2	XV-006	MOS Tank A Permeate	_Cmd	XV-006_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	4	a.3
A	PLC	TG-F3WT-PH2	XV-007	MOS Tank A Permeate Outlet	_Cmd	XV-007_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	4	a.4
A	PLC	TG-F3WT-PH2	XV-008	MOS Tank A Permeate Recycling	_Cmd	XV-008_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	4	a.5
A	PLC	TG-F3WT-PH2	XV-009	MOS Tank A Test Air Inlet	_Cmd	XV-009_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	4	a.6
A	PLC	TG-F3WT-PH2	XV-010	MOS Tank A MC Inlet	_Cmd	XV-010_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	4	a.7
A	PLC	TG-F3WT-PH2	XV-011	MOS Tank A Compressed Air Inlet	_Cmd	XV-011_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	4	b.0
A	PLC	TG-F3WT-PH2	XV-012	MOS Tank A RAS Return	_Cmd	XV-012_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	4	b.1
A	PLC	TG-F3WT-PH2	XV-013	MOS Tank A RAS Discharge	_Cmd	XV-013_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	4	b.2
A	PLC	TG-F3WT-PH2	XV-014	MOS Tank B MC Tank Inlet	_Cmd	XV-014_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	4	b.3
A	PLC	TG-F3WT-PH2	XV-015	MOS Tank B Blower Air Inlet	_Cmd	XV-015_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	4	b.4
A	PLC	TG-F3WT-PH2	XV-016	MOS Tank B Compressed Air Inlet	_Cmd	XV-016_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	4	b.5
A	PLC	TG-F3WT-PH2	XV-017	MOS Tank B Test Air Inlet	_Cmd	XV-017_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	4	b.6
A	PLC	TG-F3WT-PH2	XV-018	MOS Tank B Priming	_Cmd	XV-018_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	4	b.7
A	PLC	TG-F3WT-PH2	XV-019	MOS Tank B MC Inlet	_Cmd	XV-019_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	5	a.0
A	PLC	TG-F3WT-PH2	XV-020	MOS Tank B Permeate	_Cmd	XV-020_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	5	a.1
A	PLC	TG-F3WT-PH2	XV-021	MOS Tank B Permeate Outlet	_Cmd	XV-021_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	5	a.2
A	PLC	TG-F3WT-PH2	XV-022	MOS Tank B Permeate Recycling	_Cmd	XV-022_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	5	a.3
A	PLC	TG-F3WT-PH2	XV-023	MOS Tank B RAS Return	_Cmd	XV-023_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	5	a.4
A	PLC	TG-F3WT-PH2	XV-024	MOS Tank B RAS Discharge	_Cmd	XV-024_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	5	a.5
A	PLC	TG-F3WT-PH2	XV-025	MOS Tank C Blower Air Inlet	_Cmd	XV-025_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	5	a.6
A	PLC	TG-F3WT-PH2	XV-026	MOS Tank C MC Tank Inlet	_Cmd	XV-026_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	5	a.7
A	PLC	TG-F3WT-PH2	XV-027	MOS Tank C Compressed Air Inlet	_Cmd	XV-027_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	5	b.0
A	PLC	TG-F3WT-PH2	XV-028	MOS Tank C Test Air Inlet	_Cmd	XV-028_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	5	b.1
A	PLC	TG-F3WT-PH2	XV-029	MOS Tank C Priming	_Cmd	XV-029_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	5	b.2
A	PLC	TG-F3WT-PH2	XV-030	MOS Tank C MC Inlet	_Cmd	XV-030_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	5	b.3
A	PLC	TG-F3WT-PH2	XV-031	MOS Tank C Permeate	_Cmd	XV-031_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	5	b.4
A	PLC	TG-F3WT-PH2	XV-032	MOS Tank C Permeate Outlet	_Cmd	XV-032_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	5	b.5
A	PLC	TG-F3WT-PH2	XV-033	MOS Tank C Permeate Recycling	_Cmd	XV-033_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	5	b.6
A	PLC	TG-F3WT-PH2	XV-034	MOS Tank C RAS Return	_Cmd	XV-034_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	5	b.7
A	PLC	TG-F3WT-PH2	XV-035	MOS Tank C RAS Discharge	_Cmd	XV-035_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	6	a.0
A	PLC	TG-F3WT-PH2	XV-036	MOS Tank D Test Air Inlet	_Cmd	XV-036_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	6	a.1
A	PLC	TG-F3WT-PH2	XV-037	MOS Tank D Compressed Air Inlet	_Cmd	XV-037_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	6	a.2
A	PLC	TG-F3WT-PH2	XV-038	MOS Tank D Blower Air Inlet	_Cmd	XV-038_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	6	a.3

ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	XV-039	MOS Tank D MC Tank Inlet	_Cmd	XV-039_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	6	a.4
A	PLC	TG-F3WT-PH2	XV-040	MOS Tank D Priming	_Cmd	XV-040_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	6	a.5
A	PLC	TG-F3WT-PH2	XV-041	MOS Tank D MC Inlet	_Cmd	XV-041_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	6	a.6
A	PLC	TG-F3WT-PH2	XV-042	MOS Tank D Permeate	_Cmd	XV-042_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	6	a.7
A	PLC	TG-F3WT-PH2	XV-043	MOS Tank D Permeate Outlet	_Cmd	XV-043_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	6	b.0
A	PLC	TG-F3WT-PH2	XV-044	MOS Tank D Permeate Recycling	_Cmd	XV-044_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	6	b.1
A	PLC	TG-F3WT-PH2	XV-045	MOS Tank D RAS Return	_Cmd	XV-045_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	6	b.2
A	PLC	TG-F3WT-PH2	XV-046	MOS Tank D RAS Discharge	_Cmd	XV-046_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	6	b.3
A	PLC	TG-F3WT-PH2	XV-047	RO A CIP Inlet	_Cmd	XV-047_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	6	b.4
A	PLC	TG-F3WT-PH2	XV-048	RO A CIP Fill	_Cmd	XV-048_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	6	b.5
A	PLC	TG-F3WT-PH2	XV-049	RO A Vent	_Cmd	XV-049_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	6	b.6
A	PLC	TG-F3WT-PH2	XV-050	RO A CIP Outlet	_Cmd	XV-050_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	6	b.7
A	PLC	TG-F3WT-PH2	XV-051	RO A Drain	_Cmd	XV-051_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	7	a.0
A	PLC	TG-F3WT-PH2	XV-052	RO B CIP Inlet	_Cmd	XV-052_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	7	a.1
A	PLC	TG-F3WT-PH2	XV-053	RO B CIP Outlet	_Cmd	XV-053_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	7	a.2
A	PLC	TG-F3WT-PH2	XV-054	RO B Drain	_Cmd	XV-054_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	7	a.3
A	PLC	TG-F3WT-PH2	XV-055	RO B Vent	_Cmd	XV-055_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	7	a.4
A	PLC	TG-F3WT-PH2	XV-056	RO B CIP Fill	_Cmd	XV-056_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	7	a.5
A	PLC	TG-F3WT-PH2	XV-057	Waste Recycling	_Cmd	XV-057_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	7	a.6
A	PLC	TG-F3WT-PH2	XV-058	Waste Discharge	_Cmd	XV-058_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	7	a.7
A	PLC	TG-F3WT-PH2	XV-059	MOS CIP NaOCl dosing pump control valve	_Cmd	XV-059_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	7	b.0
A	PLC	TG-F3WT-PH2	XV-060	MOS MC Citric acid dosing pump control valve	_Cmd	XV-060_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	7	b.1
A	PLC	TG-F3WT-PH2	XV-061	MOS CIP Citric acid dosing pump control valve	_Cmd	XV-061_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	7	b.2
A	PLC	TG-F3WT-PH2	XV-062	Neutralization SMBS dosing pump control valve	_Cmd	XV-062_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	7	b.3
A	PLC	TG-F3WT-PH2	XV-063	Neutralization caustic dosing pump control valve	_Cmd	XV-063_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	7	b.4
A	PLC	TG-F3WT-PH2	XV-064	Neutralization H2SO4 dosing pump control valve	_Cmd	XV-064_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	7	b.5
A	PLC	TG-F3WT-PH2	XV-065	NaOCl MC Inlet	_Cmd	XV-065_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	7	b.6
A	PLC	TG-F3WT-PH2	XV-066	Citric Acid MC Inlet	_Cmd	XV-066_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	7	b.7
A	PLC	TG-F3WT-PH2	XV-067	RO 1 Feed Suction Valve	_Cmd	XV-067_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	8	a.0
A	PLC	TG-F3WT-PH2	XV-068	RO 2 Feed Suction Valve	_Cmd	XV-068_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	8	a.1
A	PLC	TG-F3WT-PH2	XV-069	SMBS RO1 Inlet	_Cmd	XV-069_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	8	a.2
A	PLC	TG-F3WT-PH2	XV-070	Antiscalant RO1 Inlet	_Cmd	XV-070_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	8	a.3
A	PLC	TG-F3WT-PH2	XV-071	SMBS RO2 Inlet	_Cmd	XV-071_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	8	a.4
A	PLC	TG-F3WT-PH2	XV-072	Antiscalant RO2 Inlet	_Cmd	XV-072_Cmd	VALVE	DO	RELAY,WET		1			SIEMENS	4	8	a.5

ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	8	a.6
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	8	a.7
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	8	b.0
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	8	b.1
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	8	b.2
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	8	b.3
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	8	b.4
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	8	b.5
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	8	b.6
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	8	b.7
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	9	a.0
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	9	a.1
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	9	a.2
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	9	a.3
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	9	a.4
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	9	a.5
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	9	a.6
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	9	a.7
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	9	b.0
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	9	b.1
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	9	b.2
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	9	b.3
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	9	b.4
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	9	b.5
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	9	b.6
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	9	b.7
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	10	a.0
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	10	a.1
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	10	a.2
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	10	a.3
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	10	a.4
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	10	a.5
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	10	a.6
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	10	a.7
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	10	b.0

ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	10	b.1
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	10	b.2
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	10	b.3
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	10	b.4
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	10	b.5
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	10	b.6
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	10	b.7
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	11	a.0
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	11	a.1
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	11	a.2
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	11	a.3
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	11	a.4
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	11	a.5
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	11	a.6
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	11	a.7
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	11	b.0
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	11	b.1
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	11	b.2
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	11	b.3
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	11	b.4
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	11	b.5
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	11	b.6
A	PLC	TG-F3WT-PH2	DO		_Spare	DO_Spare		DO	RELAY,WET		1			SIEMENS	4	11	b.7
A	PLC	TG-F3WT-PH2	FIT001	Intake Pump Flow	_RawIn	FIT001_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	12	0
A	PLC	TG-F3WT-PH2	FIT002	WWRP Phase 1 Inlet Flow	_RawIn	FIT002_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	12	1
A	PLC	TG-F3WT-PH2	FIT003	WWRP Phase 2 Inlet Flow	_RawIn	FIT003_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	12	2
A	PLC	TG-F3WT-PH2	FIT004	MOS Tank A Inlet Flow	_RawIn	FIT004_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	12	3
A	PLC	TG-F3WT-PH2	FIT005	MOS Tank A Scouring Air Flow	_RawIn	FIT005_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	12	4
A	PLC	TG-F3WT-PH2	FIT006	MOS Tank A Permeate Flow	_RawIn	FIT006_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	12	5
A	PLC	TG-F3WT-PH2	FIT007	MOS Tank A RAS Flow	_RawIn	FIT007_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	12	6
A	PLC	TG-F3WT-PH2	FIT008	MOS Tank B Inlet Flow	_RawIn	FIT008_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	12	7
A	PLC	TG-F3WT-PH2	FIT009	MOS Tank B Scouring Air Flow	_RawIn	FIT009_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	13	0
A	PLC	TG-F3WT-PH2	FIT010	MOS Tank B Permeate Flow	_RawIn	FIT010_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	13	1
A	PLC	TG-F3WT-PH2	FIT011	MOS Tank B RAS Flow	_RawIn	FIT011_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	13	2
A	PLC	TG-F3WT-PH2	FIT012	MOS Tank C Inlet Flow	_RawIn	FIT012_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	13	3

ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	FIT013	MOS Tank C Scouring Air Flow	_RawIn	FIT013_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	13	4
A	PLC	TG-F3WT-PH2	FIT014	MOS Tank C Permeate Flow	_RawIn	FIT014_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	13	5
A	PLC	TG-F3WT-PH2	FIT015	MOS Tank C RAS Flow	_RawIn	FIT015_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	13	6
A	PLC	TG-F3WT-PH2	FIT016	MOS Tank D Inlet Flow	_RawIn	FIT016_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	13	7
A	PLC	TG-F3WT-PH2	FIT017	MOS Tank D Scouring Air Flow	_RawIn	FIT017_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	14	0
A	PLC	TG-F3WT-PH2	FIT018	MOS Tank D Permeate Flow	_RawIn	FIT018_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	14	1
A	PLC	TG-F3WT-PH2	FIT019	MOS Tank D RAS Flow	_RawIn	FIT019_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	14	2
A	PLC	TG-F3WT-PH2	FIT020	MBR MC Flow	_RawIn	FIT020_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	14	3
A	PLC	TG-F3WT-PH2	FIT021	RO A Feed Flow	_RawIn	FIT021_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	14	4
A	PLC	TG-F3WT-PH2	FIT022	RO A Recirculation Flow	_RawIn	FIT022_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	14	5
A	PLC	TG-F3WT-PH2	FIT023	RO B Feed Flow	_RawIn	FIT023_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	14	6
A	PLC	TG-F3WT-PH2	FIT024	RO B Recirculation Flow	_RawIn	FIT024_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	14	7
A	PLC	TG-F3WT-PH2	FIT025	CIP Flow	_RawIn	FIT025_RawIn	FLOW TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	15	0
A	PLC	TG-F3WT-PH2	DO001	Areation Tank DO Analyser	_RawIn	DO001_RawIn	ANALYSER TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	15	1
A	PLC	TG-F3WT-PH2	AIT001	RO A Feed ORP Analyser	_RawIn	AIT001_RawIn	ANALYSER TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	15	2
A	PLC	TG-F3WT-PH2	AIT002	RO A Feed pH Analyser	_RawIn	AIT002_RawIn	ANALYSER TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	15	3
A	PLC	TG-F3WT-PH2	AIT003	RO A Feed Conductivity Analyser	_RawIn	AIT003_RawIn	ANALYSER TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	15	4
A	PLC	TG-F3WT-PH2	AIT004	RO A Permeate Conductivity Analyser	_RawIn	AIT004_RawIn	ANALYSER TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	15	5
A	PLC	TG-F3WT-PH2	AIT005	RO A Permeate pH Analyser	_RawIn	AIT005_RawIn	ANALYSER TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	15	6
A	PLC	TG-F3WT-PH2	AIT006	RO A Recirculation Conductivity Analyser	_RawIn	AIT006_RawIn	ANALYSER TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	15	7
A	PLC	TG-F3WT-PH2	AIT007	RO B Feed ORP Analyser	_RawIn	AIT007_RawIn	ANALYSER TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	16	0
A	PLC	TG-F3WT-PH2	AIT008	RO B Feed Conductivity Analyser	_RawIn	AIT008_RawIn	ANALYSER TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	16	1
A	PLC	TG-F3WT-PH2	AIT009	RO B Feed pH Analyser	_RawIn	AIT009_RawIn	ANALYSER TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	16	2
A	PLC	TG-F3WT-PH2	AIT010	RO B Permeate Conductivity Analyser	_RawIn	AIT010_RawIn	ANALYSER TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	16	3
A	PLC	TG-F3WT-PH2	AIT011	RO B Permeate pH Analyser	_RawIn	AIT011_RawIn	ANALYSER TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	16	4
A	PLC	TG-F3WT-PH2	AIT012	RO B Recirculation Conductivity Analyser	_RawIn	AIT012_RawIn	ANALYSER TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	16	5
A	PLC	TG-F3WT-PH2	PT001	MOS Tank A Permeate Pump Inlet Pressure	_RawIn	PT001_RawIn	PRESSURE TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	16	6
A	PLC	TG-F3WT-PH2	PT002	MOS Tank B Permeate Pump Inlet Pressure	_RawIn	PT002_RawIn	PRESSURE TRANSMITTER	AI	4 WIRE			1		SIEMENS	4	16	7
A	PLC	TG-F3WT-PH2	PT003	MOS Tank C Permeate Pump Inlet Pressure	_RawIn	PT003_RawIn	PRESSURE TRANSMITTER	AI	4 WIRE			1		SIEMENS	5	1	0
A	PLC	TG-F3WT-PH2	PT004	MOS Tank D Permeate Pump Inlet Pressure	_RawIn	PT004_RawIn	PRESSURE TRANSMITTER	AI	4 WIRE			1		SIEMENS	5	1	1
A	PLC	TG-F3WT-PH2	PT005	RO A HPP Suction Pressure	_RawIn	PT005_RawIn	PRESSURE TRANSMITTER	AI	4 WIRE			1		SIEMENS	5	1	2
A	PLC	TG-F3WT-PH2	PT006	RO A Vessel Feed Pressure	_RawIn	PT006_RawIn	PRESSURE TRANSMITTER	AI	4 WIRE			1		SIEMENS	5	1	3
A	PLC	TG-F3WT-PH2	PT007	RO A Permeate Pressure	_RawIn	PT007_RawIn	PRESSURE TRANSMITTER	AI	4 WIRE			1		SIEMENS	5	1	4
A	PLC	TG-F3WT-PH2	PT008	RO A Recirculation Pressure	_RawIn	PT008_RawIn	PRESSURE TRANSMITTER	AI	4 WIRE			1		SIEMENS	5	1	5
A	PLC	TG-F3WT-PH2	PT009	RO B HPP Suction Pressure	_RawIn	PT009_RawIn	PRESSURE TRANSMITTER	AI	4 WIRE			1		SIEMENS	5	1	6



ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	PT010	RO B Vessel Feed Pressure	_RawIn	PT010_RawIn	PRESSURE TRANSMITTER	AI	4 WIRE			1		SIEMENS	5	1	7
A	PLC	TG-F3WT-PH2	PT011	RO B Permeate Pressure	_RawIn	PT011_RawIn	PRESSURE TRANSMITTER	AI	4 WIRE			1		SIEMENS	5	2	0
A	PLC	TG-F3WT-PH2	PT012	RO B Recirculation Pressure	_RawIn	PT012_RawIn	PRESSURE TRANSMITTER	AI	4 WIRE			1		SIEMENS	5	2	1
A	PLC	TG-F3WT-PH2	LT001	Areation Tank Level	_RawIn	LT001_RawIn	LEVEL TRANSMITTER	AI	4 WIRE			1		SIEMENS	5	2	2
A	PLC	TG-F3WT-PH2	LT002	MOS Tank A Level	_RawIn	LT002_RawIn	LEVEL TRANSMITTER	AI	4 WIRE			1		SIEMENS	5	2	3
A	PLC	TG-F3WT-PH2	LT003	MOS Tank B Level	_RawIn	LT003_RawIn	LEVEL TRANSMITTER	AI	4 WIRE			1		SIEMENS	5	2	4
A	PLC	TG-F3WT-PH2	LT004	MOS Tank C Level	_RawIn	LT004_RawIn	LEVEL TRANSMITTER	AI	4 WIRE			1		SIEMENS	5	2	5
A	PLC	TG-F3WT-PH2	LT005	MOS Tank D Level	_RawIn	LT005_RawIn	LEVEL TRANSMITTER	AI	4 WIRE			1		SIEMENS	5	2	6
A	PLC	TG-F3WT-PH2	LT006	MBR Permeate Tank Level	_RawIn	LT006_RawIn	LEVEL TRANSMITTER	AI	4 WIRE			1		SIEMENS	5	2	7
A	PLC	TG-F3WT-PH2	LT007	RO Permeate Tank Level	_RawIn	LT007_RawIn	LEVEL TRANSMITTER	AI	4 WIRE			1		SIEMENS	5	3	0
A	PLC	TG-F3WT-PH2	LT008	CIP Tank Level	_RawIn	LT008_RawIn	LEVEL TRANSMITTER	AI	4 WIRE			1		SIEMENS	5	3	1
A	PLC	TG-F3WT-PH2	AI		_Spare	AI_Spare		AI	4 WIRE			1		SIEMENS	5	3	2
A	PLC	TG-F3WT-PH2	AI		_Spare	AI_Spare		AI	4 WIRE			1		SIEMENS	5	3	3
A	PLC	TG-F3WT-PH2	AI		_Spare	AI_Spare		AI	4 WIRE			1		SIEMENS	5	3	4
A	PLC	TG-F3WT-PH2	AI		_Spare	AI_Spare		AI	4 WIRE			1		SIEMENS	5	3	5
A	PLC	TG-F3WT-PH2	AI		_Spare	AI_Spare		AI	4 WIRE			1		SIEMENS	5	3	6
A	PLC	TG-F3WT-PH2	AI		_Spare	AI_Spare		AI	4 WIRE			1		SIEMENS	5	3	7
A	PLC	TG-F3WT-PH2	AI		_Spare	AI_Spare		AI	4 WIRE			1		SIEMENS	5	4	0
A	PLC	TG-F3WT-PH2	AI		_Spare	AI_Spare		AI	4 WIRE			1		SIEMENS	5	4	1
A	PLC	TG-F3WT-PH2	AI		_Spare	AI_Spare		AI	4 WIRE			1		SIEMENS	5	4	2
A	PLC	TG-F3WT-PH2	AI		_Spare	AI_Spare		AI	4 WIRE			1		SIEMENS	5	4	3
A	PLC	TG-F3WT-PH2	AI		_Spare	AI_Spare		AI	4 WIRE			1		SIEMENS	5	4	4
A	PLC	TG-F3WT-PH2	AI		_Spare	AI_Spare		AI	4 WIRE			1		SIEMENS	5	4	5
A	PLC	TG-F3WT-PH2	AI		_Spare	AI_Spare		AI	4 WIRE			1		SIEMENS	5	4	6
A	PLC	TG-F3WT-PH2	AI		_Spare	AI_Spare		AI	4 WIRE			1		SIEMENS	5	4	7
A	PLC	TG-F3WT-PH2	AI		_Spare	AI_Spare		AI	4 WIRE			1		SIEMENS	5	5	0
A	PLC	TG-F3WT-PH2	AI		_Spare	AI_Spare		AI	4 WIRE			1		SIEMENS	5	5	1
A	PLC	TG-F3WT-PH2	AI		_Spare	AI_Spare		AI	4 WIRE			1		SIEMENS	5	5	2
A	PLC	TG-F3WT-PH2	AI		_Spare	AI_Spare		AI	4 WIRE			1		SIEMENS	5	5	3
A	PLC	TG-F3WT-PH2	AI		_Spare	AI_Spare		AI	4 WIRE			1		SIEMENS	5	5	4
A	PLC	TG-F3WT-PH2	AI		_Spare	AI_Spare		AI	4 WIRE			1		SIEMENS	5	5	5
A	PLC	TG-F3WT-PH2	AI		_Spare	AI_Spare		AI	4 WIRE			1		SIEMENS	5	5	6
A	PLC	TG-F3WT-PH2	AI		_Spare	AI_Spare		AI	4 WIRE			1		SIEMENS	5	5	7
A	PLC	TG-F3WT-PH2	P004A	MBR Permeate Pump A Control	_Speed	P004A_Speed	VFD	AO	2 WIRE				1	SIEMENS	5	6	0
A	PLC	TG-F3WT-PH2	P004B	MBR Permeate Pump B Control	_Speed	P004B_Speed	VFD	AO	2 WIRE				1	SIEMENS	5	6	1



ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	P004C	MBR Permeate Pump C Control	_Speed	P004C_Speed	VFD	AO	2 WIRE				1	SIEMENS	5	6	2
A	PLC	TG-F3WT-PH2	P004D	MBR Permeate Pump D Control	_Speed	P004D_Speed	VFD	AO	2 WIRE				1	SIEMENS	5	6	3
A	PLC	TG-F3WT-PH2	P006A	MBR MC Pump A Control	_Speed	P006A_Speed	VFD	AO	2 WIRE				1	SIEMENS	5	7	0
A	PLC	TG-F3WT-PH2	P006B	MBR MC Pump B Control	_Speed	P006B_Speed	VFD	AO	2 WIRE				1	SIEMENS	5	7	1
A	PLC	TG-F3WT-PH2	P007A	RO Feed Pump A Control	_Speed	P007A_Speed	VFD	AO	2 WIRE				1	SIEMENS	5	7	2
A	PLC	TG-F3WT-PH2	P007B	RO Feed Pump B Control	_Speed	P007B_Speed	VFD	AO	2 WIRE				1	SIEMENS	5	7	3
A	PLC	TG-F3WT-PH2	P007C	RO Feed Pump C Control	_Speed	P007C_Speed	VFD	AO	2 WIRE				1	SIEMENS	5	8	0
A	PLC	TG-F3WT-PH2	P007D	RO Feed Pump D Control	_Speed	P007D_Speed	VFD	AO	2 WIRE				1	SIEMENS	5	8	1
A	PLC	TG-F3WT-PH2	P008A	RO High Pressure Pump A Control	_Speed	P008A_Speed	VFD	AO	2 WIRE				1	SIEMENS	5	8	2
A	PLC	TG-F3WT-PH2	P008B	RO High Pressure Pump B Control	_Speed	P008B_Speed	VFD	AO	2 WIRE				1	SIEMENS	5	8	3
A	PLC	TG-F3WT-PH2	P009A	RO Recirculation Pump A Control	_Speed	P009A_Speed	VFD	AO	2 WIRE				1	SIEMENS	5	9	0
A	PLC	TG-F3WT-PH2	P009B	RO Recirculation Pump B Control	_Speed	P009B_Speed	VFD	AO	2 WIRE				1	SIEMENS	5	9	1
A	PLC	TG-F3WT-PH2	P009C	RO Recirculation Pump C Control	_Speed	P009C_Speed	VFD	AO	2 WIRE				1	SIEMENS	5	9	2
A	PLC	TG-F3WT-PH2	P009D	RO Recirculation Pump D Control	_Speed	P009D_Speed	VFD	AO	2 WIRE				1	SIEMENS	5	9	3
A	PLC	TG-F3WT-PH2	BL001A	Areation Air Blower A Control	_Speed	BL001A_Speed	VFD	AO	2 WIRE				1	SIEMENS	5	10	0
A	PLC	TG-F3WT-PH2	BL001B	Areation Air Blower B Control	_Speed	BL001B_Speed	VFD	AO	2 WIRE				1	SIEMENS	5	10	1
A	PLC	TG-F3WT-PH2	BL001C	Areation Air Blower C Control	_Speed	BL001C_Speed	VFD	AO	2 WIRE				1	SIEMENS	5	10	2
A	PLC	TG-F3WT-PH2	BL002A	MBR Scouring Blower A Control	_Speed	BL002A_Speed	VFD	AO	2 WIRE				1	SIEMENS	5	10	3
A	PLC	TG-F3WT-PH2	BL002B	MBR Scouring Blower B Control	_Speed	BL002B_Speed	VFD	AO	2 WIRE				1	SIEMENS	5	11	0
A	PLC	TG-F3WT-PH2	BL002C	MBR Scouring Blower C Control	_Speed	BL002C_Speed	VFD	AO	2 WIRE				1	SIEMENS	5	11	1
A	PLC	TG-F3WT-PH2	BL002D	MBR Scouring Blower D Control	_Speed	BL002D_Speed	VFD	AO	2 WIRE				1	SIEMENS	5	11	2
A	PLC	TG-F3WT-PH2	DP003A	RO SMBS Dosing Pump A Control	_Speed	DP003A_Speed	SMART PUMP	AO	2 WIRE				1	SIEMENS	5	11	3
A	PLC	TG-F3WT-PH2	DP003B	RO SMBS Dosing Pump B Control	_Speed	DP003B_Speed	SMART PUMP	AO	2 WIRE				1	SIEMENS	5	12	0
A	PLC	TG-F3WT-PH2	DP005A	RO Antiscalant Dosing Pump A Control	_Speed	DP005A_Speed	SMART PUMP	AO	2 WIRE				1	SIEMENS	5	12	1
A	PLC	TG-F3WT-PH2	DP005B	RO Antiscalant Dosing Pump B Control	_Speed	DP005B_Speed	SMART PUMP	AO	2 WIRE				1	SIEMENS	5	12	2
A	PLC	TG-F3WT-PH2	DP008	Coagulant Dosing Pump	_Speed	DP008_Speed	SMART PUMP	AO	2 WIRE				1	SIEMENS	5	12	3
A	PLC	TG-F3WT-PH2	FCV001	MOS Tank A WW Inlet Flow Control Valve	_CMD	FCV001_CMD	VALVE	AO	2 WIRE				1	SIEMENS	5	13	0
A	PLC	TG-F3WT-PH2	FCV002	MOS Tank B WW Inlet Flow Control Valve	_CMD	FCV002_CMD	VALVE	AO	2 WIRE				1	SIEMENS	5	13	1
A	PLC	TG-F3WT-PH2	FCV003	MOS Tank C WW Inlet Flow Control Valve	_CMD	FCV003_CMD	VALVE	AO	2 WIRE				1	SIEMENS	5	13	2
A	PLC	TG-F3WT-PH2	FCV004	MOS Tank D WW Inlet Flow Control Valve	_CMD	FCV004_CMD	VALVE	AO	2 WIRE				1	SIEMENS	5	13	3
A	PLC	TG-F3WT-PH2	AO		_Spare	AO_Spare		AO	2 WIRE				1	SIEMENS	5	14	0
A	PLC	TG-F3WT-PH2	AO		_Spare	AO_Spare		AO	2 WIRE				1	SIEMENS	5	14	1
A	PLC	TG-F3WT-PH2	AO		_Spare	AO_Spare		AO	2 WIRE				1	SIEMENS	5	14	2
A	PLC	TG-F3WT-PH2	AO		_Spare	AO_Spare		AO	2 WIRE				1	SIEMENS	5	14	3
A	PLC	TG-F3WT-PH2	AO		_Spare	AO_Spare		AO	2 WIRE				1	SIEMENS	5	15	0

ELECTRICAL IO LIST

Rev	Date	Description	Prepared By	Checked By	Approved By
A	15-Apr-21	Issued for Construction	CC	IH	ST

REV.	PANEL CODE	PLANT NAME	EQUIPMENT TAG	EQUIPMENT NAME	SIGNAL	SIGNAL TAG	SIGNAL DESCRIPTION	I/O TYPE	SIGNAL TYPE	DI	DO	AI	AO	PLC	RACK	SLOT	Channel
A	PLC	TG-F3WT-PH2	AO		_Spare	AO_Spare		AO	2 WIRE				1	SIEMENS	5	15	1
A	PLC	TG-F3WT-PH2	AO		_Spare	AO_Spare		AO	2 WIRE				1	SIEMENS	5	15	2
A	PLC	TG-F3WT-PH2	AO		_Spare	AO_Spare		AO	2 WIRE				1	SIEMENS	5	15	3
A	PLC	TG-F3WT-PH2	AO		_Spare	AO_Spare		AO	2 WIRE				1	SIEMENS	5	16	0
A	PLC	TG-F3WT-PH2	AO		_Spare	AO_Spare		AO	2 WIRE				1	SIEMENS	5	16	1
A	PLC	TG-F3WT-PH2	AO		_Spare	AO_Spare		AO	2 WIRE				1	SIEMENS	5	16	2
A	PLC	TG-F3WT-PH2	AO		_Spare	AO_Spare		AO	2 WIRE				1	SIEMENS	5	16	3
									Total	**528**	**176**	**80**	**44**				
									Spare	**145**	**58**	**22**	**12**				