Apache Airflow Integration

1. Airflow deployment

As usual, we login to the OpenShift cluster

```
# Replace the command with your own one inside the single quotes and run the cell
# Example OC_LOGIN_COMMAND='oc login --token=sha256~3bR5KXgwiUoaQiph2_kIXCDQnVfm_HQy3YwU2m-b
OC_LOGIN_COMMAND='_replace_this_string_by_pasting_the_clipboard_'
$OC_LOGIN_COMMAND
```

We beging by allocating a small piece of storage for our DAGs. We simply call it my-volume-claim

```
# This command creates a small persistent volume claim (1 GB, NFS)

oc apply -f - << EOF
kind: PersistentVolumeClaim
apiVersion: v1
metadata:
  name: my-volume-claim
  namespace: airflow
spec:
  accessModes:
    - ReadWriteMany
  resources:
    requests:
      storage: 1Gi
  storageClassName: managed-nfs-storage
  volumeMode: Filesystem
status:
  accessModes:
    - ReadWriteMany
  capacity:
```

```
      storage: 1Gi
EOF
```

Now, we reconfigure Airflow to look in our storage to find the DAGs. Additionally, we change one parameter (lazy_load) that is mandatory for the monitoring to work properly

```
 helm upgrade airflow apache-airflow/airflow \
  --set core.lazy_load_plugins=false \
  --set dags.persistence.enabled=true \
  --set dags.persistence.existingClaim=my-volume-claim \
  --set dags.gitSync.enabled=false -f - << EOF
extraEnv: |
   - name: AIRFLOW__CORE__LAZY_LOAD_PLUGINS
     value: 'False'
EOF
```

2. Airflow customization for Databand

The monitors of databand need a python package that we need to install in two pods of Airflow.

Warning: in a production system, you should extend the official container with the package and not install it directly into the pod. For educational purposes, it is OK to modify directly the pod but be aware that these changes will be lost after a redeployment / restart / etc.

```
# Install the monitoring package. Expect a long output
oc rsh  --shell=/bin/bash airflow-worker-0 /home/airflow/.local/bin/pip install dbnd-airflo
POD_SCHEDULER=$(oc get pods | grep airflow-scheduler | awk '{print $1}')
oc rsh  --shell=/bin/bash $POD_SCHEDULER /home/airflow/.local/bin/pip install dbnd-airflow c
echo dbnd-airflow-auto-tracking installed in airflow-worker-0 and $POD_SCHEDULER
```

That is the simple DAG that databand needs to initiate the monitors. We copy it into the default directory for the dags. Again, this file will be lost every time you redeploy / restart / etc. the pod. Never do this in production

```
oc project airflow
echo '# This DAG is used by Databand to monitor your Airflow installation.
from airflow_monitor.monitor_as_dag import get_monitor_dag
dag = get_monitor_dag()
' > databand_airflow_monitor.py

oc cp databand_airflow_monitor.py airflow-worker-0:/opt/airflow/dags
```

After some minutes, you should see a DAG in the Airflow console. Please activate it as indicated in the picture:

move this switch to the right

Actually, this is an auxiliary DAG of databand. Leave it as-is and you may want to experiment with your own ones or simply try a few examples located here https://github.com/apache/airflaow/tree/main/airflow/example_dags

```
curl https://raw.githubusercontent.com/apache/airflow/main/airflow/example_dags/example_comp
curl https://raw.githubusercontent.com/apache/airflow/main/airflow/example_dags/tutorial.py

oc cp my_test_dag.py airflow-worker-0:/opt/airflow/dags
oc cp tutorial.py airflow-worker-0:/opt/airflow/dags
```

3. Integration with databand

Now, we will connect Databand to Airflow. Start the Databand console and go to the Integrations secion


Select Airflow

Open the OpenShift console in a separate window and pick the address of the Airflow route

Paste the route of Airflow route in the `Airflow URL` field.

Complete the next section as follows:

Now, you you will have to copy-and-paste two fields to create a connection in Airflow

Add Airflow Integration   ✕

✓ ——————————— ✓ ——————————— ③
Configure Integration   Add Alerts   Connect Integration

click here

Connect Airflow Integration

1. Go to Airflow Connections page and create a new connection.

2. Copy the following value into the conn_id field of the Airflow Connection.

copy these values for the Airflow connection

| dbnd_config | 🗗 Copy |

The Conn type is 'HTTP'

3. Copy the following json into the extra field of the Airflow Connection.

🗗 Copy

```json
{
    "airflow_monitor": {
        "dag_ids": "",
        "is_sync_enabled": true,
        "syncer_name": "Airflow"
    },
    "core": {
        "databand_url": "http://databand-web-databand.itzroks-1
        "databand_access_token": "eyJ0eXAiOiJKV1QiLCJhbGciOiJIU
    },
    "log": {
        "preview_head_bytes": 8192,
        "preview_tail_bytes": 8192
    },
    "tracking": {
        "track_source_code": true
    }
}
```

tick the box and continue after having saved the connection in Airflow

☑ I've applied this configuration in Airflow   Back   Test Connection

This is the Airflow configuration page and the boxes to paste the values picked in the last picture

This message indicates that the configuration has been successfuly applied

Add Airflow Integration

Configure Integration — Add Alerts — **Connect Integration** 3

Integration has successfully connected!

Airflow integration is now synced.

Finish

If you used the DAGs examples mentioned before, you need to trigger them manually

Finally, the two DAGs will be displayed in Databand

Next Section: Datastage integration. Previous Section: Airflow deployment

Return to main