

Details of the Client					
Name					
Address					
Details of the Installation					
Name					
Address					
The extent of liability of the signatory is limited to the system described. Extent of system covered by this report:					
Variations from the recommendations of Clause 45 of BS 5839-1:2013 for periodic or annual inspection and test:					
Summary of Test & Inspection					
Inspection & Test Carried Out By:					
Address:					
Check ☐ Fire alarm & detection devices have been tested for correct operation Check ☐ Fire alarm & detection devices are undamaged, unpainted & unobstructed Check ☐ Automatic transmission of all signals to alarm receiving centre verified Check ☐ All monitored circuits have been checked by simulation of fault condition Check ☐ Printers have been checked, text is legible and supplies available Check ☐ CIE functions checked for correct operation Check ☐ The control equipment is in overall good condition Check ☐ The buildings structure, occupancy and layout have not changed Check ☐ System log book examined & faults recorded have been attended to					Remarks: Remarks: Remarks: Remarks: Remarks: Remarks: Remarks: Remarks: Remarks:
Battery Information			Battery Load Test Results		
No. of Batteries: <i>(for more than 2, record results on a separate numbered page)</i>		Battery A	Voltage:	Charge:	Date Installed:
Battery Voltage: Battery Capacity: <i>(if batteries are vented, make a note in the observations section)</i>		Battery B	Voltage:	Charge:	Date Installed:
<i>(For category M systems, enter not applicable "N/A")</i>					
During the past 12 months, 0 false alarms have occurred			The number of false alarms equates to 0 false alarms per 100 AFD's per annum		
The following work/action is considered necessary:					
Certification of Inspection and Servicing					
I/We being the competent person(s) responsible (as indicated by my/our signature(s) below) for the inspection and servicing of the fire alarm system, particulars of which are set out above, CERTIFY that the said work for which I/we have been responsible complies to the best of my/our knowledge and belief with the recommendations of Clause 45 of BS 5839-1: 2013 quarterly inspection of vented batteries/periodic inspection and test over a 12 month period except for the variations, if any, stated in this certificate. I/We further declare that in my/our judgement, the said system was overall in (tick appropriate box) ☒ a satisfactory ☐ an unsatisfactory condition at the time the inspection and servicing was carried out, and that it should be further inspected as recommended.					
Name:		Position:		Signature: Date:	