


# QUALIFIED VAR CALCULATION FOR SCHEDULE 2

Operations Support Services, ISO New England Inc.



- 1) Calculate the generator apparent power. The apparent power is calculated from the generator and the plant station service load real power and reactive power (gross values). Generally, the sign convention for the delivered VARs is positive and when VARs are being absorbed by the generator, the VARs are represented as negative.

The calculation for lagging and leading apparent power is as follow:

$$S_{\text{leading}} = \sqrt{(\text{Gen. gross Watts} - \text{Station Service Watts})^2 + (\text{Gen. gross VARs} - \text{Station Service VARs})^2}$$

$$S_{\text{lagging}} = \sqrt{(\text{Gen. gross Watts} - \text{Station Service Watts})^2 + (\text{Gen. gross VARs} - \text{Station Service VARs})^2}$$

To demonstrate the formula above, consider the following example based on a leading test raw data set.

Generator intended Gross MW Output =600 MW

Generator intended Gross MVAR Output =-100 MVAR (Leading)

Plant Station Service: 20 MW, 10 MVAR

GSU impedance % = 1.92 @ GSU Tap 1.00 p.u

$V_T = 20.9 \text{ kV}$  (Assume that  $S_{\text{base}} = 100 \text{ MVA}$ );  $1 \times 10^6 = \text{Mega (M)}$

$$S_{\text{gen leading (Apparent Power)}} = \sqrt{((600 - 20)E6)^2 + ((-100 - 10)E6)^2}$$

$$S_{\text{gen leading (Apparent Power)}} = \sqrt{((580)E6)^2 + ((-110)E6)^2}$$

$$S_{\text{gen leading (Apparent Power)}} = 590.339 \text{ MVA}$$

- 2) Determine the power factor of the machine using Net Watt and VAR value

$$\text{P.f} = \frac{P_{\text{net}} (\text{Net real power})}{\text{-----}}$$

$$\sqrt{(\text{Gen. gross Watts} - \text{Station Service Watts})^2 + (\text{Gen. gross VARs} - \text{Station Service VARs})^2}$$

# QUALIFIED VAR CALCULATION FOR SCHEDULE 2

Operations Support Services, ISO New England Inc.

$$= \frac{580 \text{ MW}}{590.339 \text{ MVA}} = .98248$$

$$\text{p.f.} = .98248 \text{ rad in degrees} \Rightarrow \cos^{-1}.98248 = 10.74^\circ$$

- 3) Determine the base current  $I_{\text{base}}$  ( Please note that (  $V_{\text{base}} = V_T$  ) and 1 kV= 1000 V)

$$I_{\text{base}} = \frac{S_{\text{base}}}{\sqrt{3} * V_{\text{base}}}$$

$$I_{\text{base}} = \frac{100 \text{ MVA}}{\sqrt{3} * 20.9 \text{ kV}} = 2.762 \text{ KA}$$

- 4) Determine the generator current (  $I_{\text{gen}}$  ) and convert to p.u.

$$I_{\text{gen}}^* = \frac{S_{\text{gen}} (\text{Apparent Power})}{\sqrt{3} * 20.9 \text{ kV}}$$

$$I_{\text{gen}}^* = \frac{590.339 \text{ MVA}}{\sqrt{3} * 20.9 \text{ kV}}$$

$$\cos^{-1}.98248 = 10.74^\circ = 16.307 \text{ KA } 10.74 \text{ degrees}$$

$$I_{\text{gen}} = \frac{16.307 \text{ KA}}{\sqrt{3} * 20.9 \text{ kV}}$$

\*conjugate

$$I_{\text{gen}} = 16.307 \text{ KA } -10.74 \text{ degrees}$$

$$I_{\text{gen p.u}} = \frac{I_{\text{gen}}}{I_{\text{base}}}$$

# QUALIFIED VAR CALCULATION FOR SCHEDULE 2

Operations Support Services, ISO New England Inc.

$$I_{\text{gen p.u}} = \frac{16.307 \text{ KA}}{2.762 \text{ KA}} = 5.9034 \text{ p.u}$$

- 5) Determine the  $Q_{\text{losses}}$  in P.U where GSU X% = Generator Impedance data %

$$X_{\text{p.u}} = X\%/100$$

$$X_{\text{p.u}} = 1.92/100 = .0192$$

$$Q_{\text{losses p.u}} = I_{\text{gen in p.u}}^2 * X_{\text{p.u}}$$

$$Q_{\text{losses p.u}} = (5.9034)^2 * (.0192) = .6691 \text{ p.u}$$

- 6) Calculate Actual GSU losses

$$Q_{\text{actual}} = Q_{\text{losses p.u}} * S_{\text{base}}$$

$$Q_{\text{actual}} = .6691 * 100\text{E6} = 66.912 \text{ MVARs}$$

- 7) Calculate the Leading Qualified VARs as follow:

Leading Qualified VARs = Leading demonstrated MVAR value+ Station Service Load + GSU Losses

$$\text{Leading Qualified VARs} = 100 + 10 + 66.912 = 176.912.5 \text{ MVAR}$$

# QUALIFIED VAR CALCULATION FOR SCHEDULE 2

Operations Support Services, ISO New England Inc.

## Consider The Following Example for Lagging VAR TEST

$V_T = 13.8$  kV Average     $S_{base} = 100$  MVA

Gross MW = 90    Gross MVAR= 25    and GSU    X% = 10.09

Plant Station Service Load : 8 MW, 3 MVAR

- 1) Calculate the generator apparent power. The apparent power is calculated from intended the Gen Gross MW and MVAR values.

$$S_{lagging} = \sqrt{(Gen. gross Watts - Station Service Watts)^2 + (Gen. gross VARs - Station Service VARs)^2}$$

$$S_{gen lagging} (Apparent Power) = \sqrt{((90 - 8)E6)^2 + ((25 - 3)E6)^2}$$

$$S_{gen lagging} (Apparent Power) = 84.899 \text{ MVA}$$

- 2) Determine the power factor of the machine at the Gross MW and MVAR value

$$P.f = \frac{P_{net} \text{ (Net real power)}}{\text{-----}}$$

$$\sqrt{(Gen. gross Watts - Station Service Watts)^2 + (Gen. gross VARs - Station Service VARs)^2}$$

$$= \frac{82 \text{ MW}}{84.99 \text{ MVA}} = .96548$$

$$p.f = .96548 \text{ in degrees} \quad \Rightarrow \quad \cos^{-1}.96548 = 15.02^\circ$$

- 3) Determine the base current  $I_{base}$  ( Please note that ( $V_{base} = V_T$ ) and 1 kV= 1000 V)

$$I_{base} = \frac{S_{base}}{\sqrt{3} * V_{base}}$$

$$I_{base} = \frac{100 \text{ MVA}}{\sqrt{3} * 13.8 \text{ kV}} = 4.183 \text{ KA}$$

- 4) Determine the generator current ( $I_{gen}$ ) and convert to p.u.

# QUALIFIED VAR CALCULATION FOR SCHEDULE 2

Operations Support Services, ISO New England Inc.

$$I_{gen}^* = \frac{S_{gen} \text{ (Apparent Power)}}{\sqrt{3} * 13.8 \text{ kV}}$$

$$\sqrt{3} * 13.8 \text{ kV}$$

$$I_{gen}^* = \frac{84.899 \text{ MVA}}{\sqrt{3} * 13.8 \text{ kV}}$$

$$\cos^{-1}(0.96548) = 15.02^\circ = 3.551 \text{ KA} \quad 15.02 \text{ degrees}$$

$$\sqrt{3} * 13.8 \text{ kV}$$

$$I_{gen} = 3.551 \text{ KA} \quad -15.02 \text{ degrees}$$

$$I_{gen \text{ p.u}} = \frac{I_{gen}}{I_{base}}$$

$$I_{gen \text{ p.u}} = \frac{3.551 \text{ KA}}{4.183 \text{ KA}} = .8490 \text{ p.u}$$

5) Determine the  $Q_{losses}$  in P.U where GSU X% = Generator Impedance data %

$$X_{p.u} = X\%/100$$

$$X_{p.u} = 10.09/100 = .1009$$

$$Q_{losses \text{ p.u}} = I_{gen \text{ p.u}}^2 * X_{p.u}$$

$$Q_{losses \text{ p.u}} = (.8490)^2 * (.1009) = .0727 \text{ p.u}$$

6) Calculate Actual GSU losses

$$Q_{actual} = Q_{losses \text{ p.u}} * S_{base}$$

$$Q_{actual} = .0727 * 100E6 = 7.272 \text{ MVARs}$$

7) Using the formula for lagging

## QUALIFIED VAR CALCULATION FOR SCHEDULE 2

Operations Support Services, ISO New England Inc.

Lagging Qualified VARs= Lagging demonstrated MVAR value- Station Service Load - GSU Losses

Lagging Qualified VARs=  $25 - 3 - 7.272 = 14.727$  MVARs

REFERENCE ONLY