

User Manual: Alarm & Output Behavior

1. Alarm Trigger

An alarm triggers immediately when any gauge value exceeds its ****High Threshold***
* (Bar turns Red).

2. Outputs

Output	Behavior	How to Reset
--------	----------	--------------

:---	:---	:---
------	------	------

Siren (Audio)	Turns **ON** immediately.	Press **Acknowledge (Button 2)** . This silences the siren permanently for the current alarm event.
--------------------------	----------------------------------	--

Strobe (Light)	Turns **ON** immediately and **Latches ON** .	Press **Reset (Button 1)** . *Note: The Strobe will only turn off if the gas level has returned to a Safe (Green) level.*
---------------------------	---	--

Warning Screen	Pops up immediately.	Press **Acknowledge (Button 2)** . This hides the screen for **60 seconds** .
---------------------------	----------------------	---

3. Warning Screen Logic

When an alarm occurs, the Warning Screen demands attention.

Acknowledge (Snooze)

- * Pressing ****Acknowledge (Button 2)**** hides the Warning Screen and returns you to the Dashboard.

- * This activates a ****60-Second Suppression Timer****.

- * During this 60 seconds, the screen will remain hidden to allow you to monitor the gauges.

Re-Appearence

- * ****After 60 Seconds****: If the alarm condition is ****still active****, the Warning Screen will automatically pop up again to remind you.

- * The Siren will ****NOT**** sound again (since you already acknowledged the audio).

- * You can press Acknowledge again to "snooze" it for another 60 seconds.

Logic Summary

> ****"Visuals remind you every minute. Audio warns you once per event."****