PRELIMINARY — NOT APPROVED FOR FABRICATION OR ENERGIZATION

PROJECT BUTTON HR-V0 ELECTRICAL V3 CARRIER-INTEGRATED CANDIDATE

P0.3 branch limiters inserted between F1/F2/F3 and DXL-STAR; pre/post rails are distinct.

01 External listed sources and DC boundaries

File: 01_external_sources.kicad_sch

02 Dual-channel E-stop and RESET eligibility

File: 02_estop_eligibility.kicad_sch

03 Distinct ARM and watchdog-gated SR1 supply

File: 03_arm_watchdog_eligibility.kicad_sch

04 Contactor coils, mirror contacts and EDM

File: 04_contactor_edm.kicad_sch

05 Redundant actuator-power interruption

File: 05_actuator_interruption.kicad_sch

06 Protected actuator branches and current-limiter carriers

File: 06_branches_and_limiters.kicad_sch

07 Independent watchdog power, controller and drivers

File: 07_watchdog_control.kicad_sch

08 Calculated dual-channel 24 V watchdog feedback

File: 08_watchdog_feedback_interface.kicad_sch

09 Compute and control terminals

File: 09_compute_and_control_terminals.kicad_sch

10 U2D2, DXL star, actuator ports and bonding boundary

File: 10_actuator_interfaces.kicad_sch

11 Watchdog PCB external connectors

File: 11_watchdog_pcb_connectors.kicad_sch

12 Watchdog PCB test access

File: 12_watchdog_pcb_test_access.kicad_sch

V2.1 PRESERVED; V3 IS A CONNECTED CANDIDATE
PRELIMINARY — NOT APPROVED FOR FABRICATION OR ENERGIZATION
Project Button
Sheet: /
File: project-button-v3-p1.15-carrier-candidate.kicad_sch
Title: PROJECT BUTTON HR-V0 ELECTRICAL V3 CARRIER-INTEGRATED CANDIDAT
Size: A3 | Date: 2026-08-09 | **Rev: V3-P1.15-CARRIER-CAN**
KiCad E.D.A. 10.0.5 | Id: 1/13

PRELIMINARY — NOT APPROVED FOR FABRICATION OR ENERGIZATION

01 External listed sources and DC boundaries

Factory-sealed adapters eliminate project-built mains wiring.





NOTE 1: All AC conductors shown are factory boundaries, not project-built wiring.

NOTE 2: Site cords, receptacles, GFCI/code basis and source application review remain open.

CONNECTED DESIGN CANDIDATE — QUALIFIED REVIEW REQUIRED
PRELIMINARY — NOT APPROVED FOR FABRICATION OR ENERGIZATION
Project Button
Sheet: /01 External listed sources and DC boundaries/
File: 01_external_sources.kicad_sch

Title: PB HR-V0 V3-P1.15-CARRIER-CANDIDATE — 01

Size: A3 | Date: 2026-08-09 | **Rev: V3-P1.15-CARRIER-CAN**
KiCad E.D.A. 10.0.5 | Id: 2/13

02 Dual-channel E-stop and RESET eligibility

Each SR1 input return contains only one S0 NC contact; RESET cannot energize K1/K2.



NOTE 1: S0 directly completes both SR1 input returns; ordinary KWD terminals are absent from both loops.

NOTE 2: Heartbeat loss removes SR1 A1 through the separate two-contact supply gate; recovery alone cannot restore the monitored RESET stage.

CONNECTED DESIGN CANDIDATE — QUALIFIED REVIEW REQUIRED
PRELIMINARY — NOT APPROVED FOR FABRICATION OR ENERGIZATION

Project Button

Sheet: /02 Dual-channel E-stop and RESET eligibility/
File: 02_estop_eligibility.kicad_sch

Title: PB HR-V0 V3-P1.15-CARRIER-CANDIDATE — 02

Size: A3	Date: 2026-08-09	**Rev: V3-P1.15-CARRIER-CAN**
KiCad E.D.A. 10.0.5		Id: 3/13

03 Distinct ARM and watchdog-gated SR1 supply

Two ordinary KWD contacts gate SR1 A1; SRA1 still requires SR1 outputs, EDM proof and a new ARM action.



NOTE 1: Required after E-stop/watchdog dropout: cause healthy -> KWD supply restored ->
RESET press/release -> SAFE_READY -> distinct ARM press/release.

NOTE 2: KWD contacts are in series with SR1 A1 only; S0 remains direct in both SR1 input
returns and SRA1 receives both SR1 safety outputs directly.

CONNECTED DESIGN CANDIDATE – QUALIFIED REVIEW REQUIRED
PRELIMINARY – NOT APPROVED FOR FABRICATION OR ENERGIZATION
Project Button
Sheet: /03 Distinct ARM and watchdog-gated SR1 supply/
File: 03_arm_watchdog_eligibility.kicad_sch
Title: PB HR-V0 V3-P1.15-CARRIER-CANDIDATE – 03
Size: A3 Date: 2026-08-09 **Rev: V3-P1.15-CARRIER-CAN**
KiCad E.D.A. 10.0.5 Id: 4/13

04 Contactor coils, mirror contacts and EDM

K1 and K2 are distinct final elements; their mirror contacts form the monitored restart return.

NOTE 1: SRA1 outputs are separately protected before K1 and K2 coils. FSR1/FSR2 use proposed Phoenix PT 4−HESI item 3211861 holders with D−ST 4 item 3030420 end cover; both fuse links, grouping and coordination remain SELECTION REQUIRED.

NOTE 2: Loaded DC interruption, suppression behavior, mirror−contact use and coordination require qualified review.

CONNECTED DESIGN CANDIDATE — QUALIFIED REVIEW REQUIRED
PRELIMINARY — NOT APPROVED FOR FABRICATION OR ENERGIZATION
Project Button
Sheet: /04 Contactor coils, mirror contacts and EDM/
File: 04_contactor_edm.kicad_sch

Title: PB HR−V0 V3−P1.15−CARRIER−CANDIDATE − 04

Size: A3	Date: 2026−08−09	**Rev: V3−P1.15−CARRIER−CAN**
KiCad E.D.A. 10.0.5		Id: 5/13

05 Redundant actuator–power interruption

Source protection, service disconnect and all three poles of K1 then K2 are represented in series.



NOTE 1: Series jumpers: K1 2T1–>3L2, 4T2–>5L3, 6T3–>K2 1L1; repeat through K2 to ACT_12V_BUS.

NOTE 2: No fuse, disconnect, conductor, connector or contactor application is released without fault–current evidence.

CONNECTED DESIGN CANDIDATE – QUALIFIED REVIEW REQUIRED
PRELIMINARY – NOT APPROVED FOR FABRICATION OR ENERGIZATION
Project Button
Sheet: /05 Redundant actuator–power interruption/
File: 05_actuator_interruption.kicad_sch
Title: PB HR–V0 V3–P1.15–CARRIER–CANDIDATE – 05
Size: A3 | Date: 2026–08–09 | **Rev: V3–P1.15–CARRIER–CAN**
KiCad E.D.A. 10.0.5 | Id: 6/13

06 Protected actuator branches and current–limiter carriers

Each fuse output and carrier output has a distinct positive rail; physical protection performance remains unproved.



NOTE 1: INJ1 is a fixed central star: U2D2 pin 2 is unrouted and J1/J2/J3 positive rails never join.

NOTE 2: Exact actuator cables, branch returns, enclosure, continuity, isolation, signal–integrity, pull and no–backfeed tests remain release gates.

CONNECTED DESIGN CANDIDATE — QUALIFIED REVIEW REQUIRED
PRELIMINARY — NOT APPROVED FOR FABRICATION OR ENERGIZATION
Project Button
Sheet: /06 Protected actuator branches and current–limiter carriers/
File: 06_branches_and_limiters.kicad_sch
Title: PB HR–V0 V3–P1.15–CARRIER–CANDIDATE — 06

Size: A3	Date: 2026–08–09	**Rev: V3–P1.15–CARRIER–CAN**
KiCad E.D.A. 10.0.5		Id: 7/13

07 Independent watchdog power, controller and drivers

The ordinary watchdog controller and drivers receive no safety–integrity credit by assertion.



NOTE 1: Power–up, brownout, clock, stuck–GPIO and firmware tests are mandatory.

NOTE 2: Qualified review decides whether watchdog loss is credited or diagnostic only;

current safety credit is NONE.

CONNECTED DESIGN CANDIDATE – QUALIFIED REVIEW REQUIRED
PRELIMINARY – NOT APPROVED FOR FABRICATION OR ENERGIZATION

Project Button

Sheet: /07 Independent watchdog power, controller and drivers/
File: 07_watchdog_control.kicad_sch

Title: PB HR–V0 V3–P1.15–CARRIER–CANDIDATE – 07

Size: A3 | Date: 2026–08–09 | **Rev: V3–P1.15–CARRIER–CAN**

KiCad E.D.A. 10.0.5 | Id: 8/13

08 Calculated dual-channel 24 V watchdog feedback

ISO1212DBQ converts both relay NC diagnostics to default-low 3.3 V logic; no isolation or safety credit is claimed.



NOTE 1: Type-3 values: RTHR=1.00 kOhm, RSENSE=562 Ohm, CIN=10 nF; calculated wetting load is 2.70 kOhm 1% 0.5 W per channel.

NOTE 2: Both grounds are SAFETY_0V; the ISO1212 barrier is not credited. Passive identities are frozen; PCB, derating, EMC and fault tests remain open.

CONNECTED DESIGN CANDIDATE — QUALIFIED REVIEW REQUIRED
PRELIMINARY — NOT APPROVED FOR FABRICATION OR ENERGIZATION
Project Button
Sheet: /08 Calculated dual-channel 24 V watchdog feedback/
File: 08_watchdog_feedback_interface.kicad_sch
Title: PB HR-V0 V3-P1.15-CARRIER-CANDIDATE — 08
Size: A3 | Date: 2026-08-09 | **Rev: V3-P1.15-CARRIER-CAN**
KiCad E.D.A. 10.0.5 | Id: 9/13

09 Compute and control terminals

High–level compute and diagnostic wiring have no authority to bypass or restore the safety chain.





NOTE 1: No installed debug connector exists; watchdog programming uses only TP15/TP16/TP2 under a future controlled unpowered–fixture procedure.

NOTE 2: Debug connection, halt, flash and disconnect must not enable outputs, back–power the board or bypass a protective function.

NOTE 3: Heartbeat cable, GPIO runtime, timing, terminal family, markers, conductor range, torque and enclosure layout remain selection required.

CONNECTED DESIGN CANDIDATE – QUALIFIED REVIEW REQUIRED
PRELIMINARY – NOT APPROVED FOR FABRICATION OR ENERGIZATION
Project Button
Sheet: /09 Compute and control terminals/
File: 09_compute_and_control_terminals.kicad_sch

Title: PB HR–V0 V3–P1.15–CARRIER–CANDIDATE – 09

Size: A3	Date: 2026–08–09	**Rev: V3–P1.15–CARRIER–CAN**
KiCad E.D.A. 10.0.5		Id: 10/13

10 U2D2, DXL star, actuator ports and bonding boundary

U2D2 pin 2 is omitted; DXL-STAR accepts three distinct limited positive rails and routes DATA/return.



NOTE 1: The V0 bus is TTL; HR-30 RS-485 remains a separate architecture.

NOTE 2: Do not bond frame or shields to 0V/PE until EMC and parallel-path review accepts the exact implementation.

CONNECTED DESIGN CANDIDATE – QUALIFIED REVIEW REQUIRED
PRELIMINARY – NOT APPROVED FOR FABRICATION OR ENERGIZATION
Project Button
Sheet: /10 U2D2, DXL star, actuator ports and bonding boundary/
File: 10_actuator_interfaces.kicad_sch
Title: PB HR-V0 V3-P1.15-CARRIER-CANDIDATE – 10
Size: A3 | Date: 2026-08-09 | **Rev: V3-P1.15-CARRIER-CAN**
KiCad E.D.A. 10.0.5 | Id: 11/13

11 Watchdog PCB external connectors

Exact PCB terminal–block candidates and project pin allocations define the board boundary; harness release remains open.



NOTE 1: Terminal numbering follows the PCB footprint and must be confirmed against received parts before wiring.

NOTE 2: Nominal terminal ratings do not release branch protection, conductor, ferrule, harness, enclosure or thermal application.

CONNECTED DESIGN CANDIDATE – QUALIFIED REVIEW REQUIRED
PRELIMINARY – NOT APPROVED FOR FABRICATION OR ENERGIZATION
Project Button
Sheet: /11 Watchdog PCB external connectors/
File: 11_watchdog_pcb_connectors.kicad_sch
Title: PB HR–V0 V3–P1.15–CARRIER–CANDIDATE – 11
Size: A3 Date: 2026–08–09 **Rev: V3–P1.15–CARRIER–CAN**
KiCad E.D.A. 10.0.5 Id: 12/13

12 Watchdog PCB test access

Exact clip–compatible test terminals expose controlled nodes without granting safety or operating authority.



NOTE 1: Test terminals are diagnostic features only; they provide no safety integrity or bypass authority.

NOTE 2: Verify clip clearance with guards, harnesses and power removed before any live measurement procedure is released.

CONNECTED DESIGN CANDIDATE – QUALIFIED REVIEW REQUIRED
PRELIMINARY – NOT APPROVED FOR FABRICATION OR ENERGIZATION
Project Button
Sheet: /12 Watchdog PCB test access/
File: 12_watchdog_pcb_test_access.kicad_sch

Title: PB HR–V0 V3–P1.15–CARRIER–CANDIDATE – 12

Size: A3 | Date: 2026–08–09 | **Rev: V3–P1.15–CARRIER–CAN**
KiCad E.D.A. 10.0.5 | Id: 13/13