

PROJECT BUTTON HR–V0 ISOLATED DYNAMIC EVENT INTERFACE

BENCH R&D EQUIPMENT ONLY; DIRECT FIELD TAPS PROHIBITED UNTIL NONINTERFERENCE REVIEW; ZERO SAFETY CREDIT

01 EVM A field taps – connection prohibited

File: 01_field_a.kicad_sch

02 EVM B field taps – connection prohibited

File: 02_field_b.kicad_sch

03 EVM logic–side connector allocation

File: 03_evm_logic.kicad_sch

04 Common–clock T7 capture and trigger witness

File: 04_common_clock_capture.kicad_sch

V2.1 PRESERVED; V3 IS A CONNECTED CANDIDATE
PRELIMINARY – NOT APPROVED FOR FABRICATION OR ENERGIZATION
Project Button
Sheet: /
File: hr–v0–dynamic–event–interface–p0.1.kicad_sch


Title: PROJECT BUTTON HR–V0 ISOLATED DYNAMIC EVENT INTERFACE		index
Size: A3	Date: 2026–08–10	Rev: R176 / P0.1
KiCad E.D.A. 10.0.5		Id: 1/5

01 EVM A field taps – connection prohibited

Exact J4 fast-channel allocation; noninterference and fault review open.

JFIELDA


LOGICAL FIELD TEST POINTS – NO CONNECTOR RELEASED



DIRECT CONNECTION PROHIBITED

EVMAJ4

TI ISO1212EVM A FIELD CONNECTOR J4



NOT SELECTED / BENCH R&D ONLY

NOTE 1: Each used input draws about 2.25 mA typical; J4 pin 1 is shared FGND.

NOTE 2: NO WIRE until diagnostic-pulse, start/reset, EDM and coil-loading effects are accepted.

CONNECTED DESIGN CANDIDATE – QUALIFIED REVIEW REQUIRED
PRELIMINARY – NOT APPROVED FOR FABRICATION OR ENERGIZATION**Project Button**

Sheet: /01 EVM A field taps – connection prohibited/

File: 01_field_a.kicad_sch

Title: PB HR-V0 R176 / P0.1 – 01

Size: A4

Date: 2026-08-10

Rev: R176 / P0.1

KiCad E.D.A. 10.0.5


Id: 2/5

02 EVM B field taps – connection prohibited

Exact J4 fast-channel allocation; noninterference and fault review open.

JFIELDB


LOGICAL FIELD TEST POINTS – NO CONNECTOR RELEASED



DIRECT CONNECTION PROHIBITED

EVMBJ4

TI ISO1212EVM B FIELD CONNECTOR J4



NOT SELECTED / BENCH R&D ONLY

NOTE 1: Each used input draws about 2.25 mA typical; J4 pin 1 is shared FGND.

NOTE 2: NO WIRE until diagnostic-pulse, start/reset, EDM and coil-loading effects are accepted.

CONNECTED DESIGN CANDIDATE – QUALIFIED REVIEW REQUIRED
PRELIMINARY – NOT APPROVED FOR FABRICATION OR ENERGIZATION

Project Button

Sheet: /02 EVM B field taps – connection prohibited/

File: 02_field_b.kicad_sch

Title: PB HR-V0 R176 / P0.1 – 02

Size: A4

Date: 2026-08-10



Rev: R176 / P0.1

KiCad E.D.A. 10.0.5

Id: 3/5

03 EVM logic-side connector allocation

Exact J1/J2 mapping; received jumpers, power budget and levels open.



NOTE 1: J3 must be photographed and verified in 1–2 ENABLE on both received EVMs.

NOTE 2: Only J2 pins 2/4/6/8 carry outputs; odd pins shown are logic GND.

CONNECTED DESIGN CANDIDATE – QUALIFIED REVIEW REQUIRED
PRELIMINARY – NOT APPROVED FOR FABRICATION OR ENERGIZATION**Project Button**

Sheet: /03 EVM logic-side connector allocation/

File: 03_evm_logic.kicad_sch

Title: PB HR-V0 R176 / P0.1 – 03

Size: A4

Date: 2026–08–10


KiCad E.D.A. 10.0.5

Rev: R176 / P0.1

Id: 4/5

04 Common-clock T7 capture and trigger witness

Exact DB37 mapping; trigger receiver and run configuration open.



NOTE 1: FIO_STATE candidate: FIO0 witness plus FIO1–FIO7 event bits.

NOTE 2: DAQ, host and trigger receive ZERO SAFETY CREDIT; timing and work authority remain open.

CONNECTED DESIGN CANDIDATE – QUALIFIED REVIEW REQUIRED
PRELIMINARY – NOT APPROVED FOR FABRICATION OR ENERGIZATION**Project Button**

Sheet: /04 Common-clock T7 capture and trigger witness/

File: 04_common_clock_capture.kicad_sch

Title: PB HR-V0 R176 / P0.1 – 04

Size: A4

Date: 2026-08-10

Rev: R176 / P0.1

KiCad E.D.A. 10.0.5

Id: 5/5