

# Engineering Change Notice

## ECN-1058

|                    |                                          |
|--------------------|------------------------------------------|
| <b>ECN Number:</b> | ECN-1058                                 |
| <b>Title:</b>      | Alarm A17 Threshold Reference Correction |
| <b>Effective:</b>  | Immediately upon publication             |
| <b>References:</b> | ECN-1042                                 |
| <b>Status:</b>     | Released                                 |

### 1. Description of Change

The Alarm Reference (AEG-AL-700) description for Alarm A17 (Hydraulic Pressure Low) referenced the pre-ECN-1042 pressure sensor (PS-04) by name. This notice corrects that reference: Alarm A17's low-pressure condition is evaluated against whichever pressure sensor is active for the installed software revision (PS-04 prior to revision 3.2, PS-04A on revision 3.2 and later). The alarm's threshold logic itself is unchanged by this notice.

This is a documentation correction only. No firmware or hardware change is required.

### 2. Note

This notice does not change the operating pressure setpoint established in ECN-1042.