

APPENDIX C — SENSOR CALIBRATION RECORD

Aegis Series-7 HCS (scanned from field service binder, uncontrolled copy)

Sensor Tag: PS-04A

Location: HPU discharge line

Calibration Date: 2026-01-09

Technician: R. Okafor

Calibration Points

Point	Reference	Reading	Result
Zero (0%)	0 bar	0.1 bar	PASS
Mid (50%)	100 bar	99.6 bar	PASS
Span (100%)	200 bar	199.4 bar	PASS

Note: this calibration record supersedes the field data sheet used prior to the PS-04 to PS-04A sensor change (see ECN-1042). Span reference target is 200 bar, consistent with the software revision 3.2 operating pressure setpoint.

Prior sensor (PS-04) span reference target was 180 bar — for historical comparison only. Do not use the 180 bar figure to evaluate PS-04A.

No calibration interval is specified for PS-04A on this form; recalibration frequency should be confirmed against the applicable maintenance schedule, which is not included in this binder.

Signature: _____

Date: _____

