

Declaration Of Performance

No XXXXXXXXXX

1. Unique identification code of the product-type

XX/XXXXX/XX/XXX

2. Intended use/es

Automatic smoke barrier mcr Prosmoke CE1 (A x B KD1-2)
Component used in smoke and heat exhaust systems

3. Name and address of the manufacturer

MERCOR S.A. ul. Grzegorza z Sanoka 2. 80-408 Gdańsk. Poland. MERCOR S.A.
ul. Kwarcowa 3A. 83-031 Łęgowo. Poland

4. Authorised representative

-

1

5. System/s of AVCP

EN 12101-1:2005. EN 12101-1:2005/A1:2006 (PN-EN12101-1:2015)

6. Harmonised standard

Notified body/ies

Notified body no. 1396 FIRES s.r.o., ul. Osloboditel'ov 282, 059 35 Batizovce.
Certificate of conformity no. CE 1396-CPR-0021

7. Declared performance/s

Essential characteristics	Performance	Harmonized technical	Notes
Reliability performance (number of cycles)	1000	EN12101-1:2005.	-
Type of a smoke barrier	ASB2	EN12101-1:2005.	-
Response time	30 s	EN12101-1:2005.	-
Fire resistance class	D XX	EN12101-1:2005.	-
Air permeability of a barrier	< 9.4 m ³ /h	EN12101-1:2005.	-
Minimal size of a gap	0 mm	EN12101-1:2005.	-

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in

Signed for and on behalf of the manufacturer by:

Tomasz Balicki

Director of the Production Plant in Ciepłowo

on 2023-12-20

Tomasz Balicki