ADDENDUM NO. 3

Project: Meridian Data Centre Campus, Phase 1 | Navi Mumbai, India
Date: June 15, 2026 | Ref: ADD-003-R0

To all prospective bidders, contractors, and vendors, this Addendum is issued to modify and amend the active tender and construction specification documents. The changes detailed below shall supersede the original clauses with immediate effect.

1. Modifications to Technical Specifications

Reference: Section 26 33 53, Part 2.3.4

```
Instruction: DELETE '96%' and INSERT '96.5%'
```

Description: UPS double-conversion efficiency requirement increased from 96.0% to 96.5% at 50%, 75%, and 100% load points.

Reference: Section 23 81 23, Part 2.2.1

```
Instruction: DELETE '10°C entering' and INSERT '11°C entering'
```

Description: CRAH chilled water design entering temperature increased from 10°C to 11°C, reducing cooling plant chiller energy.

2. Impact Summary & Affected Registers

Ingestion of Addendum No. 3 shifts the compliance status of several packages, procurement orders, and testing criteria. The affected elements are detailed in the project bible flips directory.

3. Detailed Ingestion Flips (Audit Trails)

Affected Target	Pre-Addendum Verdict	Post-Addendum Verdict	Technical Reason for Flip
DEV-UPS-R1-ADD3-EFF100	**COMPLIANT**	**DEVIATION**	UPS R1 efficiency at 100% load is 96.2%. Spec is increased from 96.0% to 96.5% under Addendum 3, flipping this parameter non-compliant.
DEV-UPS-R1-ADD3-EFF75	**COMPLIANT**	**DEVIATION**	UPS R1 efficiency at 75% load is 96.0%. Spec is increased from 96.0% to 96.5% under Addendum 3, flipping this parameter non-compliant.
DEV-UPS-R1-ADD3-EFF50	**COMPLIANT**	**DEVIATION**	UPS R1 efficiency at 50% load is 96.2%. Spec is increased from 96.0% to 96.5% under Addendum 3, flipping this parameter non-compliant.
COMP-CRAH-CHW-IN	**COMPLIANT**	**DEVIATION**	CRAH entering water temperature claimed is 10°C. Addendum 3 shifts spec to 11°C entering, making the 10°C unit a deviation.
PO-263353-H1	**VALID**	**INVALID**	UPS modules procured under PO-263353-H1 no longer meet the updated efficiency specification of 96.5%.
PO-263353-H2	**VALID**	**INVALID**	UPS modules procured under PO-263353-H2 no longer meet the updated efficiency specification of 96.5%.
PO-263353-H3	**VALID**	**INVALID**	UPS modules procured under PO-263353-H3 no longer meet the updated efficiency specification of 96.5%.
PO-263353-H4	**VALID**	**INVALID**	UPS modules procured under PO-263353-H4 no longer meet the updated efficiency specification of 96.5%.
PO-238123-H1	**VALID**	**INVALID**	CRAH units procured under PO-238123-H1 are designed for 10°C entering chilled water, but the chilled water loop design has changed to 11°C.
PO-238123-H2	**VALID**	**INVALID**	CRAH units procured under PO-238123-H2 are designed for 10°C entering chilled water, but the chilled water loop design has changed to 11°C.
PO-238123-H3	**VALID**	**INVALID**	CRAH units procured under PO-238123-H3 are designed for 10°C entering chilled water, but the chilled water loop design has changed to 11°C.
PO-238123-H4	**VALID**	**INVALID**	CRAH units procured under PO-238123-H4 are designed for 10°C entering chilled water, but the chilled water loop design has changed to 11°C.
CX-UPS-L5-01	**VALID**	**STALE**	Acceptance criteria of 96.0% efficiency in the UPS L5 test plan is now stale and must be updated to

Affected Target	Pre-Addendum Verdict	Post-Addendum Verdict	Technical Reason for Flip
			96.5%.
CX-CRAH-L4-01	**VALID**	**STALE**	Acceptance criteria of 250 kW capacity at 10°C entering water temp in the CRAH test plan is now stale and must be updated to 11°C entering water temp.