

EQUIPMENT SUBMITTAL

MV Switchgear

Project: Meridian Data Centre Campus - Phase 1

Reference Section: 26 13 26

Package ID: SUB-261326-01-R0

Revision: R0

Reviewed Spec Revision: Rev 2024

Date: 01-01-2025

ACTIVE

Rev	Date	Description
R0	01-01-2025	Initial / Updated Submittal

Technical Parameters

Parameter	Claimed Value
Main Busbar Current	2000 A
Busbar Material	High conductivity copper
Certifications	IEC 62271-200
Current Transformer Accuracy Class	0.5s metering class and 5P20 protection class
Earthing Busbar Material	Copper sized for full short circuit rating
Internal Arc Classification	AFLR
Enclosure IP Rating	IP4X
Lightning Impulse Withstand Voltage (BIL)	75 kV
Loss of Service Continuity	LSC-2B
Rated Short-Circuit Making Capacity	66 kA peak
Short-Circuit Duration	3 s
Short-Circuit Withstand	31.5 kA
Rated Voltage	12 kV
Voltage Transformer Accuracy Class	0.5

Clause ID	Requirement Summary	Response
26 13 26 Part 2.2.1.A	Switchgear rated voltage shall be 12 kV, suitable for the 11 kV nominal system voltage. Rated insula...	Comply
26 13 26 Part 2.2.1.B	Main busbar continuous current rating shall be a minimum of 2000 A at 45°C ambient temperature....	Comply
26 13 26 Part 2.2.2.A	Rated short-time withstand current shall be a minimum of 31.5 kA (rms) for a duration of 3 seconds....	Comply
26 13 26 Part 2.2.2.B	Short-circuit current withstand duration shall be a minimum of 3 seconds. All busbars, connections, ...	Comply
26 13 26 Part 2.3.1.A	Switchgear enclosure external protection shall be a minimum of IP4X per IEC 60529. Internal compartm...	Comply
26 13 26 Part 2.3.1.E	Switchgear shall be classified for Internal Arc Containment (IAC) AFLR (Accessibility: Front, Latera...	Comply
26 13 26 Part 1.4.2	Manufacturer shall provide ASTA or KEMA type test certificates for the switchgear assemblies demonst...	Comply
26 13 26 Part 2.2.3	Rated short-circuit making capacity shall be a minimum of 66 kA peak. Circuit breakers shall have a ...	Comply
26 13 26 Part 2.2.4	Rated lightning impulse withstand voltage (BIL) shall be a minimum of 75 kV (1.2/50 microsecond wave...	Comply
26 13 26 Part 2.3.2.A	Main busbars shall be high conductivity electrolytic copper, silver-plated at all joint surfaces. Bu...	Comply

Clause ID	Requirement Summary	Response
26 13 26 Part 2.3.3.B	Earthing busbar shall be high conductivity copper, continuous throughout the switchgear lineup, and ...	Comply
26 13 26 Part 2.3.7.A	Current transformers shall have metering accuracy class 0.5s and protection accuracy class 5P20. CT ...	Comply
26 13 26 Part 2.3.7.C	Voltage transformers shall have accuracy class 0.5 for metering and 3P for protection. Primary volta...	Comply
26 13 26 Part 1.4.5	Switchgear shall be rated for continuous operation over an ambient temperature range of -5°C to 45°C...	Comply
26 13 26 Part 2.3.1.F	Loss of service continuity classification shall be LSC-2B per IEC 62271-200, ensuring that maintenanc...	Comply

CERTIFICATE OF COMPLIANCE

This certifies that the equipment complies with standard testing requirements.

Issued by: Third Party Testing Laboratory