

# ADD-001 — CONTRACT ADDENDUM

---

Project: MERIDIAN-1 Data Centre, Hall A  
Date: 2026-03-02  
Status: Issued for incorporation

## Change Notice

**Reference:** Section 23 64 26, Part 2.1

**Action:** DELETE 'Minimum full-load COP shall be 6.0.' and INSERT 'Minimum full-load COP shall be 6.3.'

**Clause:** Revised chiller efficiency requirement.

All unaffected requirements remain in force. Contractor shall identify affected calculations, procurement releases, factory tests and commissioning scripts.

## Change Notice

**Reference:** Section 26 33 53, Part 2.7

**Action:** DELETE 'Test efficiency in accordance with IEC 62040-3.' and INSERT 'Test efficiency in accordance with IEC 62040-3:2021 at 0.9 lagging power factor; unity-power-factor data may be supplementary only.'

**Clause:** Clarified UPS test condition.

All unaffected requirements remain in force. Contractor shall identify affected calculations, procurement releases, factory tests and commissioning scripts.