

ADD-002 — CONTRACT ADDENDUM

Project: MERIDIAN-1 Data Centre, Hall A
Date: 2026-05-11
Status: Issued for incorporation

Change Notice

Reference: Section 23 65 00, Part 2.4

Action: DELETE 'Sound pressure shall not exceed 84 dBA at 1 m.' and INSERT 'Sound pressure shall not exceed 82 dBA at 1 m.'

Clause: Revised cooling-tower acoustics.

All unaffected requirements remain in force. Contractor shall identify affected calculations, procurement releases, factory tests and commissioning scripts.

Change Notice

Reference: Section 27 15 00, Part 2.4

Action: DELETE 'Cable fire performance shall be Cca-s1,d1,a1.' and INSERT 'Cable fire performance shall be B2ca-s1a,d1,a1.'

Clause: Enhanced cable fire class.

All unaffected requirements remain in force. Contractor shall identify affected calculations, procurement releases, factory tests and commissioning scripts.