

CryoCore Climate

THERMODYNAMIC PERFORMANCE BULLETIN • SAP 0000101877

Technical Submittal

R1 — FOR TECHNICAL REVIEW

1,250 TR chiller revised after ADD-001

Package ID	SUB-236426-01-R1
Reference Section	23 64 26
Reviewed Spec Revision	Rev C, including ADD-001
Project	MERIDIAN-1 Data Centre, Hall A
Submitted	2026-04-14

CryoCore Climate

THERMODYNAMIC PERFORMANCE BULLETIN • SAP 0000101877

Transmittal and Document Register

No.	Document	Document reference	Rev.	Purpose
1	Technical schedule	SUB-236426-01-R1-01	R1	Technical review
2	Compliance statement	SUB-236426-01-R1-02	R1	Technical review
3	Certified performance data	SUB-236426-01-R1-03	R1	Technical review
4	Type-test evidence	SUB-236426-01-R1-04	R1	Technical review
5	Material traceability	SUB-236426-01-R1-05	R1	Technical review
6	Inspection and test plan	SUB-236426-01-R1-06	R1	Technical review

Revision note: Resubmission superseding R0. Review comments and applicable addendum requirements have been incorporated.

CryoCore Climate

THERMODYNAMIC PERFORMANCE BULLETIN • SAP 0000101877

Equipment Technical Schedule

Clause	Scheduled parameter	Specified	Offered
2.1.C	Full-load COP	6.3	86 dBA at 1 m
2.2.B	Cooling duty	1250 TR	evidence available on request
2.3.D	Evaporator pressure drop	85 kPa	traceability reference absent from material master
3.4.C	Sound pressure at 1 m	88 dBA	88 dBA

Design conditions

Electrical supply	415 V, 3-phase, 50 Hz unless scheduled otherwise
Site	Navi Mumbai, India
Maximum ambient	40 °C indoor design basis
Controls	Hardwired safety; BACnet/IP or Modbus TCP supervisory interface

Selections are project-specific. Catalogue ratings at other conditions are not substituted for scheduled duty.

CryoCore Climate

THERMODYNAMIC PERFORMANCE BULLETIN • SAP 0000101877

Clause-by-Clause Compliance Statement

Clause	Requirement	Submitted basis	Status
2.1.C	Full-load COP shall be not less than 6.3 .	6.3	COMPLIES
2.2.B	Cooling duty shall be not less than 1250 TR .	evidence available on request	EXCEPTION
2.3.D	Evaporator pressure drop shall not exceed 85 kPa .	85 kPa	COMPLIES
3.4.C	Sound pressure at 1 m shall not exceed 88 dBA .	86 dBA at 1 m	EXCEPTION

Status is based on the evidence in this package. “Complies” does not waive specified witness testing.

CryoCore Climate

THERMODYNAMIC PERFORMANCE BULLETIN • SAP 0000101877

Type-Test and Performance Evidence

Clause	Characteristic	Evidence statement	Record
3.4.C	Sound pressure at 1 m	86 dBA at 1 m	datasheet
2.2.B	Cooling duty	evidence available on request	matrix
3.4.C	Sound pressure at 1 m	traceability reference absent from material master	hexagon

Evidence controls

Certificates shall identify laboratory, standard edition, test object, rating, construction, date and authorised signatory. Similarity claims require an engineering comparison.

CryoCore Climate

THERMODYNAMIC PERFORMANCE BULLETIN • SAP 0000101877

Material and Component Traceability

Material and component records are indexed by equipment tag, purchase order, serial number and source lot.

Item	Trace reference	Inspection
Primary assembly	SUB-236426-01-R1-MTR-01	Incoming inspection accepted
Safety-critical components	SUB-236426-01-R1-SCC-01	Certificate review required
Labels and terminals	SUB-236426-01-R1-ID-01	100% visual check

CryoCore Climate

THERMODYNAMIC PERFORMANCE BULLETIN • SAP 0000101877

Factory Inspection and Test Plan

Seq.	Inspection / test	Acceptance	Point	Record
10	Document and drawing review	Approved data	R	Review sheet
20	Incoming material inspection	Approved BOM and certificates	W	Material report
30	Assembly and workmanship	Approved drawings	S	Inspection checklist
40	Rated functional test	Section 23 64 26	H	FAT record
50	Final inspection and release	No open major NCR	W	Release note

H = hold, W = witness, R = review, S = surveillance. Give seven calendar days' notice for witness and hold points.

CryoCore Climate

THERMODYNAMIC PERFORMANCE BULLETIN • SAP 0000101877

Exceptions, Declarations and Sign-Off

Declared exceptions

Exceptions are identified in the compliance statement and require Engineer disposition before release for manufacture.

Manufacturer declaration

We certify that this package is prepared for MER-1-2026 and that the offered construction will not be changed without formal resubmission.

Prepared by: Package Engineer

Approved by: Engineering Manager

Date: 14 April 2026

Document status: Technical review