

# Indus Thermal Works

HEAT-REJECTION TECHNICAL FOLIO • SAP 0000117358

## Technical Submittal

R0 — FOR TECHNICAL REVIEW

### Open-circuit cooling towers

|                        |                                |
|------------------------|--------------------------------|
| Package ID             | SUB-236500-01-R0               |
| Reference Section      | 23 65 00                       |
| Reviewed Spec Revision | Rev C, including ADD-002       |
| Project                | MERIDIAN-1 Data Centre, Hall A |
| Submitted              | 2026-03-18                     |

# Indus Thermal Works

HEAT-REJECTION TECHNICAL FOLIO • SAP 0000117358

## Transmittal and Document Register

| No. | Document                   | Document reference  | Rev. | Purpose          |
|-----|----------------------------|---------------------|------|------------------|
| 1   | Technical schedule         | SUB-236500-01-R0-01 | R0   | Technical review |
| 2   | Compliance statement       | SUB-236500-01-R0-02 | R0   | Technical review |
| 3   | Certified performance data | SUB-236500-01-R0-03 | R0   | Technical review |
| 4   | Type-test evidence         | SUB-236500-01-R0-04 | R0   | Technical review |
| 5   | Material traceability      | SUB-236500-01-R0-05 | R0   | Technical review |
| 6   | Inspection and test plan   | SUB-236500-01-R0-06 | R0   | Technical review |

**Revision note:** Initial submission. Any departure is identified in the compliance schedule and shall not be inferred from catalogue data.

# Indus Thermal Works

HEAT-REJECTION TECHNICAL FOLIO • SAP 0000117358

## Equipment Technical Schedule

| Clause | Scheduled parameter   | Specified   | Offered                                    |
|--------|-----------------------|-------------|--------------------------------------------|
| 2.1.B  | Thermal capacity      | 4500 kW     | 4,280 kW                                   |
| 2.2.C  | Fan specific power    | 0.028 kW/kW | declared at unity power factor             |
| 2.4.A  | Sound pressure at 1 m | 82 dBA      | certificate value conflicts with datasheet |
| 3.3.B  | Vibration velocity    | 4.5 mm/s    | 4.5 mm/s                                   |

### Design conditions

|                   |                                                                 |
|-------------------|-----------------------------------------------------------------|
| Electrical supply | 415 V, 3-phase, 50 Hz unless scheduled otherwise                |
| Site              | Navi Mumbai, India                                              |
| Maximum ambient   | 40 °C indoor design basis                                       |
| Controls          | Hardwired safety; BACnet/IP or Modbus TCP supervisory interface |

Selections are project-specific. Catalogue ratings at other conditions are not substituted for scheduled duty.

# Indus Thermal Works

HEAT-REJECTION TECHNICAL FOLIO • SAP 0000117358

## Clause-by-Clause Compliance Statement

| Clause | Requirement                                              | Submitted basis                | Status    |
|--------|----------------------------------------------------------|--------------------------------|-----------|
| 2.1.B  | Thermal capacity shall be not less than <b>4500 kW</b> . | 4,280 kW                       | EXCEPTION |
| 2.2.C  | Fan specific power shall not exceed <b>0.028 kW/kW</b> . | 0.028 kW/kW                    | COMPLIES  |
| 2.4.A  | Sound pressure at 1 m shall not exceed <b>82 dBA</b> .   | declared at unity power factor | EXCEPTION |
| 3.3.B  | Vibration velocity shall not exceed <b>4.5 mm/s</b> .    | 4.5 mm/s                       | COMPLIES  |

Status is based on the evidence in this package. “Complies” does not waive specified witness testing.

# Indus Thermal Works

HEAT-REJECTION TECHNICAL FOLIO • SAP 0000117358

## Type-Test and Performance Evidence

| Clause | Characteristic        | Evidence statement                         | Record      |
|--------|-----------------------|--------------------------------------------|-------------|
| 2.1.B  | Thermal capacity      | 4,280 kW                                   | datasheet   |
| 2.4.A  | Sound pressure at 1 m | declared at unity power factor             | datasheet   |
| 2.1.B  | Thermal capacity      | certificate value conflicts with datasheet | certificate |

### Evidence controls

Certificates shall identify laboratory, standard edition, test object, rating, construction, date and authorised signatory. Similarity claims require an engineering comparison.

# Indus Thermal Works

HEAT-REJECTION TECHNICAL FOLIO • SAP 0000117358

## Material and Component Traceability

Material and component records are indexed by equipment tag, purchase order, serial number and source lot.

| Item                       | Trace reference         | Inspection                   |
|----------------------------|-------------------------|------------------------------|
| Primary assembly           | SUB-236500-01-R0-MTR-01 | Incoming inspection accepted |
| Safety-critical components | SUB-236500-01-R0-SCC-01 | Certificate review required  |
| Labels and terminals       | SUB-236500-01-R0-ID-01  | 100% visual check            |

# Indus Thermal Works

HEAT-REJECTION TECHNICAL FOLIO • SAP 0000117358

## Factory Inspection and Test Plan

| Seq. | Inspection / test            | Acceptance                    | Point | Record               |
|------|------------------------------|-------------------------------|-------|----------------------|
| 10   | Document and drawing review  | Approved data                 | R     | Review sheet         |
| 20   | Incoming material inspection | Approved BOM and certificates | W     | Material report      |
| 30   | Assembly and workmanship     | Approved drawings             | S     | Inspection checklist |
| 40   | Rated functional test        | Section 23 65 00              | H     | FAT record           |
| 50   | Final inspection and release | No open major NCR             | W     | Release note         |

H = hold, W = witness, R = review, S = surveillance. Give seven calendar days' notice for witness and hold points.

# Indus Thermal Works

HEAT-REJECTION TECHNICAL FOLIO • SAP 0000117358

## Exceptions, Declarations and Sign-Off

### Declared exceptions

Exceptions are identified in the compliance statement and require Engineer disposition before release for manufacture.

### Manufacturer declaration

We certify that this package is prepared for MER-1-2026 and that the offered construction will not be changed without formal resubmission.

Prepared by: Package Engineer

Approved by: Engineering Manager

Date: 18 March 2026

Document status: Technical review