

Indus Thermal Works

HEAT-REJECTION TECHNICAL FOLIO • SAP 0000117358

Technical Submittal

R1 — FOR TECHNICAL REVIEW

Cooling tower revised acoustics

Package ID	SUB-236500-01-R1
Reference Section	23 65 00
Reviewed Spec Revision	Rev C, including ADD-002
Project	MERIDIAN-1 Data Centre, Hall A
Submitted	2026-04-14

Indus Thermal Works

HEAT-REJECTION TECHNICAL FOLIO • SAP 0000117358

Transmittal and Document Register

No.	Document	Document reference	Rev.	Purpose
1	Technical schedule	SUB-236500-01-R1-01	R1	Technical review
2	Compliance statement	SUB-236500-01-R1-02	R1	Technical review
3	Certified performance data	SUB-236500-01-R1-03	R1	Technical review
4	Type-test evidence	SUB-236500-01-R1-04	R1	Technical review
5	Material traceability	SUB-236500-01-R1-05	R1	Technical review
6	Inspection and test plan	SUB-236500-01-R1-06	R1	Technical review

Revision note: Resubmission superseding R0. Review comments and applicable addendum requirements have been incorporated.

Indus Thermal Works

HEAT-REJECTION TECHNICAL FOLIO • SAP 0000117358

Equipment Technical Schedule

Clause	Scheduled parameter	Specified	Offered
2.1.B	Thermal capacity	4500 kW	above requirement
2.2.C	Fan specific power	0.028 kW/kW	test temperature differs from scheduled duty
2.4.A	Sound pressure at 1 m	82 dBA	mail commitment conflicts with programme
3.3.B	Vibration velocity	4.5 mm/s	4.5 mm/s

Design conditions

Electrical supply	415 V, 3-phase, 50 Hz unless scheduled otherwise
Site	Navi Mumbai, India
Maximum ambient	40 °C indoor design basis
Controls	Hardwired safety; BACnet/IP or Modbus TCP supervisory interface

Selections are project-specific. Catalogue ratings at other conditions are not substituted for scheduled duty.

Indus Thermal Works

HEAT-REJECTION TECHNICAL FOLIO • SAP 0000117358

Clause-by-Clause Compliance Statement

Clause	Requirement	Submitted basis	Status
2.1.B	Thermal capacity shall be not less than 4500 kW .	4500 kW	COMPLIES
2.2.C	Fan specific power shall not exceed 0.028 kW/kW .	above requirement	EXCEPTION
2.4.A	Sound pressure at 1 m shall not exceed 82 dBA .	82 dBA	COMPLIES
3.3.B	Vibration velocity shall not exceed 4.5 mm/s .	test temperature differs from scheduled duty	EXCEPTION

Status is based on the evidence in this package. “Complies” does not waive specified witness testing.

Indus Thermal Works

HEAT-REJECTION TECHNICAL FOLIO • SAP 0000117358

Type-Test and Performance Evidence

Clause	Characteristic	Evidence statement	Record
2.2.C	Fan specific power	above requirement	datasheet
3.3.B	Vibration velocity	test temperature differs from scheduled duty	factory test plan
2.2.C	Fan specific power	mail commitment conflicts with programme	aconex

Evidence controls

Certificates shall identify laboratory, standard edition, test object, rating, construction, date and authorised signatory. Similarity claims require an engineering comparison.

Indus Thermal Works

HEAT-REJECTION TECHNICAL FOLIO • SAP 0000117358

Material and Component Traceability

Material and component records are indexed by equipment tag, purchase order, serial number and source lot.

Item	Trace reference	Inspection
Primary assembly	SUB-236500-01-R1-MTR-01	Incoming inspection accepted
Safety-critical components	SUB-236500-01-R1-SCC-01	Certificate review required
Labels and terminals	SUB-236500-01-R1-ID-01	100% visual check

Indus Thermal Works

HEAT-REJECTION TECHNICAL FOLIO • SAP 0000117358

Factory Inspection and Test Plan

Seq.	Inspection / test	Acceptance	Point	Record
10	Document and drawing review	Approved data	R	Review sheet
20	Incoming material inspection	Approved BOM and certificates	W	Material report
30	Assembly and workmanship	Approved drawings	S	Inspection checklist
40	Rated functional test	Section 23 65 00	H	FAT record
50	Final inspection and release	No open major NCR	W	Release note

H = hold, W = witness, R = review, S = surveillance. Give seven calendar days' notice for witness and hold points.

Indus Thermal Works

HEAT-REJECTION TECHNICAL FOLIO • SAP 0000117358

Exceptions, Declarations and Sign-Off

Declared exceptions

Exceptions are identified in the compliance statement and require Engineer disposition before release for manufacture.

Manufacturer declaration

We certify that this package is prepared for MER-1-2026 and that the offered construction will not be changed without formal resubmission.

Prepared by: Package Engineer

Approved by: Engineering Manager

Date: 14 April 2026

Document status: Technical review