

Meridian Switchgear

CERTIFICATION-LED ASSEMBLY RECORD • SAP 0000110051

Technical Submittal

R0 — FOR TECHNICAL REVIEW

Main LV switchboard MSB-A

Package ID	SUB-262413-01-R0
Reference Section	26 24 13
Reviewed Spec Revision	Rev C
Project	MERIDIAN-1 Data Centre, Hall A
Submitted	2026-03-18

Meridian Switchgear

CERTIFICATION-LED ASSEMBLY RECORD • SAP 0000110051

Transmittal and Document Register

No.	Document	Document reference	Rev.	Purpose
1	Technical schedule	SUB-262413-01-R0-01	R0	Technical review
2	Compliance statement	SUB-262413-01-R0-02	R0	Technical review
3	Certified performance data	SUB-262413-01-R0-03	R0	Technical review
4	Type-test evidence	SUB-262413-01-R0-04	R0	Technical review
5	Material traceability	SUB-262413-01-R0-05	R0	Technical review
6	Inspection and test plan	SUB-262413-01-R0-06	R0	Technical review

Revision note: Initial submission. Any departure is identified in the compliance schedule and shall not be inferred from catalogue data.

Meridian Switchgear

CERTIFICATION-LED ASSEMBLY RECORD • SAP 0000110051

Equipment Technical Schedule

Clause	Scheduled parameter	Specified	Offered
2.2.D	Short-circuit withstand	65 kA for 1 s	50 kA for 1 s
2.3.A	Rated operational voltage	415 V	declared at unity power factor
2.4.C	Busbar temperature rise	70 K	certificate value conflicts with datasheet
3.5.B	Dielectric withstand	2.5 kV for 60 s	2.5 kV for 60 s

Design conditions

Electrical supply	415 V, 3-phase, 50 Hz unless scheduled otherwise
Site	Navi Mumbai, India
Maximum ambient	40 °C indoor design basis
Controls	Hardwired safety; BACnet/IP or Modbus TCP supervisory interface

Selections are project-specific. Catalogue ratings at other conditions are not substituted for scheduled duty.

Meridian Switchgear

CERTIFICATION-LED ASSEMBLY RECORD • SAP 0000110051

Clause-by-Clause Compliance Statement

Clause	Requirement	Submitted basis	Status
2.2.D	Short-circuit withstand shall be not less than 65 kA for 1 s .	50 kA for 1 s	EXCEPTION
2.3.A	Rated operational voltage shall be 415 V .	415 V	COMPLIES
2.4.C	Busbar temperature rise shall not exceed 70 K .	declared at unity power factor	EXCEPTION
3.5.B	Dielectric withstand shall be not less than 2.5 kV for 60 s .	2.5 kV for 60 s	COMPLIES

Status is based on the evidence in this package. “Complies” does not waive specified witness testing.

Meridian Switchgear

CERTIFICATION-LED ASSEMBLY RECORD • SAP 0000110051

Type-Test and Performance Evidence

Clause	Characteristic	Evidence statement	Record
2.2.D	Short-circuit withstand	50 kA for 1 s	datasheet
2.4.C	Busbar temperature rise	declared at unity power factor	datasheet
2.2.D	Short-circuit withstand	certificate value conflicts with datasheet	certificate

Type-test scope: Certificate MS-IEC-61439-22 records 50 kA for 1 s for the tested assembly.

Evidence controls

Certificates shall identify laboratory, standard edition, test object, rating, construction, date and authorised signatory. Similarity claims require an engineering comparison.

Meridian Switchgear

CERTIFICATION-LED ASSEMBLY RECORD • SAP 0000110051

Material and Component Traceability

Material and component records are indexed by equipment tag, purchase order, serial number and source lot.

Item	Trace reference	Inspection
Primary assembly	SUB-262413-01-R0-MTR-01	Incoming inspection accepted
Safety-critical components	SUB-262413-01-R0-SCC-01	Certificate review required
Labels and terminals	SUB-262413-01-R0-ID-01	100% visual check

Meridian Switchgear

CERTIFICATION-LED ASSEMBLY RECORD • SAP 0000110051

Factory Inspection and Test Plan

Seq.	Inspection / test	Acceptance	Point	Record
10	Document and drawing review	Approved data	R	Review sheet
20	Incoming material inspection	Approved BOM and certificates	W	Material report
30	Assembly and workmanship	Approved drawings	S	Inspection checklist
40	Rated functional test	Section 26 24 13	H	FAT record
50	Final inspection and release	No open major NCR	W	Release note

H = hold, W = witness, R = review, S = surveillance. Give seven calendar days' notice for witness and hold points.

Meridian Switchgear

CERTIFICATION-LED ASSEMBLY RECORD • SAP 0000110051

Exceptions, Declarations and Sign-Off

Declared exceptions

Exceptions are identified in the compliance statement and require Engineer disposition before release for manufacture.

Manufacturer declaration

We certify that this package is prepared for MER-1-2026 and that the offered construction will not be changed without formal resubmission.

Prepared by: Package Engineer

Approved by: Engineering Manager

Date: 18 March 2026

Document status: Technical review