

SUBMITTAL TRANSMITTAL

Package ID: SUB-212200-01 · Revision: R0 · Date: 2026-03-20
Reference Section: 21 22 00 — Clean-Agent Fire Suppression
Reviewed Spec Revision: Issued for Construction Rev 0
Vendor: AegisFire Systems Pvt Ltd · Equipment: FK-5-1-12 Total Flooding System, Hall A
Declared deviations: NONE

AegisFire AF-5112 System — Design Summary

Parameter	Value
Agent	FK-5-1-12, virgin agent, UL 2166 listed hardware
Protected volume (data hall enclosure)	2,450 cubic metres
Discharge time to 95% design concentration	11 seconds, using AF-EDN-40 extended-discharge nozzles per UL 2166 listing; hydraulic calculation AF-HC-118 attached
Design concentration (Class C)	5.8%
Predicted peak enclosure pressure	22 Pa with relief venting as designed
Cylinder charging pressure	24.8 bar at 21 °C

Room integrity: door-fan test procedure per NFPA 2001 Annex C included, target retention 10 minutes.