

SUBMITTAL TRANSMITTAL

Package ID: SUB-236426-01 · Revision: R0 · Date: 2026-03-10
Reference Section: 23 64 26 — Water-Cooled Centrifugal Chillers
Reviewed Spec Revision: Issued for Construction Rev 0
Vendor: CryoCore Climate Pvt Ltd · Equipment: CC-1200 Chillers (CH-A1, CH-A2)
Declared deviations: NONE

CryoCore CC-1200 — Selection Data at AHRI 550/590 Conditions

Parameter	Value
Cooling capacity	1210 TR, zero fouling allowance deducted
COP at 100% load	6.1
Sound pressure at 1 m (AHRI 575)	83 dBA
Refrigerant	R-1233zd(E), GWP 1
Shaft vibration, all load points	3.6 mils peak-to-peak (ISO 10816-3)

Weld inspection plan: WPS/PQR per ASME B31.9 with 10 percent RT at chiller connections; acceptance zero porosity. Plan document CC-WIP-09 attached.