

ADDENDUM NO. 1

Project: Meridian Data Centre Campus - Phase 1

Date: 2026-06-15

Subject: Clarifications and revisions to specification requirements

This addendum modifies the following specification clauses. All other requirements remain unchanged.

Section	Clause	Change	Reason
26 33 53	Part 2.3.4	UPS double-conversion efficiency minimum revised from 96.0% to 96.5% at all load points (50%, 75%, 100%).	Updated energy efficiency target per ASHRAE 90.1-2025.
23 81 23	Part 2.2.1	Entering chilled water temperature revised from 10°C to 11°C. Leaving chilled water temperature remains 18°C.	Revised per chiller optimization study and RFI-238123-01.
26 32 13	Part 2.3.8.C	Day tank maximum capacity revised from 1040 L to 990 L.	Compliance with local NBC fire code and RFI-263213-01.

Effect on Schedule: These changes affect the critical path through chiller delivery and commissioning sequence. All affected POs shall be re-issued to reflect updated requirements.

Issued by: Consultant Project Manager

Status: This addendum becomes part of the contract documents upon issuance.