

EQUIPMENT SUBMITTAL

CoolWave CW-350 Chiller

Project: Meridian Data Centre Campus - Phase 1
Reference Section: 23 64 26
Package ID: SUB-236426-02-R0
Revision: R0
Reviewed Spec Revision: Rev 2024
Date: 01-03-2025

ACTIVE

Rev	Date	Description
R0	01-03-2025	Initial Submittal

Product Technical Parameters

Parameter	Claimed Value
Model	CoolWave CW-350 Chiller
Rated Capacity	See performance table
Operating Voltage	415 V / 3-phase / 50 Hz
Ambient Temperature Range	0°C to 40°C
Efficiency at Full Load	96.0%
Efficiency at 75% Load	95.5%
Efficiency at 50% Load	94.8%
Enclosure Rating	IP20
Enclosure Paint Finish	RAL 7035
Cooling Method	Forced air, front-to-top exhaust
Noise Level at 1 m	72 dBA
Weight	1800 kg
Dimensions (W x D x H)	1200 x 950 x 1950 mm
Manufacturing Certifications	ISO 9001, ISO 14001

¹ Evaporator approach temperature of 1.4°C maintained only with clean tubes; with fouling factor of 0.0001 m²K/W approach increases to 2.0°C

Clause ID	Requirement Summary	Response
23 64 26 Part 1.1.1.A	Section scope of work requirements	Comply
23 64 26 Part 1.2.1.A	Compliance with applicable standards	Comply
23 64 26 Part 1.3.1	Correct specification revision referenced	Comply
23 64 26 Part 1.3.2.A	Submittal documentation completeness	Comply
23 64 26 Part 1.4.1.A	Manufacturer experience requirements	Comply
23 64 26 Part 1.4.1.B	ISO certifications	Comply
23 64 26 Part 2.1.1.A	Acceptable manufacturer listing	Comply
23 64 26 Part 2.1.2.A	N+1 configuration	Comply
23 64 26 Part 2.2.1.A	Performance standards compliance	Comply
23 64 26 Part 2.3.1.A	Enclosure construction requirements	Comply
23 64 26 Part 2.3.2.A	Paint finish requirements	Comply
23 64 26 Part 3.4.1.A	Functional test requirements	Comply

CERTIFICATE OF COMPLIANCE

This certifies that the equipment described herein complies with the applicable testing and performance requirements.

Issued by: CoolWave Quality Assurance

Certificate No: QA-9279-716

Date: 15-11-2024